

SHENZHEN, China

WMO: 594930

Lat: 22.5417N

Lon: 114.0033E

Elev: 4

StdP: 101.28

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.2	8.8	-6.0	2.3	12.9	-2.9	3.0	13.1	8.2	12.3	7.4	12.7	4.5	20	0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	34.0	26.4	33.1	26.4	32.3	26.3	28.9	31.2	28.4	30.6	27.9	30.2	3.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.2	24.4	30.3	28.0	24.1	30.1	27.2	22.9	29.8	94.8	31.4	92.2	30.5	90.0	30.7	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.1	7.2	6.4	DB	5.6	36.3	1.9	1.0	4.2	37.1	3.0	37.7	2.0	38.3	0.5	39.0	
			WB	1.8	29.4	1.9	0.9	0.5	30.1	-0.6	30.7	-1.7	31.2	-3.0	31.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.9	16.1	17.2	19.9	23.7	26.8	28.7	29.5	29.3	28.5	26.3	22.3	17.7
	DBStd	5.55	3.62	4.21	3.40	2.85	2.06	1.57	1.40	1.51	1.71	2.02	3.01	3.29
	HDD10.0	6	3	3	0	0	0	0	0	0	0	0	0	1
	HDD18.3	236	87	65	24	3	0	0	0	0	0	0	6	51
	CDD10.0	5067	192	204	308	412	522	561	604	598	555	505	368	238
	CDD18.3	2254	17	33	73	165	264	311	346	340	305	247	124	31
	CDH23.3	22460	18	58	201	952	2536	3700	4383	4256	3543	2158	597	58
CDH26.7	8261	1	3	13	154	743	1463	1966	1864	1386	583	84	2	
Wind	WSAvg	3.2	3.1	3.0	3.0	3.1	3.3	3.5	3.5	3.1	3.0	3.1	3.1	3.2
Precipitation	PrecAvg	1806	27	46	73	164	241	302	299	312	189	73	33	29
	PrecMax	2988	103	228	545	377	722	768	591	878	491	614	156	178
	PrecMin	947	0	0	1	3	8	0	2	50	7	0	0	0
	PrecStd	499	29	63	110	101	200	163	164	175	129	124	44	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	26.9	28.1	30.4	33.0	34.0	35.1	35.2	34.2	32.9	30.1	26.6
		MCWB	20.0	21.3	22.8	24.7	25.8	26.0	27.2	26.5	25.6	24.5	22.2	20.7
	2%	DB	23.4	25.0	26.6	29.2	31.7	32.7	33.8	33.9	33.2	31.2	28.8	25.0
		MCWB	18.7	20.5	22.3	24.4	25.8	26.5	26.9	26.6	25.6	23.8	22.1	19.6
	5%	DB	22.0	23.8	25.2	28.3	30.8	32.0	32.9	33.0	32.2	30.3	27.6	23.6
		MCWB	17.7	19.9	21.5	24.1	25.7	26.7	26.8	26.7	25.4	23.4	21.6	18.6
	10%	DB	20.9	22.3	24.2	27.4	29.9	31.2	32.0	32.1	31.4	29.5	26.4	22.2
		MCWB	17.0	18.9	20.9	23.8	25.6	26.9	26.9	26.7	25.4	23.1	20.9	17.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	22.7	24.6	27.1	28.4	29.4	29.7	29.6	28.5	27.1	24.9	22.7
		MCDB	23.8	25.3	26.4	28.3	30.3	31.4	32.1	31.9	30.9	29.8	27.5	24.8
	2%	WB	19.8	21.6	23.3	25.9	27.6	28.6	28.9	28.7	27.7	26.2	23.8	21.2
		MCDB	22.3	24.1	25.4	27.8	29.5	30.6	31.2	31.2	30.3	29.0	26.9	23.5
	5%	WB	18.8	20.6	22.4	25.1	27.0	28.1	28.2	28.2	27.1	25.6	23.1	19.9
		MCDB	21.2	23.0	24.7	27.2	29.2	30.0	30.6	30.6	30.1	28.5	26.2	22.7
	10%	WB	17.7	19.5	21.5	24.4	26.4	27.6	27.7	27.6	26.6	24.8	22.3	18.5
		MCDB	20.2	21.9	23.8	26.7	28.8	29.8	30.3	30.4	29.7	28.0	25.4	21.6
Mean Daily Temperature Range	5% DB	MDBR	6.7	6.3	6.1	5.7	5.5	5.0	5.4	5.6	5.9	6.3	6.8	6.9
		MCDBR	8.0	7.9	7.2	6.5	6.3	5.6	6.2	6.7	6.7	6.8	7.3	8.1
		MCWBR	4.5	4.4	4.1	3.5	3.3	2.9	2.9	3.2	3.1	3.3	3.5	4.3
	5% WB	MCDBR	7.2	7.0	6.4	5.8	5.3	4.9	5.4	5.9	5.9	5.9	6.2	6.8
MCWBR		4.5	4.3	4.1	3.8	3.4	3.2	3.4	3.6	3.2	3.2	3.7	4.3	
Clear-Sky Solar Irradiance	taub		0.592	0.644	0.775	0.753	0.594	0.559	0.546	0.613	0.648	0.693	0.586	0.575
	taud		1.783	1.712	1.502	1.580	1.945	2.050	2.082	1.884	1.786	1.650	1.858	1.841
	Ebn at Noon		668	666	604	631	737	756	767	718	682	620	669	663
	Edh at Noon		201	229	295	276	191	170	165	201	219	241	185	184
All-Sky Solar Radiation	RadAvg		3.08	3.12	3.32	3.63	4.39	4.52	5.30	4.97	4.68	4.37	3.56	3.23
	RadStd		0.50	0.49	0.45	0.58	0.59	0.67	0.56	0.44	0.33	0.44	0.41	0.48

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (13 neighbors)	N/A	N/A	N/A	+0.25	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page