

SHANWEI, China

WMO: 595010

Lat: 22.7917N

Lon: 115.3606E

Elev: 58

StdP: 14.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.4	48.7	21.9	16.5	54.6	29.4	23.5	55.3	17.1	54.4	14.4	57.2	6.8	20	0.314

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	90.5	79.2	89.3	79.2	88.2	79.3	82.7	86.4	81.9	85.8	81.4	85.4	7.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.7	165.0	85.0	80.9	160.8	84.6	80.3	157.4	84.3	46.7	86.7	46.0	86.0	45.3	85.6	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.5	13.4	11.8	43.2	94.3	3.3	1.8	40.9	95.6	38.9	96.6	37.1	97.6	34.7	98.9
			35.6	83.4	3.9	1.1	32.8	84.2	30.5	84.8	28.3	85.4	25.4	86.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.5	60.3	61.6	65.8	72.5	78.1	82.0	83.4	83.3	82.1	77.8	71.3	63.5
	DBStd	9.48	5.37	6.29	5.42	4.90	3.73	3.01	2.28	2.43	2.68	3.29	4.73	5.28
	HDD50	7	3	3	0	0	0	0	0	0	0	0	0	1
	HDD65	446	160	125	57	7	0	0	0	0	0	0	9	88
	CDD50	8598	323	328	491	674	870	959	1037	1032	963	862	638	421
	CDD65	3561	15	30	82	231	405	509	572	567	513	397	197	43
	CDH74	33143	15	34	144	1013	3303	5682	6930	6740	5588	2936	702	56
	CDH80	10402	0	0	5	85	691	1898	2673	2528	1856	597	68	1
Wind	WSAvg	5.7	5.4	5.4	5.3	5.4	5.8	6.5	6.2	5.8	5.7	5.7	5.6	5.5
Precipitation	PrecAvg	71.1	1.0	1.8	3.0	6.7	11.4	13.5	11.9	11.1	7.3	2.5	1.3	1.1
	PrecMax	116.3	3.6	10.5	16.5	22.5	29.6	40.4	23.9	23.5	21.9	15.9	6.0	4.9
	PrecMin	35.2	0.0	0.0	0.0	0.1	0.6	1.7	1.8	1.4	0.5	0.0	0.0	0.0
	PrecStd	18.4	0.9	2.4	3.6	5.0	6.8	7.4	6.4	5.4	6.0	3.9	1.6	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.3	77.4	79.9	84.3	87.9	90.0	92.4	92.4	91.6	88.9	84.5	78.8
		MCWB	67.2	68.7	72.8	76.1	79.0	80.1	80.7	79.8	77.4	75.8	72.3	69.2
	2%	DB	72.5	74.8	77.4	82.3	86.2	88.5	89.9	90.4	89.7	86.6	82.0	75.3
		MCWB	64.2	67.7	70.7	75.4	78.5	80.1	80.0	79.7	77.6	75.1	71.7	66.3
	5%	DB	69.9	72.4	75.5	80.7	84.9	87.5	88.7	89.1	88.4	84.9	79.9	72.9
		MCWB	62.2	66.3	69.3	74.8	78.3	80.1	80.0	79.7	77.6	74.1	70.4	65.0
	10%	DB	67.7	69.9	73.4	79.2	83.6	86.5	87.7	87.9	87.1	83.4	78.0	70.9
		MCWB	61.0	64.1	67.3	74.0	77.9	80.1	80.1	79.7	77.4	73.3	69.4	63.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.5	71.8	74.9	79.0	82.2	83.4	83.7	83.6	81.9	79.0	75.5	72.5
		MCDB	73.6	74.1	78.4	82.0	84.8	86.3	87.8	87.2	86.5	84.5	80.3	76.6
	2%	WB	66.3	69.7	72.8	77.4	81.1	82.5	82.5	82.4	80.9	77.8	74.2	69.6
		MCDB	70.9	73.6	75.9	80.2	83.9	85.7	86.6	86.7	85.5	83.4	79.2	73.1
	5%	WB	64.1	67.5	71.0	76.3	80.2	81.8	81.8	81.6	80.1	76.7	72.8	66.8
		MCDB	68.5	71.0	74.1	79.2	83.3	85.2	86.0	86.0	84.8	82.5	78.1	71.5
	10%	WB	62.3	65.3	69.1	75.1	79.2	81.1	81.2	80.9	79.4	75.7	71.3	64.8
		MCDB	66.6	69.2	72.2	78.2	82.6	84.8	85.5	85.3	84.2	81.3	76.4	69.4
Mean Daily Temperature Range	5% DB	MDBR	10.7	9.6	9.2	8.2	7.7	6.4	7.3	7.7	8.9	10.1	11.0	11.1
		MCDBR	12.4	12.4	11.3	9.4	8.8	7.6	8.8	9.8	10.4	11.2	11.9	12.3
		MCWBR	6.8	7.1	6.6	4.8	3.9	2.8	3.2	3.6	3.9	4.6	5.6	6.5
	5% WB	MCDBR	10.7	10.5	9.4	7.7	6.8	6.1	7.5	8.0	8.5	9.5	9.9	10.4
		MCWBR	6.8	7.4	6.6	4.7	3.9	3.1	3.5	4.0	3.6	4.1	5.4	6.8
Clear-Sky Solar Irradiance	taub	0.555	0.617	0.740	0.723	0.567	0.540	0.526	0.585	0.622	0.645	0.552	0.544	
	taud	1.835	1.746	1.545	1.621	2.004	2.089	2.126	1.940	1.828	1.724	1.914	1.888	
	Ebn at Noon	221	218	199	206	240	245	248	234	222	207	221	219	
	Edh at Noon	60	70	89	84	57	52	50	60	66	71	56	56	
All-Sky Solar Radiation	RadAvg	976	1024	1098	1230	1422	1472	1738	1630	1537	1415	1131	1007	
	RadStd	150	153	145	190	202	225	167	154	108	149	126	141	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	+86

Nomenclature: See separate page