

QINZHOU, China

WMO: 596320

Lat: 21.9498N

Lon: 108.6138E

Elev: 6

StdP: 101.25

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.4	7.7	-3.1	2.9	12.7	-0.7	3.6	12.1	7.9	9.1	7.1	10.3	3.7	0	0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	34.3	26.9	33.6	26.8	32.9	26.7	28.5	31.3	28.1	31.1	27.8	30.8	2.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.8	23.9	29.9	27.4	23.3	29.8	27.0	22.8	29.6	92.8	31.6	90.8	31.2	89.2	30.8	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	6.1	5.3	5.0	36.1	1.9	0.8	3.6	36.7	2.5	37.2	1.5	37.7	0.1	38.2		
			2.8	29.1	1.4	0.5	1.8	29.4	1.0	29.7	0.2	30.0	-0.8	30.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.3	14.4	16.0	19.0	23.8	27.2	28.7	29.1	29.0	28.1	25.6	21.4	16.6	
	DBStd	6.17	4.24	4.86	4.19	3.50	2.22	1.64	1.73	1.66	1.95	2.59	3.38	3.56	
	HDD10.0	16	9	5	0	0	0	0	0	0	0	0	0	2	
	HDD18.3	371	134	96	45	6	0	0	0	0	0	1	12	77	
	CDD10.0	4865	146	173	281	415	534	562	591	543	483	342	206		
	CDD18.3	2178	13	31	67	171	276	312	333	332	293	224	104	22	
	CDH23.3	21746	14	84	259	1203	2811	3714	4052	3937	3201	1883	532	55	
	CDH26.7	8064	0	8	33	269	982	1505	1741	1648	1228	564	83	2	
Wind	WSAvg	2.4	2.6	2.5	2.4	2.5	2.5	2.4	2.3	2.1	2.3	2.4	2.4	2.5	
Precipitation	PrecAvg	2136	46	54	63	144	223	342	423	417	207	128	58	30	
	PrecMax	2808	200	250	208	402	527	844	849	949	486	387	194	106	
	PrecMin	1205	2	2	9	15	74	93	165	144	40	9	0	0	
	PrecStd	337	46	49	41	100	117	179	200	185	116	89	60	29	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.1	27.9	29.3	31.7	33.7	34.4	35.2	35.7	34.6	32.9	30.0	26.6	
		MCWB	20.4	22.5	23.8	25.1	26.5	27.2	27.4	26.3	26.2	23.9	22.8	21.3	
	2%	DB	23.4	25.7	27.5	30.4	32.6	33.4	34.1	34.4	33.5	31.7	28.7	24.9	
		MCWB	19.1	21.4	23.2	25.1	26.4	27.2	27.2	26.8	26.0	23.8	22.1	20.2	
	5%	DB	22.0	24.1	26.0	29.4	31.7	32.6	33.2	33.4	32.6	30.7	27.6	23.5	
		MCWB	18.2	20.7	22.5	24.7	26.0	27.2	27.3	26.9	25.9	23.5	21.5	19.0	
	10%	DB	20.6	22.7	24.6	28.3	30.8	31.8	32.3	32.5	31.7	29.7	26.3	22.1	
		MCWB	17.7	19.9	21.8	24.3	25.8	27.1	27.2	26.8	25.5	23.2	21.1	18.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	23.2	24.8	26.7	28.8	29.0	29.1	28.8	28.0	26.4	25.1	23.7
			MCDB	23.8	26.8	27.5	29.0	30.8	31.4	32.1	31.6	31.0	29.6	27.3	25.3
2%		WB	20.4	22.2	23.8	26.1	27.8	28.4	28.5	28.2	27.5	25.7	24.5	22.2	
		MCDB	22.4	24.7	26.6	28.8	30.6	31.0	31.5	31.3	30.7	29.0	26.6	23.8	
5%		WB	19.4	21.4	23.1	25.5	27.2	28.0	28.1	27.7	27.1	25.2	23.8	20.7	
		MCDB	21.2	23.5	25.4	28.2	30.1	30.8	31.1	31.0	30.4	28.3	26.0	22.2	
10%		WB	18.5	20.4	22.4	25.0	26.7	27.7	27.7	27.4	26.6	24.8	23.0	19.0	
		MCDB	20.2	22.3	24.3	27.7	29.5	30.4	30.8	30.7	29.9	27.8	25.3	21.1	
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.3	5.2	5.3	5.6	5.1	5.2	5.8	6.1	6.5	6.7	6.4	
		MCDBR	7.9	7.2	6.9	6.3	6.6	6.2	6.6	7.4	7.4	7.5	8.0	8.2	
		MCWBR	4.3	3.6	3.5	2.6	2.2	1.8	1.8	2.2	2.2	2.5	3.2	4.2	
	5% WB	MCDBR	6.1	6.7	6.4	5.5	5.5	5.2	5.6	6.4	6.4	6.4	6.1	6.2	
		MCWBR	3.9	4.1	3.9	2.8	2.3	2.0	2.0	2.4	2.2	2.6	3.3	4.4	
Clear-Sky Solar Irradiance	taub	0.621	0.656	0.812	0.768	0.572	0.544	0.522	0.586	0.636	0.733	0.613	0.633		
	taud	1.694	1.660	1.422	1.537	1.992	2.086	2.140	1.941	1.792	1.569	1.761	1.693		
	Ebn at Noon	646	659	582	623	753	768	785	738	693	595	648	616		
	Edh at Noon	221	243	320	289	182	164	156	190	218	262	205	215		
All-Sky Solar Radiation	RadAvg	2.31	2.59	2.84	3.71	4.50	4.44	4.71	4.73	4.59	4.14	3.35	2.67		
	RadStd	0.55	0.47	0.42	0.44	0.41	0.60	0.55	0.27	0.28	0.28	0.47	0.46		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.60	+0.26	+0.20	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	+62

Nomenclature: See separate page