

ZHANJIANG, China

WMO: 596580

Lat: 21.1548N

Lon: 110.3034E

Elev: 50

StdP: 100.73

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.6	9.1	0.0	3.8	13.8	2.5	4.6	12.5	8.5	14.6	7.9	14.7	4.3	0	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.9	34.0	26.8	33.2	26.8	32.5	26.7	28.2	30.9	28.0	30.7	27.6	30.4	3.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.7	23.8	29.5	27.2	23.2	29.3	26.9	22.7	29.2	91.8	31.0	90.2	30.9	88.6	30.5	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.1	7.0	6.2	6.4	35.5	1.6	0.8	5.3	36.1	4.4	36.5	3.5	37.0	2.3	37.6
			4.0	28.7	1.6	0.6	2.8	29.2	1.8	29.5	0.9	29.9	-0.3	30.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.9	16.2	17.5	20.4	24.3	27.4	29.0	29.1	28.8	27.7	25.8	22.3	18.1
	DBStd	5.35	3.54	4.17	3.38	3.12	2.20	1.55	1.47	1.42	1.53	1.94	2.88	3.24
	HDD10.0	6	3	2	0	0	0	0	0	0	0	0	0	1
	HDD18.3	213	82	60	19	3	0	0	0	0	0	0	6	43
	CDD10.0	5085	196	212	322	428	541	571	593	582	532	489	368	252
	CDD18.3	2251	17	36	83	181	282	321	335	323	282	231	124	37
	CDH23.3	21524	6	53	213	1167	2898	3889	4110	3788	2972	1834	541	52
CDH26.7	7406	0	7	29	247	946	1613	1715	1451	942	399	54	1	
Wind	WSAvg	3.2	3.4	3.4	3.5	3.4	3.0	2.8	3.1	2.8	3.0	3.2	3.4	3.3
Precipitation	PrecAvg	1666	35	33	50	108	219	255	239	301	232	111	46	38
	PrecMax	2309	285	175	126	321	515	773	747	575	579	383	171	193
	PrecMin	1083	0	1	3	9	79	56	45	100	94	2	1	0
	PrecStd	365	52	38	32	77	111	142	153	111	104	113	46	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.2	27.5	29.5	32.9	34.7	34.8	35.1	34.4	33.3	31.6	29.5	26.4
		MCWB	20.0	22.4	23.9	26.1	26.5	26.9	26.8	26.7	26.4	24.6	23.4	22.1
	2%	DB	22.7	24.8	27.1	30.7	32.9	33.6	33.8	33.4	32.3	30.5	28.3	24.7
		MCWB	19.1	21.8	23.6	25.9	26.7	26.9	26.9	26.8	26.2	24.4	23.1	21.0
	5%	DB	21.6	23.3	25.5	29.3	31.6	32.7	32.9	32.5	31.4	29.7	27.1	23.5
		MCWB	18.6	20.8	22.9	25.4	26.7	26.9	26.9	26.8	25.9	24.2	22.4	20.1
	10%	DB	20.6	22.2	24.2	28.0	30.6	31.8	32.0	31.6	30.6	28.8	26.1	22.4
		MCWB	18.1	20.4	22.4	25.0	26.5	26.9	26.8	26.7	25.7	23.8	22.1	19.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	23.4	24.9	27.3	28.3	28.8	28.6	28.5	28.2	27.1	25.3	23.9
		MCDB	22.9	25.6	27.7	29.9	30.8	31.5	31.3	31.1	30.1	28.7	27.2	25.3
	2%	WB	20.2	22.4	24.1	26.5	27.7	28.3	28.1	28.0	27.6	26.1	24.8	22.8
		MCDB	21.6	24.1	26.1	29.0	30.5	31.0	31.0	30.9	29.9	28.5	26.6	23.9
	5%	WB	19.6	21.6	23.5	26.0	27.3	27.9	27.7	27.6	27.1	25.6	24.2	21.4
		MCDB	20.8	22.9	25.0	28.4	30.0	30.6	30.6	30.4	29.6	28.0	26.0	22.7
	10%	WB	18.9	20.8	22.7	25.4	26.9	27.5	27.4	27.2	26.6	25.1	23.5	20.1
		MCDB	20.1	21.9	23.9	27.5	29.5	30.2	30.3	30.0	29.2	27.5	25.4	21.6
Mean Daily Temperature Range	5% DB	MDBR	5.3	4.6	4.5	4.5	4.9	5.0	4.9	5.1	5.2	5.5	5.8	5.9
		MCDBR	5.9	6.0	6.0	6.2	6.3	6.1	6.4	6.3	6.3	6.1	6.1	6.3
		MCWBR	3.0	2.8	2.8	2.3	2.2	1.9	1.9	2.0	2.1	2.1	2.4	3.0
	5% WB	MCDBR	4.8	5.2	5.7	5.6	5.5	5.2	5.5	5.4	5.4	4.8	4.7	4.8
		MCWBR	3.0	2.8	3.2	2.5	2.4	2.2	2.1	2.2	2.3	1.9	2.3	3.1
Clear-Sky Solar Irradiance	taub	0.589	0.627	0.773	0.738	0.547	0.512	0.499	0.566	0.614	0.700	0.586	0.594	
	taud	1.771	1.722	1.490	1.593	2.071	2.190	2.216	2.003	1.850	1.626	1.832	1.781	
	Ebn at Noon	678	685	609	642	772	792	803	755	711	621	676	655	
	Edh at Noon	206	229	300	274	168	148	144	179	206	248	192	198	
All-Sky Solar Radiation	RadAvg	2.79	3.08	3.45	4.18	4.97	5.00	5.20	4.97	4.68	4.30	3.59	2.99	
	RadStd	0.55	0.50	0.41	0.50	0.41	0.62	0.53	0.34	0.32	0.27	0.40	0.43	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.24	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page