

YANGJIANG, China

WMO: 596630

Lat: 21.8457N

Lon: 111.9779E

Elev: 91

StdP: 100.24

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.2	8.5	-3.9	2.8	13.1	-1.2	3.5	13.1	9.3	11.7	8.5	11.7	4.9	40	0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	33.0	26.7	32.2	26.5	31.5	26.3	28.0	30.5	27.7	30.1	27.4	29.8	3.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.4	23.5	29.3	27.1	23.0	29.1	26.7	22.5	28.9	90.7	30.7	89.0	30.1	87.7	29.8	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.7	7.4	6.5	5.9	35.3	1.6	0.8	4.8	35.9	3.8	36.4	2.9	36.9	1.7	37.5		
			2.9	28.7	1.6	0.6	1.7	29.1	0.7	29.4	-0.2	29.8	-1.4	30.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.3	15.8	16.9	19.4	23.3	26.4	28.1	28.5	27.6	25.4	21.6	17.4		
		DBStd	5.38	3.75	4.34	3.50	2.98	2.02	1.55	1.47	1.67	2.00	2.91	3.28		
		HDD10.0	8	3	4	0	0	0	0	0	0	0	0	1		
		HDD18.3	265	94	71	31	4	0	0	0	0	0	8	57		
		CDD10.0	4848	184	197	292	398	507	542	572	527	478	349	229		
		CDD18.3	2065	17	31	65	153	249	292	314	314	277	107	27		
		CDH23.3	18767	16	33	121	842	2256	3282	3643	3585	2862	1638	434		
(14)	Wind	CDH26.7	5759	0	1	3	94	553	1133	1344	1316	911	357	47		
		WSAvg	3.4	3.6	3.4	3.4	3.3	3.2	3.3	3.3	3.1	3.2	3.4	3.4		
		PrecAvg	2276	39	61	87	220	402	382	282	381	245	86	52		
		PrecMax	3342	198	359	397	593	1189	830	846	826	525	242	310		
		PrecMin	1200	0	3	2	17	55	64	78	75	21	0	0		
		PrecStd	551	47	80	81	140	288	182	163	182	150	69	70		
		DB	25.0	25.9	26.8	29.8	31.8	33.1	34.3	34.5	33.4	31.7	29.3	26.5		
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	20.1	20.9	22.6	25.2	26.4	26.6	27.1	26.8	25.9	24.5	22.6	21.0		
		DB	23.5	24.3	25.5	28.7	30.7	31.9	32.7	33.1	32.3	30.5	28.0	24.9		
		MCWB	19.2	20.6	22.4	24.8	26.2	26.7	27.0	26.8	25.8	24.1	22.2	20.1		
		DB	22.2	23.2	24.7	27.7	30.0	31.2	31.8	32.1	31.5	29.6	26.9	23.5		
		MCWB	18.4	20.2	22.1	24.6	26.0	26.8	26.7	26.7	25.6	23.6	21.5	19.0		
		DB	20.9	22.2	23.8	26.9	29.2	30.5	31.0	31.2	30.5	28.7	25.8	22.1		
		MCWB	17.6	19.7	21.7	24.5	25.8	26.7	26.5	26.5	25.4	23.1	20.9	17.6		
		WB	21.5	22.7	24.2	26.6	28.0	28.4	28.4	28.4	27.7	26.4	24.8	23.3		
		MCDB	23.5	24.1	25.3	27.9	29.5	30.5	31.9	31.6	30.6	29.1	26.8	24.9		
		WB	20.3	21.7	23.6	26.0	27.4	27.9	27.8	27.8	27.2	25.7	24.2	21.7		
		MCDB	22.5	23.1	24.7	27.3	29.2	29.9	30.5	30.7	30.1	28.5	26.1	23.7		
		WB	19.3	21.1	23.0	25.5	26.9	27.6	27.5	27.4	26.7	25.1	23.5	20.2		
		MCDB	21.6	22.5	24.0	26.9	28.8	29.6	30.2	30.3	29.6	28.0	25.6	22.4		
		WB	18.2	20.2	22.3	25.0	26.5	27.2	27.2	27.1	26.3	24.6	22.5	18.8		
		MCDB	20.4	21.9	23.4	26.4	28.4	29.4	29.7	29.8	29.1	27.4	24.9	21.4		
(35)	Mean Daily Temperature Range	MDBR	6.2	5.3	4.9	4.2	4.3	4.1	4.4	5.0	5.2	5.7	6.3	6.4		
		5% DB	7.5	6.5	5.4	4.7	5.0	4.8	5.6	6.4	6.4	6.5	7.1	7.5		
		MCDBR	3.8	3.2	2.9	2.1	2.0	1.7	1.9	2.2	2.3	2.5	3.2	3.9		
		5% WB	6.4	4.6	4.0	3.8	4.1	4.2	4.9	5.5	5.4	5.5	5.5	6.2		
		MCWBR	3.7	3.0	3.0	2.2	2.1	2.0	2.1	2.4	2.2	2.3	3.0	3.9		
		taub	0.579	0.619	0.757	0.728	0.555	0.521	0.506	0.579	0.624	0.694	0.579	0.575		
		taud	1.779	1.733	1.507	1.603	2.033	2.152	2.183	1.954	1.816	1.620	1.835	1.809		
(42)	Clear-Sky Solar Irradiance	Ebn at Noon	682	689	617	648	766	786	798	744	701	622	678	666		
		Edh at Noon	203	225	294	271	175	154	149	188	213	249	191	192		
		RadAvg	2.91	3.00	3.19	3.67	4.51	4.68	5.17	4.86	4.57	4.26	3.57	3.12		
(44)	All-Sky Solar Radiation	RadStd	0.49	0.45	0.40	0.57	0.42	0.68	0.59	0.38	0.35	0.34	0.40	0.45		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page