

SHANGCHUAN DAO, China

WMO: 596730

Lat: 21.7358N

Lon: 112.7731E

Elev: 59

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.4	48.7	30.4	24.6	54.8	34.4	29.2	55.1	39.9	48.5	35.3	50.7	25.8	20	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.6	90.7	81.2	89.4	80.7	88.3	80.5	82.7	87.5	82.2	86.7	81.7	86.1	8.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.7	165.0	85.4	81.0	161.3	85.1	80.5	158.8	84.9	46.9	87.6	46.3	87.0	45.7	86.4	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
33.5	28.4	24.0	DB	44.5	93.9	3.1	1.4	42.3	94.9	40.5	95.7	38.8	96.5	36.6	97.5	(4)
			WB	39.3	84.0	2.9	1.1	37.2	84.8	35.5	85.4	33.9	86.1	31.8	86.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.2	60.3	62.3	67.3	74.1	80.0	83.2	83.9	83.5	82.1	78.1	71.2	63.5
	DBStd	9.67	6.05	7.24	5.75	5.01	3.67	2.63	2.32	2.53	2.82	3.30	5.05	5.35
	HDD50	10	4	5	0	0	0	0	0	0	0	0	0	1
	HDD65	438	166	122	43	5	0	0	0	0	0	0	12	90
	CDD50	8836	324	350	536	722	929	995	1051	1040	962	870	636	421
	CDD65	3789	20	48	115	276	464	545	586	575	512	405	198	45
	CDH74	35684	4	39	215	1464	4352	6397	7124	6836	5546	3044	628	35
	CDH80	11114	0	0	4	168	1114	2341	2777	2540	1698	441	31	0
Wind	WSAvg	10.6	13.1	11.9	10.2	9.2	8.7	8.6	8.5	7.9	9.9	11.5	13.1	14.2
Precipitation	PrecAvg	85.0	1.1	1.9	2.9	6.9	13.7	13.4	10.6	13.6	12.4	7.3	1.6	1.1
	PrecMax	116.2	3.5	10.4	15.0	17.6	38.2	33.1	23.8	34.5	35.6	20.4	7.9	7.1
	PrecMin	40.5	0.0	0.0	0.2	0.1	1.3	1.8	3.6	3.9	1.1	0.0	0.0	0.0
	PrecStd	19.9	1.1	2.5	3.0	5.0	9.1	7.6	5.6	7.4	7.8	5.7	1.9	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.4	77.4	80.2	85.4	89.9	91.2	92.2	92.7	91.3	87.4	83.0	77.3
		MCWB	67.9	71.7	74.4	78.1	80.4	80.9	82.5	81.6	80.9	77.7	75.0	70.6
	2%	DB	72.0	75.2	78.2	83.7	87.7	89.1	90.1	90.7	89.2	85.4	80.7	74.7
		MCWB	66.2	70.8	73.7	77.8	80.1	80.7	81.3	81.3	79.9	77.0	73.5	69.3
	5%	DB	69.9	73.3	76.5	82.1	86.2	88.1	88.9	89.2	87.7	83.8	79.0	72.6
		MCWB	64.8	69.5	72.9	77.1	79.7	80.7	80.9	80.9	79.4	75.8	72.7	67.6
	10%	DB	68.0	71.1	74.6	80.6	84.9	87.0	87.7	87.8	86.3	82.5	77.6	70.6
		MCWB	63.6	67.3	71.4	76.6	79.4	80.6	80.6	80.6	78.9	74.9	71.8	65.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.0	73.7	76.0	80.0	82.4	83.3	83.7	83.5	82.7	80.1	77.0	73.7
		MCDB	72.7	75.6	78.6	82.7	85.6	87.2	89.8	89.3	88.1	84.0	80.3	75.4
	2%	WB	67.7	72.2	74.7	78.9	81.7	82.6	82.7	82.6	81.7	78.9	75.7	71.3
		MCDB	70.5	74.4	77.2	82.1	85.1	86.3	87.7	87.8	86.5	83.1	78.9	73.2
	5%	WB	66.0	70.0	73.6	78.0	81.1	81.9	81.9	81.9	80.9	77.9	74.7	68.8
		MCDB	69.1	72.7	75.9	81.2	84.7	85.8	86.6	86.8	85.4	82.1	78.0	71.8
	10%	WB	64.4	68.0	72.1	77.1	80.2	81.4	81.5	81.3	80.2	76.9	73.4	66.2
		MCDB	67.3	70.4	74.1	80.1	84.0	85.4	86.1	86.0	84.5	81.1	77.0	70.1
Mean Daily Temperature Range	5% DB	MDBR	7.7	7.2	7.1	6.6	6.6	6.3	6.6	7.3	7.2	6.9	7.6	7.8
		MCDBR	9.6	9.3	8.5	8.1	7.9	7.5	8.3	9.5	9.0	8.2	8.5	8.8
		MCWBR	5.0	5.0	4.6	3.6	3.0	2.7	3.1	3.8	3.8	3.8	4.1	4.9
	5% WB	MCDBR	8.8	8.1	7.9	7.5	6.8	6.3	7.2	8.4	8.1	7.1	6.9	7.7
MCWBR		5.6	5.4	5.1	4.0	3.1	3.0	3.2	4.0	3.9	3.5	4.1	5.5	
Clear-Sky Solar Irradiance	taub	0.592	0.631	0.761	0.730	0.555	0.522	0.508	0.579	0.625	0.696	0.593	0.590	
	taud	1.784	1.732	1.523	1.620	2.057	2.173	2.205	1.976	1.838	1.643	1.834	1.805	
	Ebn at Noon	213	216	195	205	243	249	253	236	223	197	212	208	
	Edh at Noon	64	72	92	84	54	48	46	58	66	77	61	61	
All-Sky Solar Radiation	RadAvg	941	974	1055	1225	1479	1524	1707	1575	1477	1363	1125	987	
	RadStd	156	152	138	189	151	221	190	126	130	115	125	136	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	+0.47	N/A	N/A	N/A	N/A
	Regional (11 neighbors)	N/A	N/A	N/A	+0.36	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page