

HAIKOU, China

WMO: 597580

Lat: 19.9938N

Lon: 110.2469E

Elev: 210

StdP: 14.58

Time Zone: 8.00 (E08)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	51.3	54.2	42.6	40.5	56.8	45.6	45.5	57.6	18.6	63.7	16.8	64.0	6.0	20	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.8	95.2	80.3	93.6	80.1	92.2	79.8	82.3	90.4	81.7	89.4	81.0	88.4	6.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	158.8	85.9	79.8	155.6	85.4	79.2	152.5	84.8	46.4	90.9	45.7	89.8	45.1	88.8	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.8	15.4	13.5	DB	48.9	98.5	2.7	2.0	46.9	99.9	45.3	101.1	43.8	102.2	41.8	103.7
			WB	46.1	83.3	2.7	1.0	44.2	84.1	42.6	84.6	41.1	85.2	39.2	85.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.0	65.1	67.3	72.8	79.2	82.9	85.0	84.7	83.8	82.0	79.1	74.3	67.6
	DBStd	8.37	5.93	7.38	6.76	5.56	3.76	2.63	2.49	2.27	2.37	2.71	4.34	5.05
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	183	74	57	17	1	0	0	0	0	0	0	3	31
	CDD50	9868	468	486	705	877	1020	1049	1077	1049	959	903	728	547
	CDD65	4575	77	122	257	428	555	599	612	584	509	438	281	113
	CDH74	44300	143	444	1497	3781	6050	7274	7461	6845	5469	3771	1348	217
	CDH80	15914	18	94	417	1320	2336	3186	3221	2690	1690	745	177	20
Wind	WSAvg	6.0	6.3	6.4	6.6	6.5	5.6	5.4	5.6	5.2	5.5	6.4	6.5	6.6
Precipitation	PrecAvg	77.6	1.1	1.6	2.1	3.7	8.1	8.0	8.5	11.1	13.0	13.8	4.0	2.6
	PrecMax	106.4	5.8	7.0	9.3	12.5	17.2	17.5	17.0	21.1	31.5	56.3	8.5	7.7
	PrecMin	47.4	0.0	0.2	0.2	0.6	4.0	3.3	4.0	2.7	4.0	0.7	0.2	0.2
	PrecStd	14.4	1.1	1.5	1.8	2.6	2.9	3.4	3.2	4.0	6.5	11.5	2.4	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.5	88.4	92.7	95.9	96.9	96.6	96.5	94.2	91.9	88.4	87.0	82.7
		MCWB	72.3	73.8	76.8	78.9	80.3	81.4	80.4	80.5	78.6	77.8	76.7	74.9
	2%	DB	77.5	82.4	88.0	92.9	94.3	94.6	94.4	92.2	89.9	86.5	84.1	78.6
		MCWB	70.4	72.5	75.6	78.5	80.3	80.9	80.3	80.0	78.9	76.9	75.9	72.4
	5%	DB	74.7	79.1	84.5	90.1	92.1	93.0	92.7	90.7	88.5	85.2	82.0	76.2
		MCWB	69.3	71.4	74.8	78.1	80.0	80.6	80.2	79.8	78.7	76.4	74.7	71.1
	10%	DB	72.3	76.1	81.4	87.3	89.8	91.3	91.0	89.3	87.1	83.9	80.0	74.1
		MCWB	68.3	70.6	73.7	77.4	79.7	80.1	79.9	79.7	78.5	75.9	73.9	69.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.2	74.9	78.2	81.5	82.7	83.5	82.9	82.2	81.4	79.9	78.0	76.0
		MCDB	79.0	83.7	88.8	91.2	91.5	92.5	91.3	89.3	87.1	85.0	83.4	80.2
	2%	WB	71.3	73.3	76.4	79.9	81.7	82.4	81.9	81.5	80.6	78.9	77.0	74.0
		MCDB	75.4	80.2	85.5	88.7	90.0	90.6	89.8	88.4	86.4	83.6	81.5	77.1
	5%	WB	70.1	72.1	75.3	78.9	80.9	81.6	81.2	80.9	80.0	78.2	76.1	72.4
		MCDB	73.7	77.4	82.9	87.0	88.6	89.3	88.9	87.7	85.4	82.6	80.5	75.4
	10%	WB	68.9	71.0	74.2	78.0	80.1	80.9	80.7	80.4	79.4	77.5	75.2	70.6
		MCDB	72.0	75.5	80.3	85.1	87.2	88.2	88.1	87.0	84.6	81.7	79.4	73.5
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.6	10.0	10.8	11.1	11.8	11.3	10.2	8.7	7.8	7.4	7.1
		MCDBR	11.5	13.1	15.2	16.0	15.2	14.4	14.1	12.4	11.3	9.7	10.1	10.0
	5% WB	MCWBR	5.0	4.5	5.2	4.8	4.7	4.5	4.5	4.2	3.7	3.3	3.5	4.8
		MCWBR	10.4	12.3	13.9	14.1	13.2	13.2	12.1	10.8	9.4	8.3	8.8	9.0
Clear-Sky Solar Irradiance	taub		0.568	0.587	0.705	0.670	0.512	0.483	0.465	0.515	0.568	0.640	0.573	0.587
		taud	1.832	1.830	1.622	1.743	2.195	2.298	2.337	2.172	1.987	1.762	1.883	1.811
	Ebn at Noon		223	229	208	219	254	259	264	252	238	213	220	212
		Edh at Noon	62	66	83	75	47	42	41	48	57	69	59	62
All-Sky Solar Radiation	RadAvg		876	1065	1240	1488	1706	1710	1718	1599	1444	1272	1054	864
	RadStd		176	195	138	167	145	163	155	121	129	109	119	130

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	-1.49	-2.16	N/A	-0.67	-0.72	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	-1.64	+0.47	N/A	N/A	N/A	N/A	N/A	+115

Nomenclature: See separate page