

DONGFANG, China

WMO: 598380

Lat: 19.0941N

Lon: 108.6216E

Elev: 8

StdP: 101.23

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 12.2	(c) 13.4	(d) 6.3	(e) 5.9	(f) 14.9	(g) 8.2	(h) 6.8	(i) 15.4	(j) 11.2	(k) 14.9	(l) 10.3	(m) 15.2	(n) 6.6	(o) 40	(p) 0.405

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 3.9	(c) 33.3	(d) 27.3	(e) 32.8	(f) 27.1	(g) 32.4	(h) 26.9	(i) 28.2	(j) 32.0	(k) 27.9	(l) 31.7	(m) 27.6	(n) 31.4	(o) 6.4	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	22.9	31.0	26.7	22.4	30.7	26.5	22.0	30.5	91.1	32.3	89.4	31.9	88.0	31.5	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.8	9.8	8.9	DB	10.8	34.4	1.4	1.0	9.8	35.1	8.9	35.7	8.1	36.3	7.1	37.1	
			WB	8.1	28.4	1.7	0.6	6.9	28.8	5.9	29.2	4.9	29.5	3.7	30.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.8	19.8	20.7	23.3	27.0	29.1	30.1	29.6	29.1	28.2	26.9	24.4	21.2	
	DBStd	4.20	2.91	3.47	2.99	2.36	1.69	1.28	1.31	1.16	1.24	1.45	2.27	2.74	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	52	21	18	4	0	0	0	0	0	0	0	1	9	
	CDD10.0	5770	304	300	413	509	593	602	607	593	546	524	433	346	
	CDD18.3	2781	67	84	158	260	334	352	349	334	296	266	184	97	
	CDH23.3	29431	172	333	973	2704	4295	4796	4588	4214	3335	2484	1201	337	
CDH26.7	11566	5	28	172	929	1963	2421	2151	1792	1161	691	228	24		
Wind	WSAvg	4.2	4.2	3.9	3.8	4.0	4.4	5.2	4.9	4.0	3.6	3.8	4.4	4.6	
Precipitation	PrecAvg	935	7	12	18	29	66	145	108	200	161	132	25	5	
	PrecMax	1529	40	93	70	85	252	539	452	518	434	400	122	20	
	PrecMin	275	0	0	0	0	0	0	3	12	11	4	0	0	
	PrecStd	317	9	19	19	25	51	118	127	138	107	89	25	5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	28.8	30.6	32.9	33.9	33.6	33.4	32.6	32.1	30.6	28.5		
		MCWB	22.1	23.4	25.0	26.5	27.4	27.9	27.5	27.6	26.8	24.8	24.4	23.3	
	2%	DB	26.0	27.6	29.6	32.1	33.1	33.2	32.9	32.5	31.9	31.2	29.6	27.3	
		MCWB	21.6	22.9	24.4	26.2	27.1	27.5	27.2	27.3	26.7	25.0	24.3	22.5	
	5%	DB	25.2	26.5	28.5	31.3	32.6	32.7	32.4	31.9	31.4	30.5	28.9	26.3	
		MCWB	21.1	22.3	23.8	25.8	26.9	27.2	26.9	27.0	26.5	25.0	23.9	21.9	
	10%	DB	24.2	25.5	27.5	30.6	32.0	32.2	31.8	31.4	30.8	29.9	28.1	25.3	
		MCWB	20.6	21.7	23.2	25.4	26.6	26.9	26.7	26.8	26.3	24.8	23.5	21.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	24.2	25.6	27.5	28.6	28.7	28.4	28.5	28.1	27.0	26.0	24.6
			MCDB	26.1	27.9	29.7	31.7	32.4	32.7	32.2	32.0	31.4	30.5	29.0	27.3
2%		WB	22.2	23.2	24.8	26.8	27.9	28.2	27.9	28.0	27.5	26.4	25.3	23.7	
		MCDB	25.0	26.8	28.7	31.0	32.2	32.2	31.7	31.4	30.8	29.7	28.3	26.3	
5%		WB	21.7	22.7	24.2	26.2	27.4	27.8	27.5	27.6	27.1	25.9	24.8	22.9	
		MCDB	24.4	25.9	27.8	30.3	31.8	31.8	31.3	31.0	30.4	29.2	27.7	25.4	
10%		WB	21.1	22.0	23.6	25.8	27.0	27.4	27.2	27.2	26.7	25.5	24.3	22.1	
		MCDB	23.7	24.9	27.0	29.8	31.3	31.5	30.9	30.6	29.9	28.6	27.1	24.6	
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.3	5.2	5.0	4.7	3.9	3.9	4.2	4.8	5.5	5.8	5.8	
		MCDBR	6.7	6.1	5.7	5.3	4.8	4.1	4.4	4.8	5.4	6.4	6.5	6.7	
		MCWBR	3.5	3.3	3.3	3.3	2.9	2.6	2.6	2.3	2.4	2.6	2.9	3.3	
	5% WB	MCDBR	6.0	5.6	5.6	5.0	4.6	4.0	4.1	4.3	4.9	5.5	5.4	5.8	
MCWBR		3.4	3.3	3.4	3.1	3.0	2.7	2.5	2.3	2.5	2.5	2.7	3.2		
Clear-Sky Solar Irradiance	taub		0.556	0.586	0.702	0.656	0.510	0.482	0.462	0.499	0.557	0.615	0.551	0.572	
	taud		1.872	1.834	1.630	1.771	2.207	2.300	2.349	2.224	2.017	1.822	1.955	1.851	
	Ebn at Noon		719	727	661	700	802	816	834	809	760	693	719	688	
	Edh at Noon		189	207	262	230	147	132	126	144	176	207	173	188	
All-Sky Solar Radiation	RadAvg		3.27	3.86	4.29	5.23	5.84	5.68	5.54	5.23	4.87	4.52	3.85	3.14	
	RadStd		0.52	0.63	0.45	0.47	0.45	0.43	0.56	0.35	0.48	0.47	0.33	0.36	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+75	+75
Regional (7 neighbors)	N/A	N/A	N/A	+0.28	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page