

DANXIAN, China

WMO: 598450

Lat: 19.5108N

Lon: 109.5773E

Elev: 169

StdP: 99.31

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	11.0	6.1	5.9	13.7	7.8	6.7	13.1	5.4	22.5	4.9	21.9	1.6	40	0.283

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.3	35.6	25.8	34.7	25.8	33.8	25.7	27.2	32.3	26.8	31.9	26.6	31.4	2.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.9	28.7	25.7	21.4	28.5	25.4	21.0	28.3	87.1	32.4	85.6	32.1	84.4	31.7	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.3	4.4	4.0	8.3	37.5	1.5	1.0	7.3	38.2	6.4	38.8	5.6	39.4	4.5	40.2
			7.2	27.8	1.5	0.6	6.2	28.2	5.3	28.5	4.5	28.9	3.4	29.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.9	18.5	20.2	23.5	26.7	28.3	29.2	28.9	28.3	27.2	25.5	22.8	19.4
	DBStd	4.68	3.84	4.65	3.94	3.25	2.25	1.65	1.54	1.38	1.54	1.79	2.80	3.25
	HDD10.0	1	1	1	0	0	0	0	0	0	0	0	0	0
	HDD18.3	122	48	33	9	1	0	0	0	0	0	0	3	27
	CDD10.0	5441	264	287	418	501	568	577	586	567	516	481	384	293
	CDD18.3	2519	53	87	169	251	310	327	327	308	266	223	138	61
	CDH23.3	22604	191	499	1197	2297	3159	3749	3617	3145	2355	1533	659	203
	CDH26.7	8462	23	147	435	970	1335	1641	1496	1156	718	380	134	28
Wind	WSAvg	2.0	2.0	1.9	2.0	1.9	1.8	1.9	2.0	1.9	1.9	2.1	2.1	2.0
Precipitation	PrecAvg	1803	18	22	32	83	233	206	255	296	317	231	81	29
	PrecMax	2536	79	68	151	318	447	391	507	534	791	716	322	100
	PrecMin	1103	1	3	0	7	66	86	65	61	80	11	1	1
	PrecStd	355	18	18	32	64	96	77	118	127	156	169	75	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.6	33.5	35.2	37.1	37.1	36.1	36.1	34.8	33.7	31.8	31.3	29.1
		MCWB	21.1	22.4	23.5	25.1	25.8	26.4	26.0	26.5	26.1	24.6	23.8	22.8
	2%	DB	27.1	30.5	32.9	35.0	35.3	35.0	34.7	33.6	32.4	30.8	29.7	27.4
		MCWB	20.5	22.2	23.8	25.0	26.0	26.3	26.0	26.2	25.9	24.3	23.6	21.8
	5%	DB	25.6	28.2	30.9	33.4	34.0	34.1	33.7	32.7	31.5	29.9	28.3	25.7
		MCWB	20.0	21.5	23.2	24.9	25.9	26.1	25.9	26.1	25.6	23.9	23.0	21.0
	10%	DB	24.1	26.4	29.0	31.8	32.6	33.1	32.6	31.8	30.5	28.9	26.9	24.0
		MCWB	19.5	20.7	22.7	24.6	25.6	26.0	25.9	26.0	25.3	23.5	22.3	20.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.5	23.7	25.2	26.8	27.5	27.6	27.3	27.5	27.1	26.1	25.1	23.7
		MCDB	26.3	30.6	32.1	33.2	33.2	33.2	32.5	32.0	31.2	29.7	28.5	27.1
	2%	WB	21.5	22.7	24.4	26.1	26.9	27.1	26.9	27.0	26.6	25.5	24.4	22.8
		MCDB	25.2	28.7	30.7	32.3	32.6	32.6	31.9	31.4	30.5	28.7	27.5	25.7
	5%	WB	20.9	22.0	23.7	25.5	26.4	26.7	26.5	26.6	26.2	25.0	23.8	22.0
		MCDB	24.2	26.9	29.3	31.4	31.9	32.0	31.4	30.8	29.8	27.8	26.6	24.4
	10%	WB	20.2	21.2	23.0	24.9	26.0	26.3	26.2	26.2	25.8	24.5	23.3	21.1
		MCDB	23.1	25.4	28.0	30.4	31.2	31.3	30.8	30.3	29.0	27.1	25.9	23.2
Mean Daily Temperature Range	5% DB	MDBR	6.5	7.3	8.2	8.1	7.7	7.3	7.1	6.8	6.1	6.0	5.9	5.8
		MCDBR	9.1	10.5	11.1	10.2	9.3	8.5	8.6	8.1	7.9	7.4	7.8	8.0
		MCWBR	3.3	3.8	4.0	3.5	2.9	2.7	2.7	2.6	2.5	2.3	2.5	3.0
	5% WB	MCDBR	7.9	9.7	10.2	9.2	8.3	7.6	7.8	7.3	6.9	6.0	6.5	6.9
		MCWBR	3.3	3.8	4.0	3.5	3.0	2.8	2.8	2.7	2.5	2.3	2.5	3.2
Clear-Sky Solar Irradiance	taub	0.549	0.565	0.683	0.647	0.499	0.470	0.452	0.497	0.552	0.610	0.551	0.569	
	taud	1.853	1.860	1.637	1.765	2.202	2.301	2.339	2.194	2.000	1.802	1.913	1.825	
	Ebn at Noon	723	742	673	706	810	827	842	811	762	696	716	687	
	Edh at Noon	192	201	260	231	148	132	128	148	178	210	180	193	
All-Sky Solar Radiation	RadAvg	2.92	3.56	4.04	4.75	5.27	5.25	5.22	4.86	4.42	3.94	3.27	2.71	
	RadStd	0.55	0.65	0.42	0.49	0.48	0.42	0.47	0.41	0.46	0.48	0.39	0.42	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.30	N/A	N/A	+0.44	N/A	+0.20	N/A	N/A	N/A	+138
(47)	Regional (8 neighbors)	N/A	N/A	-1.00	+0.22	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page