

XISHA DAO, China

WMO: 599810

Lat: 16.8327N

Lon: 112.3325E

Elev: 16

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.3	70.5	57.8	71.3	71.4	60.0	77.4	72.4	19.1	71.8	18.1	72.6	11.3	40	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	5.3	90.5	82.1	89.8	81.8	89.1	81.5	83.8	88.4	83.3	88.0	82.8	87.5	7.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.6	170.0	87.6	81.9	166.3	87.1	81.5	163.7	86.8	48.1	88.8	47.4	88.1	46.8	87.5	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.8	18.8	16.7	DB	67.2	91.8	1.6	1.0	66.0	92.5	65.1	93.0	64.2	93.6	63.1	94.3	(4)
			WB	60.8	84.2	2.1	1.2	59.3	85.1	58.1	85.7	56.9	86.4	55.3	87.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	75.6	76.6	79.6	83.0	85.2	85.8	85.1	84.9	83.9	82.3	80.4	77.1	(6)
		DBStd	4.07	2.33	2.41	2.50	2.04	1.93	1.78	1.71	1.82	1.85	1.69	2.11	2.64	(7)
		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
		CDD50	11550	795	743	918	991	1091	1073	1088	1081	1016	1001	912	841	(10)
		CDD65	6075	330	323	453	541	626	623	623	616	566	536	462	376	(11)
		CDH74	64910	1339	1650	3848	6233	8127	8270	8060	7897	6952	5918	4351	2265	(12)
		CDH80	23060	49	137	740	2145	3703	3962	3621	3460	2694	1661	738	150	(13)
(14)	Wind	WSAvg	8.8	8.9	8.0	7.5	7.2	7.6	10.0	10.0	9.8	7.6	8.4	9.9	10.5	(14)
(15)	Precipitation	PrecAvg	58.9	0.7	0.5	0.4	1.5	2.6	8.7	6.3	9.4	10.0	10.4	5.8	1.3	(15)
(16)		PrecMax	95.5	4.3	2.1	2.4	5.7	9.6	23.7	30.8	31.5	30.8	24.3	18.0	5.3	(16)
(17)		PrecMin	28.7	0.1	0.0	0.0	0.0	0.1	0.2	1.1	0.2	1.0	0.4	0.2	0.1	(17)
(18)		PrecStd	17.2	0.7	0.6	0.6	1.6	2.6	6.4	6.7	5.9	6.9	6.8	5.0	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.7	84.5	87.1	89.3	90.9	91.5	90.8	90.8	89.9	88.6	87.5	84.4	(19)
(20)			MCWB	75.5	75.6	78.3	80.3	82.0	82.8	82.2	82.3	81.0	79.8	79.5	76.8	(20)
(21)		2%	DB	81.4	82.9	86.0	88.4	90.0	90.5	89.7	89.8	89.0	87.5	86.0	82.8	(21)
(22)			MCWB	74.3	75.2	77.7	80.0	81.8	82.5	81.7	81.9	80.6	79.4	78.8	75.9	(22)
(23)		5%	DB	80.2	81.7	84.9	87.6	89.4	89.6	88.9	88.9	88.2	86.6	84.8	81.7	(23)
(24)			MCWB	73.5	74.7	77.2	79.7	81.6	82.2	81.5	81.6	80.3	79.0	78.1	75.0	(24)
(25)		10%	DB	79.1	80.6	83.8	86.8	88.6	88.8	88.1	88.0	87.4	85.7	83.6	80.6	(25)
(26)			MCWB	72.7	73.9	76.6	79.2	81.3	81.9	81.3	81.3	80.1	78.5	77.5	74.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.5	77.9	79.9	81.9	84.3	84.6	84.2	84.1	83.2	81.7	80.6	78.2	(27)
(28)			MCDB	81.0	82.0	84.8	87.1	88.6	89.4	88.9	88.9	87.4	86.2	85.7	82.3	(28)
(29)		2%	WB	75.8	76.5	78.9	81.3	83.5	83.9	83.3	83.3	82.3	80.9	79.6	77.2	(29)
(30)			MCDB	79.6	80.7	83.9	86.5	88.0	88.6	87.9	88.0	86.9	85.6	84.4	81.1	(30)
(31)		5%	WB	74.7	75.6	78.2	80.6	82.8	83.3	82.7	82.7	81.6	80.2	78.9	76.4	(31)
(32)			MCDB	78.8	80.1	83.2	85.9	87.5	88.1	87.3	87.3	86.4	84.9	83.5	80.2	(32)
(33)		10%	WB	73.7	74.6	77.4	80.0	82.2	82.7	82.1	82.1	80.9	79.6	78.2	75.6	(33)
(34)			MCDB	78.0	79.3	82.4	85.3	87.2	87.5	86.7	86.7	85.9	84.1	82.6	79.5	(34)
(35)	Mean Daily Temperature Range	MDBR	5.7	6.5	7.0	6.8	6.2	5.3	5.5	5.5	6.1	6.2	5.1	4.8		(35)
(36)		5% DB	MCDBR	6.7	7.5	7.5	7.1	6.6	6.0	6.2	6.3	7.0	7.1	6.4	5.8	(36)
(37)			MCWBR	3.3	3.4	3.1	3.0	2.8	2.8	2.9	3.1	3.3	3.2	2.9		(37)
(38)		5% WB	MCDBR	6.2	7.1	7.0	6.6	5.7	5.2	5.4	5.5	6.2	6.5	6.0	5.1	(38)
(39)			MCWBR	3.2	3.3	3.1	3.1	2.9	3.0	3.0	3.0	3.3	3.4	3.2	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.483	0.479	0.542	0.507	0.450	0.447	0.442	0.456	0.486	0.535	0.542	0.554		(40)
(41)		taud	2.143	2.174	2.028	2.186	2.418	2.437	2.449	2.390	2.279	2.078	2.021	1.946		(41)
(42)		Ebn at Noon	254	263	250	259	270	268	270	268	261	244	235	228		(42)
(43)		Edh at Noon	47	47	56	48	38	36	36	39	43	51	52	56		(43)
(44)	All-Sky Solar Radiation	RadAvg	1337	1634	1861	2058	2001	1909	1818	1756	1655	1536	1316	1156		(44)
(45)		RadStd	132	156	140	119	140	175	137	133	122	141	161	176		(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.58	N/A	N/A	+0.81	N/A	N/A	N/A	N/A	+202	+202
Regional (1 neighbor)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+202	+202

Nomenclature: See separate page