

XISHA DAO, China

WMO: 599810

Lat: 16.8327N

Lon: 112.3325E

Elev: 5

StdP: 101.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.7	21.4	14.3	10.2	21.9	15.6	11.1	22.4	8.5	22.1	8.1	22.6	5.1	40	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	3.0	32.5	27.8	32.1	27.7	31.7	27.5	28.8	31.3	28.5	31.1	28.2	30.8	3.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.1	24.3	30.9	27.7	23.8	30.6	27.5	23.4	30.4	94.0	31.6	92.4	31.2	91.1	30.9	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.4	7.5	DB	19.6	33.2	0.9	0.5	18.9	33.6	18.4	33.9	17.9	34.2	17.3	34.6	
			WB	16.0	29.0	1.2	0.6	15.2	29.5	14.5	29.8	13.8	30.2	13.0	30.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	24.2	24.8	26.4	28.3	29.6	29.9	29.5	29.4	28.8	27.9	26.9	25.1
	DBStd	2.26	1.29	1.34	1.39	1.13	1.07	0.99	0.95	1.01	1.03	0.94	1.17	1.46
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6417	442	413	510	551	606	596	604	601	564	556	507	467
	CDD18.3	3375	183	179	252	301	348	346	346	342	314	298	257	209
	CDH23.3	36061	744	917	2138	3463	4515	4594	4478	4387	3862	3288	2417	1258
Wind	WSAvg	3.9	4.0	3.6	3.4	3.2	3.4	4.5	4.5	4.4	3.4	3.8	4.4	4.7
	PrecAvg	1496	19	12	11	38	67	222	160	238	255	265	148	32
	PrecMax	2425	108	53	62	144	243	602	783	800	782	616	458	135
	PrecMin	730	2	0	0	0	2	5	27	5	26	11	4	2
	PrecStd	437	19	14	15	40	67	163	170	151	176	173	126	28
	DB	28.2	29.2	30.6	31.9	32.7	33.1	32.6	32.7	32.2	31.4	30.8	29.1	
	MCWB	24.2	24.2	25.7	26.8	27.8	28.2	27.9	27.9	27.2	26.6	26.4	24.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	27.4	28.3	30.0	31.3	32.2	32.5	32.0	32.1	31.7	30.9	30.0	28.2	
	2% MCWB	23.5	24.0	25.4	26.6	27.7	28.1	27.6	27.7	27.0	26.4	26.0	24.4	
	5% DB	26.8	27.6	29.4	30.9	31.9	32.0	31.6	31.6	31.2	30.3	29.4	27.6	
	5% MCWB	23.0	23.7	25.1	26.5	27.6	27.9	27.5	27.5	26.8	26.1	25.6	23.9	
	10% DB	26.2	27.0	28.8	30.4	31.5	31.5	31.2	31.1	30.8	29.8	28.7	27.0	
	10% MCWB	22.6	23.3	24.8	26.2	27.4	27.7	27.4	27.4	26.7	25.8	25.3	23.5	
	WB	25.3	25.5	26.6	27.7	29.1	29.2	29.0	29.0	28.5	27.6	27.0	25.7	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	27.2	27.8	29.3	30.6	31.5	31.9	31.6	31.6	30.8	30.1	29.8	27.9	
	2% WB	24.3	24.7	26.1	27.4	28.6	28.8	28.5	28.5	28.0	27.1	26.4	25.1	
	2% MCDB	26.5	27.0	28.8	30.3	31.1	31.4	31.1	31.1	30.5	29.8	29.1	27.3	
	5% WB	23.7	24.2	25.6	27.0	28.2	28.5	28.1	28.1	27.6	26.8	26.0	24.7	
	5% MCDB	26.0	26.7	28.4	30.0	30.9	31.1	30.7	30.7	30.2	29.4	28.6	26.8	
	10% WB	23.2	23.7	25.2	26.7	27.9	28.2	27.8	27.8	27.2	26.5	25.7	24.2	
	10% MCDB	25.5	26.3	28.0	29.6	30.6	30.8	30.4	30.4	29.9	29.0	28.1	26.4	
Mean Daily Temperature Range	MDBR	3.2	3.6	3.9	3.8	3.4	3.0	3.1	3.1	3.4	3.4	2.8	2.6	
	5% DB MCDBR	3.7	4.2	4.2	3.9	3.6	3.4	3.4	3.5	3.9	4.0	3.6	3.2	
	5% DB MCWBR	1.8	1.9	1.7	1.7	1.6	1.6	1.5	1.6	1.7	1.9	1.8	1.6	
	5% WB MCDBR	3.4	3.9	3.9	3.6	3.2	2.9	3.0	3.0	3.4	3.6	3.3	2.9	
	5% WB MCWBR	1.8	1.9	1.7	1.7	1.6	1.6	1.6	1.7	1.8	1.9	1.8	1.5	
Clear-Sky Solar Irradiance	taub	0.483	0.479	0.542	0.507	0.450	0.447	0.442	0.456	0.486	0.535	0.542	0.554	
	taud	2.143	2.174	2.028	2.186	2.418	2.437	2.449	2.390	2.279	2.078	2.021	1.946	
	Ebn at Noon	801	828	787	815	851	845	850	846	823	768	740	718	
	Edh at Noon	147	149	177	152	119	115	114	122	136	162	165	175	
All-Sky Solar Radiation	RadAvg	4.22	5.15	5.87	6.49	6.31	6.02	5.73	5.54	5.22	4.84	4.15	3.64	
	RadStd	0.41	0.49	0.44	0.38	0.44	0.55	0.43	0.42	0.38	0.44	0.51	0.56	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.32	N/A	N/A	+0.45	N/A	N/A	N/A	+112	+112
(47) Regional (1 neighbor)		+0.27	N/A	N/A	N/A	N/A	N/A	N/A	+112	+112

Nomenclature: See separate page