

SANHU DAO, China

WMO: 599850

Lat: 16.5343N

Lon: 111.6056E

Elev: 5

StdP: 101.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	21.4	15.2	10.8	22.0	16.4	11.6	22.4	10.4	21.9	10.0	22.1	6.3	40	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	4.5	34.1	28.9	33.5	28.6	33.0	28.5	29.6	32.9	29.2	32.6	28.9	32.3	3.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.7	25.1	32.2	28.3	24.6	31.8	28.0	24.2	31.4	97.9	33.2	96.2	32.7	94.6	32.4	32.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	8.5	7.6	19.4	35.3	1.0	0.7	18.7	35.8	18.1	36.2	17.5	36.6	16.7	37.1		
(5)			16.5	30.4	1.1	0.8	15.7	31.0	15.1	31.4	14.5	31.9	13.7	32.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	24.4	25.1	26.9	28.8	30.0	30.4	29.9	29.5	28.8	27.9	26.9	25.2	(6)	(7)
	DBStd	2.36	1.33	1.53	1.47	1.19	1.25	1.20	1.19	1.08	1.14	0.96	1.22	1.45	(7)	(8)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	(9)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	(10)
	CDD10.0	6505	447	423	523	564	619	611	616	606	564	556	506	471	(10)	(11)
	CDD18.3	3463	189	189	265	314	361	361	358	347	314	297	256	212	(11)	(12)
	CDH23.3	36497	794	1054	2295	3613	4667	4794	4593	4341	3655	3131	2311	1248	(12)	(13)
	CDH26.7	13556	58	169	586	1365	2220	2408	2141	1897	1349	856	397	107	(13)	(14)
(14) Wind	WSAvg	3.7	4.9	3.9	3.5	3.0	2.9	3.2	3.0	3.0	2.7	3.8	5.1	5.6	(14)	(15)
(15) Precipitation	PrecAvg	1339	20	13	18	55	88	81	164	199	224	241	156	81	(15)	(16)
	PrecMax	1995	105	31	42	309	206	269	369	574	646	609	452	361	(16)	(17)
	PrecMin	577	0	3	7	0	0	0	31	7	49	14	28	0	(17)	(18)
	PrecStd	352	22	9	12	77	69	79	95	159	150	129	109	91	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.2	30.4	32.2	33.5	34.7	35.0	34.4	33.7	33.2	32.1	31.2	29.7	(19)	(20)
		MCWB	24.9	25.7	26.8	27.7	28.9	29.2	29.3	29.0	28.4	27.5	27.1	25.3	(20)	(21)
	2%	DB	28.1	29.6	31.3	32.8	33.9	34.1	33.5	33.1	32.5	31.3	30.3	28.6	(21)	(22)
		MCWB	24.2	25.1	26.5	27.5	28.6	29.0	28.9	28.8	28.2	27.1	26.6	24.8	(22)	(23)
	5%	DB	27.2	28.6	30.6	32.2	33.2	33.5	33.0	32.5	31.9	30.7	29.6	27.9	(23)	(24)
		MCWB	23.5	24.5	26.0	27.3	28.4	28.8	28.6	28.6	28.0	26.8	26.1	24.3	(24)	(25)
	10%	DB	26.5	27.7	29.7	31.5	32.6	32.8	32.4	31.9	31.4	30.0	28.8	27.1	(25)	(26)
		MCWB	23.0	23.9	25.4	27.0	28.1	28.6	28.4	28.3	27.8	26.4	25.6	23.9	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.6	26.4	27.4	28.7	29.7	30.0	30.0	30.0	29.4	28.4	27.9	26.2	(27)	(28)
		MCDB	28.2	29.7	31.2	32.3	33.4	33.5	33.3	32.9	32.1	31.2	30.3	28.8	(28)	(29)
	2%	WB	24.8	25.6	26.8	28.1	29.2	29.6	29.4	29.2	28.8	27.8	27.0	25.4	(29)	(30)
		MCDB	27.1	28.6	30.5	31.8	32.9	33.1	32.8	32.2	31.7	30.5	29.7	27.6	(30)	(31)
	5%	WB	24.2	25.0	26.3	27.6	28.8	29.2	29.0	28.9	28.4	27.3	26.5	24.9	(31)	(32)
		MCDB	26.5	27.6	29.7	31.3	32.3	32.7	32.4	31.9	31.2	29.8	28.9	26.9	(32)	(33)
	10%	WB	23.6	24.4	25.8	27.2	28.5	28.8	28.6	28.5	27.9	26.9	26.0	24.5	(33)	(34)
		MCDB	25.8	26.9	28.8	30.7	31.7	32.2	31.7	31.3	30.7	29.2	28.2	26.5	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	3.6	4.4	5.0	5.2	4.9	4.5	4.6	4.5	4.7	4.1	3.2	3.0	(35)	(36)
		MCDBR	4.6	5.5	6.0	5.9	5.6	5.3	5.3	5.2	5.4	5.0	4.3	4.0	(36)	(37)
	5% WB	MCWBR	2.3	2.4	2.5	2.3	2.2	2.2	2.4	2.6	2.7	2.6	2.2	2.0	(37)	(38)
		MCWBR	4.3	5.3	5.8	5.5	5.0	4.9	5.0	4.9	5.1	4.7	4.1	3.6	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.484	0.481	0.545	0.507	0.451	0.446	0.436	0.450	0.487	0.536	0.541	0.556	(39)	(40)
		taud	2.140	2.171	2.024	2.185	2.415	2.439	2.466	2.407	2.277	2.078	2.025	1.943	(40)	(41)
	Ebn at Noon		801	827	786	814	850	845	855	851	822	768	742	719	(41)	(42)
		Edh at Noon	148	150	178	152	119	115	112	120	136	162	165	176	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		4.24	5.15	5.84	6.47	6.38	6.09	5.82	5.64	5.26	4.89	4.15	3.64	(43)	(44)
	RadStd		0.41	0.50	0.44	0.33	0.42	0.51	0.44	0.43	0.36	0.43	0.54	0.57	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	-0.24	-0.30	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+112	+112

Nomenclature: See separate page