

SANTA CRUZ DE TENERIFE, Spain

WMO: 600200

Lat: 28.4632N

Lon: 16.2555W

Elev: 118

StdP: 14.63

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	57.4	58.6	37.2	32.7	64.9	41.6	38.9	65.7	15.7	65.6	13.8	66.1	5.7	280	0.248

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.0	87.7	69.5	85.5	69.7	83.7	69.6	73.6	81.3	72.6	80.7	71.7	80.2	6.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.1	115.3	77.4	69.8	110.2	77.5	68.6	105.6	77.4	37.1	81.4	36.2	80.5	35.4	80.3	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.7	11.6	DB	53.4	93.3	3.8	3.1	50.7	95.5	48.5	97.3	46.4	99.0	43.7	101.2	(4)
(5)			WB	47.0	74.7	2.5	2.3	45.2	76.4	43.8	77.8	42.4	79.1	40.5	80.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.1	65.1	65.2	66.6	68.0	70.0	73.5	76.9	77.9	76.7	74.4	70.7	67.6	(6)	
	DBStd	5.20	2.50	2.53	3.16	2.66	2.87	2.60	2.73	2.60	2.00	2.72	2.77	1.99	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	74	28	23	14	4	1	0	0	0	0	0	1	3	(9)	
	CDD50	7700	467	427	516	540	621	706	833	864	802	757	622	545	(10)	
	CDD65	2298	30	30	65	94	157	256	368	399	352	292	172	83	(11)	
	CDH74	10201	8	32	128	123	289	998	2393	2816	1963	1129	290	32	(12)	
	CDH80	1754	0	1	21	7	33	126	557	617	255	118	19	0	(13)	
(14) Wind	WSAvg	5.6	5.4	5.6	5.8	6.1	6.2	6.0	5.6	5.4	5.4	4.8	5.0	5.4	(14)	
(15) Precipitation	PrecAvg	8.6	1.4	1.3	1.1	0.5	0.1	0.0	0.0	0.0	0.1	0.7	1.5	1.8	(15)	
	PrecMax	16.9	8.0	5.4	3.6	2.0	1.0	0.5	0.0	1.6	1.1	3.4	6.3	9.4	(16)	
	PrecMin	4.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	3.1	1.6	1.4	1.0	0.4	0.2	0.1	0.0	0.2	0.2	0.8	1.6	2.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.1	77.6	82.6	80.2	84.4	87.0	91.5	90.7	86.4	87.7	83.2	76.9	(19)	
		MCWB	63.3	60.4	62.0	64.4	67.2	67.5	68.6	69.8	71.0	68.3	66.7	65.0	(20)	
	2%	DB	72.6	74.4	77.1	77.1	79.1	83.1	87.4	87.3	84.3	82.7	79.2	74.6	(21)	
		MCWB	62.7	61.4	62.1	63.6	65.8	67.8	69.5	70.5	70.9	68.5	67.3	64.6	(22)	
	5%	DB	71.0	71.8	74.0	74.9	76.8	80.8	84.9	85.2	82.7	80.7	77.1	73.0	(23)	
		MCWB	61.9	61.4	62.3	63.2	65.1	67.3	69.6	70.4	70.2	69.0	66.9	63.7	(24)	
	10%	DB	69.3	69.9	71.7	73.0	75.0	79.0	83.1	83.2	81.3	79.1	75.4	71.6	(25)	
		MCWB	60.9	60.8	61.5	62.4	64.4	66.8	69.1	70.1	69.8	68.7	66.1	62.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.0	67.2	67.2	67.7	69.0	71.6	73.4	77.1	74.4	73.6	72.5	68.3	(27)	
		MCDB	72.0	70.8	72.9	74.9	78.0	80.2	84.7	82.3	81.3	78.3	77.4	73.7	(28)	
	2%	WB	65.1	64.8	65.5	65.9	67.4	70.2	72.0	73.8	73.2	72.1	70.1	66.6	(29)	
		MCDB	70.4	70.4	72.0	73.9	76.0	78.6	83.2	82.1	80.2	78.2	76.1	72.1	(30)	
	5%	WB	63.5	63.0	64.0	64.5	66.4	69.0	71.1	72.6	72.2	71.1	68.6	65.4	(31)	
		MCDB	69.3	69.6	71.4	72.8	74.7	78.0	82.0	81.4	79.7	77.7	75.0	71.2	(32)	
	10%	WB	62.0	61.7	62.6	63.2	65.4	67.8	70.1	71.5	71.2	70.2	67.3	64.3	(33)	
		MCDB	68.3	68.6	70.9	71.8	73.8	77.6	80.8	80.9	79.2	77.0	74.2	70.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	9.2	9.5	9.8	9.8	10.9	11.8	11.0	9.8	9.6	8.8	8.9	(35)	
		MCDBR	10.5	11.9	12.8	11.9	12.2	13.3	14.4	13.4	11.7	11.4	10.6	10.5	(36)	
	5% WB	MCWBR	8.1	8.8	8.2	7.2	6.5	6.7	7.3	7.2	5.9	7.1	7.6	7.8	(37)	
		MCWBR	10.1	10.4	11.7	11.1	11.1	11.8	12.5	11.5	10.2	10.1	9.7	9.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.356	0.375	0.403	0.395	0.387	0.414	0.495	0.491	0.441	0.394	0.379	0.368	(40)	
		taud	2.489	2.413	2.320	2.377	2.421	2.351	2.083	2.127	2.313	2.458	2.469	2.467	(41)	
	Ebn at Noon		280	283	281	286	287	277	255	256	266	273	270	270	(42)	
		Edh at Noon	30	35	40	39	37	40	52	49	40	33	30	29	(43)	
(44) All-Sky Solar Radiation	RadAvg		1112	1361	1720	1990	2141	2211	2141	2029	1848	1480	1133	1000	(44)	
(45)	RadStd		48	89	68	86	87	95	99	89	67	46	63	70	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page