

SANTA CRUZ DE TENERIFE, Spain

WMO: 600200

Lat: 28.4632N

Lon: 16.2555W

Elev: 36

StdP: 100.89

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	14.8	2.9	4.7	18.3	5.3	5.6	18.7	7.0	18.7	6.2	18.9	2.6	280	0.248

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.1	30.9	20.8	29.7	20.9	28.7	20.9	23.1	27.4	22.5	27.0	22.1	26.8	2.8	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.7	16.5	25.2	21.0	15.7	25.3	20.3	15.1	25.2	68.3	27.5	66.3	26.9	64.5	26.8	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.4	5.7	5.2	11.9	34.0	2.1	1.7	10.4	35.3	9.2	36.3	8.0	37.2	6.5	38.4		
			8.4	23.7	1.4	1.3	7.4	24.7	6.5	25.4	5.8	26.1	4.7	27.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.7	18.4	18.5	19.2	20.0	21.1	23.1	24.9	25.5	24.9	23.6	21.5	19.8
	DBStd	2.89	1.39	1.40	1.75	1.48	1.60	1.45	1.52	1.44	1.11	1.51	1.54	1.11
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	41	16	13	8	2	1	0	0	0	0	0	1	2
	CDD10.0	4278	259	237	287	300	345	392	463	480	446	421	346	303
	CDD18.3	1277	17	17	36	52	87	142	204	222	196	162	96	46
	CDH23.3	5667	4	18	71	68	161	554	1329	1564	1091	627	161	18
	CDH26.7	974	0	1	12	4	18	70	309	343	142	66	11	0
Wind	WSAvg	2.5	2.4	2.5	2.6	2.7	2.8	2.7	2.5	2.4	2.4	2.1	2.2	2.4
Precipitation	PrecAvg	218	35	34	27	12	3	1	0	1	3	19	37	46
	PrecMax	429	202	138	91	52	26	13	1	41	29	87	161	239
	PrecMin	105	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	80	40	35	25	11	5	2	0	6	5	20	40	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.9	25.3	28.1	26.8	29.1	30.6	33.0	32.6	30.2	31.0	28.4	25.0
		MCWB	17.4	15.8	16.7	18.0	19.5	19.7	20.3	21.0	21.6	20.2	19.3	18.3
	2%	DB	22.5	23.6	25.1	25.1	26.2	28.4	30.8	30.7	29.1	28.1	26.2	23.6
		MCWB	17.0	16.3	16.7	17.5	18.8	19.9	20.9	21.4	21.6	20.3	19.6	18.1
	5%	DB	21.6	22.1	23.3	23.8	24.9	27.1	29.4	29.5	28.2	27.0	25.1	22.8
		MCWB	16.6	16.3	16.8	17.4	18.4	19.6	20.9	21.3	21.2	20.6	19.4	17.6
	10%	DB	20.7	21.1	22.0	22.8	23.9	26.1	28.4	28.5	27.4	26.2	24.1	22.0
		MCWB	16.0	16.0	16.4	16.9	18.0	19.3	20.6	21.2	21.0	20.4	19.0	17.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.4	19.5	19.6	19.8	20.6	22.0	23.0	25.0	23.6	23.1	22.5	20.2
		MCDB	22.2	21.6	22.7	23.8	25.5	26.8	29.3	27.9	27.4	25.7	25.2	23.1
	2%	WB	18.4	18.2	18.6	18.8	19.7	21.2	22.2	23.2	22.9	22.3	21.2	19.2
		MCDB	21.3	21.3	22.2	23.3	24.5	25.9	28.4	27.8	26.8	25.7	24.5	22.3
	5%	WB	17.5	17.2	17.8	18.1	19.1	20.6	21.7	22.5	22.4	21.7	20.3	18.6
		MCDB	20.7	20.9	21.9	22.7	23.7	25.6	27.8	27.5	26.5	25.4	23.9	21.8
	10%	WB	16.7	16.5	17.0	17.4	18.6	19.9	21.2	22.0	21.8	21.2	19.6	17.9
		MCDB	20.2	20.3	21.6	22.1	23.2	25.4	27.1	27.2	26.2	25.0	23.4	21.3
Mean Daily Temperature Range	5% DB	MDBR	4.8	5.1	5.3	5.4	5.4	6.0	6.6	6.1	5.4	5.3	4.9	4.9
		MCDBR	5.8	6.6	7.1	6.6	6.8	7.4	8.0	7.5	6.5	6.3	5.9	5.8
		MCWBR	4.5	4.9	4.5	4.0	3.6	3.7	4.0	4.0	3.3	4.0	4.2	4.3
	5% WB	MCDBR	5.6	5.8	6.5	6.1	6.1	6.6	7.0	6.4	5.6	5.6	5.4	5.4
		MCWBR	4.6	4.8	4.5	4.2	3.8	3.8	3.8	3.8	3.4	4.0	4.5	4.2
Clear-Sky Solar Irradiance	taub	0.356	0.375	0.403	0.395	0.387	0.414	0.495	0.491	0.441	0.394	0.379	0.368	
	taud	2.489	2.413	2.320	2.377	2.421	2.351	2.083	2.127	2.313	2.458	2.469	2.467	
	Ebn at Noon	884	893	886	902	904	874	804	806	839	862	851	851	
	Edh at Noon	93	109	126	123	118	126	164	156	126	103	95	92	
All-Sky Solar Radiation	RadAvg	3.51	4.29	5.42	6.28	6.75	6.97	6.75	6.40	5.83	4.67	3.57	3.15	
	RadStd	0.15	0.28	0.21	0.27	0.27	0.30	0.31	0.28	0.21	0.15	0.20	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page