

AL HOCEIMA CHERIF AL IDRISSE, MoroccoWMO: **601070**Lat: **35.1803N**Lon: **3.8437W**Elev: **46**StdP: **14.67**Time Zone: **1.00 (E01)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.5	44.4	28.9	23.0	50.2	33.5	28.1	52.5	22.5	57.6	18.7	58.8	3.9	180	0.340

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.8	88.2	69.5	85.7	70.4	83.0	70.8	77.0	81.7	75.6	80.4	74.4	79.2	9.2	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.3	133.0	80.2	73.8	126.1	78.7	73.0	122.8	78.0	40.3	81.9	39.1	80.4	37.9	79.1	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	16.1	14.1	38.7	94.6	3.3	3.5	36.3	97.1	34.4	99.1	32.5	101.0	30.1	103.6		
(5)			35.4	78.4	3.4	2.7	33.0	80.3	31.1	81.9	29.2	83.4	26.7	85.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	55.2	56.2	58.8	61.3	66.2	71.7	75.5	76.5	72.5	67.9	61.2	57.1
	DBStd	8.19	3.60	3.55	3.33	3.20	3.54	3.21	3.39	3.29	3.43	3.55	4.26	3.51
	HDD50	8	4	3	0	0	0	0	0	0	0	0	0	1
	HDD65	1274	303	247	195	116	26	0	0	0	0	13	127	247
	CDD50	5508	167	176	273	339	503	650	792	822	675	554	337	220
	CDD65	1298	0	0	2	6	64	200	327	357	225	102	14	1
	CDH74	7188	1	0	16	22	182	839	2172	2572	1071	272	39	2
	CDH80	1464	0	0	1	1	18	134	504	623	156	24	3	0
Wind	WSAvg	5.6	5.2	5.8	6.0	6.2	6.1	6.4	6.0	5.8	5.4	4.7	5.1	4.9
Precipitation	PrecAvg	14.5	1.8	1.8	1.7	1.5	0.9	0.4	0.1	0.2	0.7	1.8	2.1	1.9
	PrecMax	25.9	5.7	8.5	4.4	5.9	3.0	4.7	0.4	1.3	1.8	13.8	8.2	6.1
	PrecMin	8.4	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1
	PrecStd	4.5	1.6	1.7	1.2	1.3	0.9	1.0	0.1	0.3	0.5	2.6	1.9	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.2	71.2	76.3	76.9	82.4	87.6	93.3	92.9	87.3	83.7	78.5	71.9
		MCWB	57.9	57.6	59.8	60.1	64.2	67.0	68.8	70.5	71.6	68.8	62.0	59.1
	2%	DB	67.2	68.1	71.2	73.4	78.5	83.6	88.5	88.2	84.0	79.1	73.8	68.4
		MCWB	57.2	57.2	59.1	60.6	64.6	67.9	68.6	70.7	72.3	68.9	62.9	58.7
	5%	DB	64.7	66.1	68.2	70.9	75.5	80.8	84.9	85.8	81.4	77.0	71.4	66.4
		MCWB	56.5	56.5	58.1	59.9	64.2	68.0	70.2	71.2	71.7	68.2	62.5	58.3
	10%	DB	62.8	64.1	66.1	68.4	73.4	78.6	82.4	83.2	79.2	75.1	69.4	64.6
		MCWB	55.7	56.2	57.8	59.7	63.9	67.8	70.2	72.2	70.7	67.5	61.8	57.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.7	60.9	63.6	65.4	69.4	75.2	77.8	79.2	77.2	72.9	67.4	63.4
		MCDB	66.4	66.1	69.2	71.1	75.7	81.0	83.1	83.9	81.9	78.1	72.4	66.6
	2%	WB	59.4	59.3	61.6	63.5	67.9	72.9	76.1	77.5	75.5	71.3	65.6	61.4
		MCDB	64.2	64.9	67.1	68.7	73.6	77.8	81.0	82.1	80.0	76.3	71.3	65.3
	5%	WB	57.9	58.1	60.3	62.3	66.7	71.3	74.7	76.3	73.9	69.9	64.1	59.9
		MCDB	63.1	63.7	65.4	67.4	72.4	76.2	79.6	80.9	78.7	74.6	69.4	64.6
	10%	WB	56.5	57.1	59.2	61.1	65.4	70.1	73.6	74.9	72.4	68.8	62.8	58.4
		MCDB	61.8	62.5	64.3	66.5	71.2	75.1	78.5	79.6	77.5	73.4	67.6	63.7
Mean Daily Temperature Range	5% DB	MDBR	15.7	14.9	14.5	14.2	13.2	12.6	12.8	12.8	12.6	13.2	14.9	15.5
		MCDBR	18.1	18.4	18.5	18.4	16.9	16.5	17.8	17.1	15.3	16.1	17.3	17.3
		MCWBR	11.9	11.3	11.0	10.4	9.3	8.2	9.5	9.2	8.8	9.5	10.2	11.1
	5% WB	MCDBR	15.9	15.3	14.9	14.3	13.8	12.5	11.8	12.3	12.4	13.4	14.2	15.7
		MCWBR	11.3	10.4	10.2	9.5	8.5	7.2	8.0	8.0	8.2	8.9	9.4	11.1
Clear-Sky Solar Irradiance	taub		0.330	0.364	0.424	0.431	0.462	0.500	0.535	0.524	0.476	0.427	0.372	0.339
	taud		2.496	2.393	2.196	2.204	2.144	2.042	1.948	1.990	2.134	2.267	2.410	2.490
	Ebn at Noon		277	277	267	272	264	252	243	243	248	251	257	265
	Edh at Noon		27	33	43	45	49	54	59	56	46	37	29	25
All-Sky Solar Radiation	RadAvg		888	1150	1508	1837	2120	2379	2339	2070	1674	1253	930	797
	RadStd		76	113	143	138	161	69	54	83	76	88	71	65