

TAZA, Morocco

WMO: 601270

Lat: 34.217N

Lon: 4.000W

Elev: 1673

StdP: 13.83

Time Zone: 1.00 (E01)

Period: 90-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 36.5	(c) 39.0	(d) 26.6	(e) 21.9	(f) 50.5	(g) 29.5	(h) 25.0	(i) 50.2	(j) 16.3	(k) 50.2	(l) 12.9	(m) 50.3	(n) 0.4	(o) 90	(p) 0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 24.2	(c) 102.4	(d) 69.4	(e) 99.2	(f) 69.0	(g) 96.2	(h) 68.5	(i) 72.8	(j) 93.3	(k) 71.5	(l) 91.5	(m) 70.3	(n) 89.9	(o) 1.5	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	104.4	80.8	65.3	99.4	79.5	63.9	94.7	78.7	37.4	94.2	36.2	91.4	35.2	90.1	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.3	(b) 11.8	(c) 9.7	(e) 33.0	(f) 107.8	(g) 3.8	(h) 2.7	(i) 30.3	(j) 109.7	(k) 28.1	(l) 111.3	(m) 25.9	(n) 112.8	(o) 23.2	(p) 114.7		
			DB													
			WB													
				30.9	76.8	3.5	2.5	28.4	78.6	26.4	80.1	24.5	81.5	21.9	83.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.6	50.5	53.9	58.0	60.9	67.6	75.8	83.0	83.3	75.3	67.2	58.3	52.4
	DBStd	12.30	4.09	4.75	5.29	5.22	6.40	5.65	5.60	4.72	5.46	5.16	5.18	3.92
	HDD50	89	42	17	7	0	0	0	0	0	0	0	2	21
	HDD65	1814	450	311	222	143	47	3	0	0	3	37	208	390
	CDD50	5777	57	127	255	328	544	774	1022	1031	759	533	251	96
	CDD65	2025	0	0	5	20	126	327	557	566	312	105	7	0
	CDH74	22344	0	5	77	217	1181	3388	7139	7000	2697	596	44	0
	CDH80	11397	0	0	7	30	425	1591	4152	3943	1112	133	4	0
Wind	WSAvg	2.8	1.9	2.7	3.0	3.8	3.3	3.7	2.8	2.3	2.9	2.4	2.6	2.3
Precipitation	PrecAvg	26.8	3.6	4.6	4.1	3.2	1.8	0.6	0.1	0.1	0.4	1.9	3.1	4.3
	PrecMax	46.7	11.0	13.7	14.8	8.5	7.7	1.9	0.7	0.5	1.8	7.3	11.7	13.3
	PrecMin	14.4	0.0	0.0	0.4	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	8.8	3.4	3.7	3.4	2.3	1.7	0.6	0.2	0.2	0.5	2.0	3.1	3.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.3	74.5	80.2	83.9	93.1	100.9	106.8	105.2	97.4	87.9	79.1	67.5
		MCWB	53.5	55.8	58.8	62.0	65.2	69.9	68.7	70.3	67.9	64.9	60.8	54.0
	2%	DB	63.7	70.2	75.7	79.5	88.8	96.3	103.6	102.0	93.3	83.6	73.8	64.3
		MCWB	52.3	54.5	56.9	59.9	64.0	68.6	68.9	69.6	67.2	63.7	58.3	53.7
	5%	DB	60.7	66.7	72.0	76.1	84.6	92.5	100.4	98.8	89.8	80.3	70.2	61.8
		MCWB	51.0	53.5	56.1	58.7	62.8	67.4	69.1	69.1	67.0	62.9	57.3	53.4
	10%	DB	58.0	63.2	68.6	72.3	80.8	88.9	97.1	95.7	86.5	77.0	67.0	59.4
		MCWB	49.9	52.4	55.6	57.8	62.1	66.5	68.7	68.5	66.6	62.4	56.2	52.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.0	59.0	61.9	64.7	68.1	73.7	73.7	75.7	71.6	68.4	63.0	59.0
		MCDB	62.7	69.6	73.0	78.4	88.5	91.1	96.0	96.4	87.8	80.7	72.4	62.7
	2%	WB	54.6	56.5	59.6	62.1	66.0	70.6	72.5	73.2	70.1	66.6	60.8	56.5
		MCDB	60.5	65.3	71.4	75.3	83.4	90.2	94.7	93.0	86.2	78.0	69.2	60.5
	5%	WB	52.6	54.9	57.9	60.4	64.4	69.1	71.3	71.7	69.0	65.2	59.3	54.9
		MCDB	58.5	63.2	68.2	72.7	80.9	88.3	93.1	91.0	84.4	75.8	66.7	59.7
	10%	WB	51.0	53.4	56.3	58.7	62.9	67.7	70.1	70.4	67.9	63.9	57.7	53.3
		MCDB	56.7	61.0	65.9	69.7	77.4	86.0	91.7	89.5	82.5	73.6	64.6	58.4
Mean Daily Temperature Range	5% DB	MDBR	15.7	16.5	17.5	18.2	19.9	22.8	25.2	24.2	20.0	17.4	15.2	14.3
		MCDBR	20.9	23.6	25.1	25.5	27.5	28.1	28.9	27.9	25.0	23.3	21.3	18.7
		MCWBR	11.0	11.1	10.8	11.1	10.0	9.3	7.9	7.9	7.7	8.6	8.8	9.9
	5% WB	MCDBR	16.4	18.7	20.7	22.3	23.8	25.6	26.8	25.5	21.6	19.5	16.5	13.9
		MCWBR	9.2	9.7	10.1	10.8	9.6	9.2	8.7	8.6	7.2	7.9	7.4	8.4
Clear-Sky Solar Irradiance	taub	0.290	0.322	0.377	0.392	0.426	0.459	0.505	0.480	0.430	0.386	0.330	0.300	
	taud	2.540	2.447	2.283	2.256	2.186	2.086	1.953	2.033	2.192	2.317	2.472	2.535	
	Ebn at Noon	295	294	284	284	274	264	251	255	263	266	276	284	
	Edh at Noon	25	31	40	43	47	52	59	53	43	35	27	24	
All-Sky Solar Radiation	RadAvg	954	1236	1616	1942	2219	2483	2444	2197	1791	1355	1001	875	
	RadStd	92	115	121	134	146	75	53	66	83	96	87	71	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	+0.70	N/A	N/A	+2.30	N/A	N/A	N/A	N/A	+351	+344

Nomenclature: See separate page