

TAZA, Morocco

WMO: 601270

Lat: 34.217N

Lon: 4.000W

Elev: 510

StdP: 95.35

Time Zone: 1.00 (E01)

Period: 90-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.5	3.9	-3.0	3.1	10.3	-1.4	3.6	10.1	7.3	10.1	5.7	10.2	0.2	90	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.4	39.1	20.8	37.4	20.5	35.7	20.3	22.6	34.1	21.9	33.1	21.3	32.2	0.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.9	27.1	18.5	14.2	26.4	17.7	13.5	25.9	69.2	34.6	66.4	33.0	64.0	32.3	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.4	5.3	4.3	0.5	42.1	2.1	1.5	-1.0	43.2	-2.2	44.0	-3.4	44.9	-4.9	45.9		
			-0.6	24.9	1.9	1.4	-2.0	25.9	-3.1	26.7	-4.2	27.5	-5.6	28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	10.3	12.2	14.4	16.1	19.8	24.3	28.3	28.5	24.1	19.5	14.6	11.3
	DBStd	6.84	2.27	2.64	2.94	2.90	3.56	3.14	3.11	2.62	3.03	2.87	2.88	2.18
	HDD10.0	49	23	9	4	0	0	0	0	0	0	0	1	12
	HDD18.3	1008	250	173	123	79	26	2	0	0	2	21	116	217
	CDD10.0	3209	32	71	142	182	302	430	568	573	422	296	139	53
	CDD18.3	1125	0	0	3	11	70	182	309	314	173	58	4	0
	CDH23.3	12413	0	3	43	121	656	1882	3966	3889	1498	331	24	0
	CDH26.7	6332	0	0	4	17	236	884	2307	2191	618	74	2	0
Wind	WSAvg	1.2	0.8	1.2	1.3	1.7	1.5	1.6	1.3	1.0	1.3	1.1	1.2	1.0
Precipitation	PrecAvg	681	92	116	104	82	45	16	3	2	11	49	79	109
	PrecMax	1185	279	347	377	215	196	49	19	12	45	186	298	338
	PrecMin	365	0	1	9	5	1	0	0	0	0	0	0	0
	PrecStd	223	86	93	86	58	42	15	4	4	12	50	78	78
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.6	23.6	26.8	28.8	34.0	38.3	41.5	40.7	36.3	31.1	26.2	19.7
		MCWB	11.9	13.2	14.9	16.7	18.4	21.1	20.4	21.3	19.9	18.3	16.0	12.2
	2%	DB	17.6	21.2	24.3	26.4	31.5	35.7	39.8	38.9	34.0	28.7	23.2	17.9
		MCWB	11.3	12.5	13.8	15.5	17.8	20.3	20.5	20.9	19.6	17.6	14.6	12.0
	5%	DB	16.0	19.3	22.2	24.5	29.2	33.6	38.0	37.1	32.1	26.8	21.2	16.6
		MCWB	10.5	11.9	13.4	14.8	17.1	19.7	20.6	20.6	19.5	17.2	14.0	11.9
	10%	DB	14.5	17.4	20.3	22.4	27.1	31.6	36.2	35.4	30.3	25.0	19.4	15.2
		MCWB	10.0	11.3	13.1	14.3	16.7	19.2	20.4	20.3	19.2	16.9	13.5	11.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.9	15.0	16.6	18.1	20.1	23.2	23.2	24.3	22.0	20.2	17.2	15.0
		MCDB	17.1	20.9	22.8	25.8	31.4	32.9	35.6	35.8	31.0	27.1	22.4	17.0
	2%	WB	12.5	13.6	15.3	16.7	18.9	21.5	22.5	22.9	21.2	19.2	16.0	13.6
		MCDB	15.8	18.5	21.9	24.1	28.6	32.3	34.8	33.9	30.1	25.6	20.7	15.8
	5%	WB	11.5	12.7	14.4	15.8	18.0	20.6	21.8	22.0	20.5	18.5	15.2	12.7
		MCDB	14.7	17.3	20.1	22.6	27.2	31.3	34.0	32.8	29.1	24.3	19.3	15.4
	10%	WB	10.5	11.9	13.5	14.8	17.2	19.8	21.2	21.4	19.9	17.7	14.3	11.8
		MCDB	13.7	16.1	18.9	20.9	25.2	30.0	33.1	31.9	28.0	23.1	18.1	14.7
Mean Daily Temperature Range	5% DB	MDBR	8.7	9.2	9.7	10.1	11.1	12.7	14.0	13.4	11.1	9.7	8.4	8.0
		MCDBR	11.6	13.1	14.0	14.2	15.3	15.6	16.1	15.5	13.9	12.9	11.9	10.4
		MCWBR	6.1	6.2	6.0	6.1	5.5	5.2	4.4	4.4	4.3	4.8	4.9	5.5
	5% WB	MCDBR	9.1	10.4	11.5	12.4	13.2	14.2	14.9	14.2	12.0	10.9	9.1	7.7
		MCWBR	5.1	5.4	5.6	6.0	5.3	5.1	4.8	4.8	4.0	4.4	4.1	4.7
Clear-Sky Solar Irradiance	taub		0.290	0.322	0.377	0.392	0.426	0.459	0.505	0.480	0.430	0.386	0.330	0.300
	taud		2.540	2.447	2.283	2.256	2.186	2.086	1.953	2.033	2.192	2.317	2.472	2.535
	Ebn at Noon		930	927	894	894	864	831	791	804	829	840	869	896
	Edh at Noon		80	98	126	136	148	163	185	168	137	111	86	77
All-Sky Solar Radiation	RadAvg		3.01	3.90	5.09	6.12	7.00	7.83	7.70	6.93	5.65	4.27	3.16	2.76
	RadStd		0.29	0.36	0.38	0.42	0.46	0.24	0.17	0.21	0.26	0.30	0.27	0.22

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+0.39	N/A	N/A	+1.28	N/A	N/A	N/A	N/A	+195	+191

Nomenclature: See separate page