

AGADIR INEZGANE, Morocco

WMO: 602500

Lat: 30.381N

Lon: 9.546W

Elev: 27

StdP: 101.00

Time Zone: 1.00 (E01)

Period: 82-91

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.0	6.4	-2.1	3.2	19.3	0.0	3.8	19.0	17.7	20.7	13.7	22.3	0.9	80	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	8.3	35.2	19.4	31.8	18.9	29.0	18.4	22.5	28.7	21.8	26.6	21.3	25.4	4.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.7	24.0	20.2	15.0	23.2	20.0	14.8	23.0	66.0	28.8	63.7	26.8	62.0	25.1	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.5	8.7	7.2	DB	2.1	43.0	1.0	3.1	1.3	45.2	0.7	47.0	0.2	48.8	-0.6	51.0	
			WB	1.3	25.2	0.8	1.8	0.6	26.5	0.1	27.6	-0.3	28.6	-0.9	29.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	13.8	15.3	17.1	17.6	18.8	20.5	22.1	22.6	22.6	20.5	17.9	15.3
	DBStd	3.97	2.62	2.94	3.15	2.87	2.43	1.57	1.87	2.70	3.05	3.10	2.83	3.07
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	520	144	94	63	46	16	1	0	0	0	9	41	107
	CDD10.0	3173	119	149	221	227	274	316	374	391	379	325	236	163
	CDD18.3	651	4	9	25	22	32	67	116	132	129	76	27	11
	CDH23.3	3239	43	74	260	219	173	128	334	581	709	495	147	76
Wind	WSAvg	2.8	2.5	3.1	3.0	3.3	3.5	3.1	2.4	2.3	2.5	2.6	2.4	2.4
	PrecAvg	255	47	34	31	15	4	1	0	0	3	20	45	56
Precipitation	PrecMax	670	179	113	131	102	36	12	1	2	42	85	192	315
	PrecMin	46	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	144	53	35	32	19	8	2	0	0	7	24	53	73
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	29.1	32.9	35.2	36.8	30.1	33.0	41.9	40.1	35.9	30.9	28.9
		MCWB	15.1	15.4	16.1	16.9	22.3	20.5	22.1	22.2	21.0	19.1	17.0	16.4
	2%	DB	23.8	25.2	29.2	29.9	26.9	25.9	28.1	32.8	33.9	31.9	27.1	25.2
		MCWB	13.4	14.7	16.2	16.4	18.7	19.6	20.9	21.5	20.3	18.6	16.7	15.5
	5%	DB	21.2	23.0	26.0	24.2	23.9	24.4	26.2	27.9	29.7	28.1	24.9	22.8
		MCWB	12.9	14.4	15.4	16.3	18.3	19.4	20.7	21.4	20.5	18.1	17.1	14.8
	10%	DB	19.2	21.0	23.0	21.8	22.2	23.3	24.9	25.7	26.8	25.2	23.0	20.9
		MCWB	13.3	13.9	15.7	16.4	17.7	19.0	20.6	21.0	20.9	18.5	17.1	14.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.9	17.8	18.7	19.2	21.9	21.7	23.0	23.5	23.2	21.3	20.6	18.7
		MCDB	24.4	21.8	24.4	24.9	33.2	27.1	29.5	33.5	30.3	26.2	23.6	23.4
	2%	WB	15.7	16.8	17.7	18.3	20.0	20.6	22.0	22.5	22.2	20.6	19.5	17.7
		MCDB	19.2	20.8	23.2	23.2	24.9	24.4	26.0	29.1	27.7	25.1	22.3	21.4
	5%	WB	15.1	16.1	17.1	17.6	19.1	19.9	21.4	21.7	21.6	20.1	18.7	16.8
		MCDB	18.3	19.9	22.2	21.9	22.8	23.3	24.8	26.7	26.5	24.4	21.8	20.2
	10%	WB	14.4	15.4	16.5	17.1	18.3	19.5	21.0	21.2	21.1	19.5	18.0	16.0
		MCDB	18.0	19.1	21.2	20.7	21.6	22.6	23.8	25.0	25.5	23.5	21.5	19.3
Mean Daily Temperature Range	5% DB	MDBR	12.3	10.8	10.7	9.3	8.2	7.0	6.9	7.2	8.3	9.4	10.1	11.5
		MCDBR	14.6	13.9	15.8	14.6	11.1	8.6	9.4	11.7	14.6	14.4	12.9	13.3
		MCWBR	8.1	6.8	6.8	6.4	5.1	4.1	4.1	4.5	5.2	6.1	6.3	7.0
	5% WB	MCDBR	12.2	11.2	12.0	10.3	9.0	7.5	7.3	9.3	9.8	9.4	9.2	10.5
		MCWBR	8.3	6.8	6.8	5.7	4.8	3.9	3.5	4.0	4.6	5.0	5.6	6.7
Clear-Sky Solar Irradiance	taub		0.323	0.369	0.426	0.425	0.449	0.491	0.582	0.563	0.472	0.430	0.376	0.349
	taud		2.509	2.348	2.153	2.193	2.140	2.030	1.801	1.868	2.110	2.220	2.369	2.442
	Ebn at Noon		911	889	856	870	847	808	735	743	803	812	837	857
	Edh at Noon		88	114	147	147	156	173	217	201	152	128	101	91
All-Sky Solar Radiation	RadAvg		3.79	4.64	5.89	6.83	7.44	7.60	7.49	6.84	5.91	4.72	3.85	3.37
	RadStd		0.21	0.36	0.23	0.27	0.36	0.16	0.19	0.17	0.27	0.21	0.22	0.25

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+0.24	N/A	N/A	N/A	-0.32	N/A	N/A	+153	+171

Nomenclature: See separate page