

JIJEL FERHAT ABBAS, Algeria

WMO: 603510

Lat: 36.795N

Lon: 5.874E

Elev: 11

StdP: 101.19

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.9	5.9	1.1	4.1	9.6	2.3	4.5	9.3	12.3	13.1	11.0	12.7	1.3	160	0.373

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	34.9	22.9	32.9	23.1	31.2	23.2	26.1	30.3	25.4	29.7	24.7	29.0	4.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.9	20.0	28.8	24.1	19.0	28.1	23.3	18.1	27.6	80.4	30.5	77.7	29.7	75.1	29.1	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	8.5	7.4	DB	3.5	39.5	1.0	2.8	2.8	41.5	2.2	43.1	1.7	44.7	1.0	46.7	
			WB	2.5	27.4	1.0	0.8	1.8	28.0	1.2	28.4	0.7	28.8	0.0	29.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	11.9	11.8	14.0	16.1	18.9	22.8	25.7	26.3	24.0	21.2	16.3	13.2
	DBStd	5.69	2.04	2.54	2.67	2.40	2.54	2.73	2.23	2.20	2.29	2.76	2.86	2.23
	HDD10.0	18	6	8	2	0	0	0	0	0	0	1	2	
	HDD18.3	854	199	183	137	75	22	1	0	0	4	73	160	
	CDD10.0	3141	65	59	126	183	274	385	487	504	419	348	189	101
	CDD18.3	936	0	1	3	8	38	136	228	246	169	94	12	1
	CDH23.3	8468	1	8	32	54	234	1079	2352	2606	1407	633	59	3
CDH26.7	2922	0	1	8	11	57	327	882	1056	396	180	6	0	
Wind	WSAvg	2.4	2.6	2.9	2.6	2.4	2.3	2.3	2.4	2.3	2.1	1.9	2.4	2.5
Precipitation	PrecAvg	975	131	113	91	75	50	13	2	15	60	96	149	179
	PrecMax	1359	333	375	255	189	156	54	20	101	185	296	344	393
	PrecMin	597	12	0	7	1	4	0	0	0	2	3	7	3
	PrecStd	180	72	86	60	48	41	15	4	24	38	67	78	96
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.2	24.2	27.0	27.5	31.9	36.1	38.0	38.0	34.6	33.9	27.2	23.3
		MCWB	14.7	15.4	16.4	17.6	22.2	22.1	23.8	23.8	22.8	20.6	17.0	15.9
	2%	DB	19.1	20.1	23.1	24.3	27.8	32.6	34.0	34.8	31.8	30.8	25.0	20.9
		MCWB	13.8	14.2	15.5	17.4	20.0	22.4	23.1	23.6	23.0	20.4	16.8	14.6
	5%	DB	17.8	18.2	21.0	22.8	25.8	30.0	31.9	32.8	30.0	28.3	23.1	19.1
		MCWB	13.4	13.6	15.1	16.8	19.4	22.0	23.6	23.6	22.9	20.7	16.8	14.0
	10%	DB	16.3	16.9	19.3	21.1	24.0	28.1	30.5	31.1	28.9	26.5	21.5	17.9
		MCWB	12.6	13.0	14.6	16.3	18.8	21.8	23.5	24.2	22.9	20.5	16.5	13.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.8	16.6	18.2	19.8	22.7	25.1	26.9	27.0	26.2	24.0	20.2	16.8
		MCDB	19.5	20.7	24.5	24.8	29.6	30.2	31.4	31.1	30.0	28.2	23.6	21.2
	2%	WB	14.7	15.2	16.7	18.5	21.1	24.0	26.0	26.2	25.1	22.9	18.8	15.6
		MCDB	18.2	18.9	21.2	22.8	25.6	28.9	30.1	30.5	28.9	26.8	22.3	19.2
	5%	WB	13.8	14.1	15.7	17.5	20.2	23.2	25.2	25.6	24.4	22.0	17.8	14.8
		MCDB	16.9	17.6	19.7	21.3	24.2	27.9	29.4	29.9	28.1	25.9	21.3	18.1
	10%	WB	13.0	13.2	15.0	16.8	19.5	22.4	24.5	25.0	23.6	21.2	16.9	14.1
		MCDB	16.0	16.4	18.6	20.1	23.1	26.9	28.8	29.2	27.5	25.3	20.3	17.2
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.5	9.0	9.0	8.9	9.4	9.4	9.5	9.0	9.3	8.4	8.3
		MCDBR	11.0	11.2	12.2	11.9	11.9	12.6	12.0	12.2	10.5	12.2	10.7	10.6
		MCWBR	7.4	6.9	6.8	6.7	6.1	5.8	6.0	6.2	5.6	6.3	6.2	6.6
	5% WB	MCDBR	10.1	10.3	10.7	10.2	10.2	10.5	9.5	9.8	9.0	10.3	9.5	9.3
		MCWBR	7.2	6.9	6.6	6.3	5.9	5.5	5.5	5.9	5.3	6.3	6.2	6.3
Clear-Sky Solar Irradiance	taub	0.346	0.365	0.421	0.458	0.488	0.480	0.526	0.502	0.479	0.431	0.386	0.352	
	taud	2.457	2.396	2.215	2.134	2.083	2.134	2.009	2.078	2.151	2.258	2.352	2.445	
	Ebn at Noon	839	864	840	828	807	811	770	780	775	778	779	803	
	Edh at Noon	85	102	133	152	163	155	174	159	140	115	94	82	
All-Sky Solar Radiation	RadAvg	2.32	3.09	4.37	5.45	6.38	7.37	7.42	6.54	5.00	3.75	2.53	2.10	
	RadStd	0.25	0.33	0.39	0.43	0.45	0.24	0.20	0.21	0.25	0.23	0.18	0.21	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page