

DAR EL BEIDA, Algeria

WMO: 603900

Lat: 36.6897N

Lon: 3.2166E

Elev: 82

StdP: 14.65

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.3	37.4	32.1	26.7	42.3	34.1	28.9	43.7	27.3	56.9	23.6	57.5	1.8	240	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.7	96.0	72.3	92.9	72.5	89.8	72.7	78.3	87.3	77.0	86.0	75.8	84.6	9.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.5	134.1	82.6	74.5	129.2	82.0	73.3	124.1	81.2	41.7	87.5	40.4	86.2	39.3	84.5	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.2	20.0	17.2	DB	31.7	104.8	1.5	4.4	30.7	108.0	29.8	110.6	29.0	113.0	27.9	116.2	(4)
(5)			WB	31.1	80.4	1.5	2.0	30.0	81.9	29.2	83.1	28.3	84.2	27.2	85.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.8	52.4	52.7	56.4	60.0	65.9	72.9	78.4	79.8	74.7	68.9	59.9	54.4	(6)	
	DBStd	10.70	4.27	4.89	4.99	4.22	4.94	4.68	3.90	4.03	4.51	5.33	5.26	4.32	(7)	
	HDD50	57	21	22	5	0	0	0	0	0	0	0	1	8	(8)	
	HDD65	1735	390	345	271	159	46	2	0	0	0	20	171	331	(9)	
	CDD50	5452	97	98	204	300	492	687	881	924	742	586	297	144	(10)	
	CDD65	1654	1	1	5	9	73	239	416	459	292	140	17	2	(11)	
	CDH74	16611	3	13	76	133	685	2263	4518	5065	2578	1144	124	9	(12)	
	CDH80	6597	0	2	18	16	178	783	2034	2341	866	341	18	0	(13)	
(14) Wind	WSAvg	6.1	5.8	6.1	6.1	6.5	6.6	6.8	6.8	6.4	6.1	5.0	5.7	5.4	(14)	
(15) Precipitation	PrecAvg	27.1	3.3	3.0	2.7	2.4	1.7	0.5	0.1	0.2	1.2	2.5	3.9	4.1	(15)	
	PrecMax	46.0	10.0	13.6	8.7	7.7	5.9	2.8	0.9	1.3	6.2	10.0	9.8	9.8	(16)	
	PrecMin	13.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.0	(17)	
	PrecStd	6.1	2.1	2.4	1.8	1.7	1.6	0.6	0.2	0.3	1.3	2.0	2.3	2.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.0	75.2	82.0	82.3	91.5	96.8	100.5	101.8	95.8	94.7	82.5	74.8	(19)	
		MCWB	57.7	59.4	62.2	64.8	68.3	70.0	72.4	73.3	71.3	68.4	64.3	60.8	(20)	
	2%	DB	68.0	69.8	74.9	77.4	84.3	91.3	94.9	95.9	89.9	87.6	77.3	69.9	(21)	
		MCWB	56.2	57.3	60.1	62.2	66.8	70.4	72.9	73.2	72.0	68.2	61.8	58.2	(22)	
	5%	DB	64.8	66.5	71.3	74.5	80.5	87.4	91.5	92.8	87.5	83.3	73.6	66.7	(23)	
		MCWB	55.4	56.3	59.0	61.4	65.8	70.3	72.7	73.8	71.8	67.5	61.4	57.0	(24)	
	10%	DB	62.5	64.0	67.9	71.6	77.2	84.3	89.2	89.8	84.6	80.2	70.6	64.4	(25)	
		MCWB	54.8	55.2	57.7	60.4	65.1	69.7	73.0	74.0	71.2	67.4	60.4	56.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.3	61.6	64.7	67.1	71.5	76.3	79.6	80.3	77.6	74.0	67.1	62.0	(27)	
		MCDB	68.0	70.8	76.8	77.1	83.8	86.5	88.8	89.9	86.7	82.3	75.3	71.1	(28)	
	2%	WB	58.4	59.1	61.9	64.6	69.3	74.1	77.8	78.8	75.7	71.7	64.9	59.9	(29)	
		MCDB	65.4	66.9	71.7	73.8	79.5	84.4	87.4	87.5	84.2	80.4	72.6	67.1	(30)	
	5%	WB	56.8	57.4	60.1	63.0	67.7	72.6	76.5	77.6	74.5	70.1	63.3	58.4	(31)	
		MCDB	63.2	64.3	68.4	71.4	77.1	82.4	85.9	86.2	82.5	78.3	70.5	65.0	(32)	
	10%	WB	55.2	56.1	58.7	61.5	66.4	71.4	75.3	76.4	73.2	68.8	61.6	57.0	(33)	
		MCDB	61.0	62.5	66.1	69.0	75.0	80.5	84.5	84.9	80.8	77.1	68.6	63.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	19.4	20.3	21.4	21.4	21.2	21.6	21.4	20.7	20.0	21.2	19.0	19.3	(35)	
		MCDBR	24.4	25.8	28.0	28.0	27.2	26.8	26.2	25.1	22.8	26.5	24.0	24.4	(36)	
	5% WB	MCWBR	15.4	15.8	15.7	15.2	12.5	11.2	10.5	10.1	10.1	11.7	13.0	15.0	(37)	
		MCWBR	22.0	23.0	24.4	23.4	22.6	21.5	20.0	19.8	18.5	21.3	21.1	21.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.337	0.357	0.414	0.440	0.473	0.481	0.528	0.502	0.471	0.423	0.379	0.343	(40)	
		taud	2.484	2.422	2.238	2.184	2.123	2.117	1.990	2.067	2.164	2.287	2.379	2.479	(41)	
	Ebn at Noon		270	278	269	268	260	257	244	247	248	250	250	259	(42)	
		Edh at Noon	26	31	41	46	49	50	56	51	44	36	29	25	(43)	
(44) All-Sky Solar Radiation	RadAvg		770	1018	1415	1751	2024	2378	2363	2099	1627	1227	827	694	(44)	
	RadStd		82	113	116	142	173	91	57	77	84	82	69	57	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (5 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page