

TIZI-OUZOU, Algeria

WMO: 603950

Lat: 36.7241N

Lon: 4.0183E

Elev: 502

StdP: 14.43

Time Zone: 1.00 (E01)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.2	39.7	33.7	28.9	43.8	35.6	31.1	44.8	28.2	55.1	22.6	57.0	0.3	N/A	0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	101.7	72.3	98.6	71.8	95.6	71.9	77.6	91.7	76.2	89.5	74.9	87.8	7.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.9	128.8	83.2	72.5	122.8	82.2	71.2	117.2	81.6	41.4	92.0	39.9	89.7	38.7	87.6	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.5	18.5	15.3	33.9	108.0	2.9	2.8	31.8	110.0	30.1	111.6	28.4	113.1	26.3	115.2
			33.6	80.3	2.9	1.2	31.5	81.2	29.9	81.9	28.2	82.6	26.2	83.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	52.0	51.9	56.6	61.4	67.7	76.4	83.2	83.0	76.6	70.8	59.8	53.1
	DBStd	12.51	4.57	5.78	5.63	5.36	5.84	6.14	4.34	4.09	5.15	6.23	5.32	4.58
	HDD50	102	29	40	11	1	0	0	0	0	0	0	2	19
	HDD65	1762	402	368	266	133	36	1	0	0	16	170	370	
	CDD50	5992	92	93	215	342	550	792	1031	1023	798	645	296	115
	CDD65	2176	0	1	5	24	122	343	566	558	348	195	13	1
	CDH74	23014	0	15	62	244	1035	3592	6908	6558	3085	1441	72	2
	CDH80	11493	0	1	9	54	346	1745	3913	3568	1311	536	10	0
Wind	WSAvg	3.1	2.0	3.0	3.4	3.4	3.3	4.0	4.4	3.7	3.2	2.3	2.2	1.8
Precipitation	PrecAvg	32.6	5.0	3.8	3.3	3.3	2.4	0.6	0.1	0.2	1.5	2.8	4.2	5.2
	PrecMax	47.7	11.9	9.6	10.2	7.8	8.4	2.0	0.8	0.8	5.8	7.5	9.7	10.5
	PrecMin	17.2	1.3	0.5	0.5	0.4	0.2	0.2	0.0	0.4	0.7	1.0	0.6	
	PrecStd	6.2	2.8	2.3	2.0	1.8	1.9	0.5	0.2	0.3	1.2	1.5	2.0	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.1	75.9	80.2	86.7	94.9	103.0	106.5	106.4	99.4	96.0	81.1	71.9
		MCWB	57.3	59.3	60.3	64.9	71.3	71.4	72.9	73.3	71.4	66.8	63.3	59.3
	2%	DB	65.5	68.1	74.5	79.9	87.3	98.2	102.1	101.2	94.5	90.3	75.4	66.9
		MCWB	55.6	56.8	60.3	64.2	68.5	71.0	72.8	73.1	70.5	67.3	61.0	57.1
	5%	DB	62.5	64.5	70.1	76.1	83.4	93.7	98.7	97.7	90.9	85.9	71.9	63.6
		MCWB	54.4	55.4	58.6	62.7	67.6	70.3	72.0	72.5	70.8	67.0	60.4	55.2
	10%	DB	59.9	61.4	66.5	72.2	79.6	89.7	95.5	94.6	87.5	81.7	69.0	61.0
		MCWB	53.3	53.8	57.6	61.3	66.3	69.8	72.1	72.8	70.2	66.4	59.3	54.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.4	61.1	63.9	68.3	73.4	77.0	79.1	80.4	76.9	73.2	66.4	60.8
		MCDB	66.3	70.5	76.3	79.5	88.3	91.4	94.8	95.4	87.3	82.6	75.9	69.7
	2%	WB	56.6	58.2	61.2	65.7	70.8	74.7	77.4	78.0	74.5	71.0	63.8	58.1
		MCDB	63.4	66.1	71.0	77.1	83.7	90.3	92.5	92.0	85.3	80.8	71.1	64.7
	5%	WB	55.2	56.2	59.4	63.8	68.7	72.9	76.0	76.4	73.2	69.2	62.0	56.4
		MCDB	61.0	62.9	67.8	74.0	80.9	87.5	90.2	88.9	84.5	79.8	68.5	62.0
	10%	WB	53.8	54.5	58.0	61.9	67.0	71.4	74.7	75.1	72.0	67.6	60.5	55.0
		MCDB	58.6	60.4	65.3	70.5	77.7	85.5	88.3	87.2	83.6	78.1	66.8	60.1
Mean Daily Temperature Range	5% DB	MDBR	14.5	14.9	16.8	17.9	19.2	21.9	23.3	22.7	20.3	19.2	15.0	13.6
		MCDBR	18.9	20.4	23.4	26.0	26.1	27.7	28.2	27.7	24.7	24.7	20.3	18.1
		MCWBR	10.9	11.0	11.4	12.7	11.4	9.4	8.8	9.1	8.4	8.7	9.2	9.9
	5% WB	MCDBR	17.3	18.3	20.4	22.9	22.9	23.0	22.1	21.6	19.9	20.4	17.9	15.4
		MCWBR	10.6	10.7	10.8	12.1	11.1	9.5	9.0	9.0	7.9	8.6	9.2	9.1
Clear-Sky Solar Irradiance	taub	0.332	0.350	0.405	0.433	0.464	0.471	0.515	0.488	0.460	0.414	0.371	0.338	
	taud	2.491	2.434	2.258	2.195	2.138	2.141	2.018	2.099	2.188	2.307	2.392	2.487	
	Ebn at Noon	272	280	272	270	262	260	247	251	251	253	253	261	
	Edh at Noon	26	31	40	45	49	49	55	49	43	35	29	25	
All-Sky Solar Radiation	RadAvg	760	1005	1406	1744	2028	2382	2387	2115	1621	1224	823	686	
	RadStd	82	113	124	146	170	89	59	75	88	82	68	63	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page