

TIZI-OUZOU, Algeria

WMO: 603950

Lat: 36.7241N

Lon: 4.0183E

Elev: 153

StdP: 99.50

Time Zone: 1.00 (E01)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.9	4.3	1.0	4.1	6.6	2.0	4.4	7.1	12.6	12.9	10.1	13.9	0.1	N/A	0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	38.7	22.4	37.0	22.1	35.3	22.2	25.3	33.2	24.5	31.9	23.8	31.0	3.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.3	18.4	28.4	22.5	17.5	27.9	21.8	16.7	27.6	78.3	33.3	74.9	32.1	72.1	30.9	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.1	8.3	6.9	DB	1.1	42.2	1.6	1.5	-0.1	43.3	-1.1	44.2	-2.0	45.1	-3.2	46.2
			WB	0.9	26.8	1.6	0.7	-0.3	27.3	-1.2	27.7	-2.1	28.1	-3.2	28.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	11.1	11.1	13.7	16.3	19.9	24.7	28.5	28.3	24.8	21.6	15.4	11.7	(6)
(7)		DBStd	6.95	2.54	3.21	3.13	2.98	3.24	3.41	2.41	2.27	2.86	3.46	2.96	2.54	(7)
(8)		HDD10.0	57	16	22	6	1	0	0	0	0	0	0	1	11	(8)
(9)		HDD18.3	979	223	204	148	74	20	1	0	0	0	9	94	206	(9)
(10)		CDD10.0	3329	51	52	119	190	306	440	573	568	443	358	164	64	(10)
(11)		CDD18.3	1209	0	1	3	13	68	191	314	310	193	108	7	1	(11)
(12)		CDH23.3	12786	0	8	34	136	575	1996	3838	3643	1714	801	40	1	(12)
(13)		CDH26.7	6385	0	1	5	30	192	969	2174	1982	728	298	6	0	(13)
(14)	Wind	WSAvg	1.4	0.9	1.3	1.5	1.5	1.8	2.0	1.7	1.4	1.0	1.0	0.8	(14)	
(15)	Precipitation	PrecAvg	827	127	96	84	84	61	15	3	6	39	70	107	133	(15)
(16)		PrecMax	1212	302	244	259	198	213	51	20	21	147	190	247	266	(16)
(17)		PrecMin	436	32	13	12	11	6	5	0	0	11	19	26	16	(17)
(18)		PrecStd	157	71	59	52	45	47	12	4	7	30	38	52	62	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.6	24.4	26.8	30.4	35.0	39.5	41.4	41.3	37.5	35.6	27.3	22.2	(19)
(20)		MCWB	14.0	15.2	15.7	18.3	21.8	21.9	22.7	22.9	21.9	19.3	17.4	15.2	(20)	
(21)		2%	DB	18.6	20.1	23.6	26.6	30.7	36.8	39.0	38.4	34.7	32.4	24.1	19.4	(21)
(22)		MCWB	13.1	13.8	15.7	17.9	20.3	21.6	22.7	22.8	21.4	19.6	16.1	13.9	(22)	
(23)		5%	DB	16.9	18.1	21.2	24.5	28.6	34.3	37.1	36.5	32.7	29.9	22.2	17.6	(23)
(24)		MCWB	12.4	13.0	14.8	17.0	19.8	21.3	22.2	22.5	21.6	19.4	15.8	12.9	(24)	
(25)		10%	DB	15.5	16.3	19.2	22.4	26.4	32.1	35.3	34.8	30.8	27.6	20.5	16.1	(25)
(26)		MCWB	11.8	12.1	14.2	16.3	19.0	21.0	22.3	22.6	21.2	19.1	15.2	12.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.7	16.2	17.7	20.1	23.0	25.0	26.2	26.9	25.0	22.9	19.1	16.0	(27)
(28)		MCDWB	19.1	21.4	24.6	26.4	31.3	33.0	34.9	35.2	30.7	28.1	24.4	20.9	(28)	
(29)		2%	WB	13.7	14.6	16.2	18.7	21.6	23.7	25.2	25.6	23.6	21.7	17.6	14.5	(29)
(30)		MCDWB	17.4	18.9	21.6	25.1	28.7	32.4	33.6	33.3	29.6	27.1	21.7	18.2	(30)	
(31)		5%	WB	12.9	13.4	15.2	17.7	20.4	22.7	24.5	24.7	22.9	20.7	16.6	13.6	(31)
(32)		MCDWB	16.1	17.2	19.9	23.3	27.2	30.9	32.4	31.6	29.2	26.6	20.3	16.7	(32)	
(33)		10%	WB	12.1	12.5	14.4	16.6	19.5	21.9	23.7	24.0	22.2	19.8	15.8	12.8	(33)
(34)		MCDWB	14.8	15.8	18.5	21.4	25.4	29.7	31.3	30.7	28.7	25.6	19.3	15.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	8.1	8.3	9.3	10.0	10.6	12.1	12.9	12.6	11.3	10.6	8.3	7.6	(35)	
(36)		5% DB	MCDBR	10.5	11.3	13.0	14.4	14.5	15.4	15.6	15.4	13.7	13.7	11.3	10.1	(36)
(37)		MCWBR	6.0	6.1	6.3	7.1	6.4	5.2	4.9	5.1	4.7	4.8	5.1	5.5	(37)	
(38)		5% WB	MCDWB	9.6	10.2	11.3	12.7	12.7	12.8	12.3	12.0	11.0	11.3	9.9	8.5	(38)
(39)		MCWBR	5.9	5.9	6.0	6.7	6.2	5.3	5.0	5.0	4.4	4.8	5.1	5.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.350	0.405	0.433	0.464	0.471	0.515	0.488	0.460	0.414	0.371	0.338	(40)	
(41)		taud	2.491	2.434	2.258	2.195	2.138	2.141	2.018	2.099	2.188	2.307	2.392	2.487	(41)	
(42)		Ebn at Noon	859	883	857	851	827	819	779	792	792	797	798	824	(42)	
(43)		Edh at Noon	82	98	127	143	154	153	172	156	135	110	90	78	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.40	3.17	4.43	5.50	6.39	7.51	7.53	6.67	5.11	3.86	2.60	2.16	(44)	
(45)		RadStd	0.26	0.36	0.39	0.46	0.54	0.28	0.19	0.24	0.28	0.26	0.21	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page