

CONSTANTINE BOUDIAF INTL, Algeria

WMO: 604190

Lat: 36.276N

Lon: 6.620E

Elev: 690

StdP: 93.30

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.2	0.8	-3.1	3.2	4.9	-2.0	3.5	4.7	11.9	9.0	10.6	8.9	1.4	300	0.461

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	39.1	20.1	37.2	20.0	35.3	19.8	22.5	33.0	21.7	32.1	20.9	31.3	5.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	15.6	25.7	18.8	14.8	25.3	17.9	14.0	24.8	69.4	33.2	66.2	32.0	63.6	31.1	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	8.5	7.4	-3.0	42.1	2.0	1.0	-4.4	42.8	-5.6	43.5	-6.7	44.0	-8.1	44.8
			-3.6	24.1	1.9	1.0	-5.0	24.8	-6.1	25.3	-7.2	25.9	-8.6	26.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	7.5	7.9	10.7	13.5	18.1	23.2	26.8	26.5	22.2	18.0	12.0	8.5
	DBStd	7.62	2.59	3.09	3.35	3.35	3.97	4.06	3.17	3.02	3.37	3.45	3.04	2.61
	HDD10.0	265	84	71	31	7	0	0	0	0	0	13	59	
	HDD18.3	1623	336	292	237	151	54	6	0	6	48	191	303	
	CDD10.0	2563	7	12	54	110	252	396	520	512	365	247	73	14
	CDD18.3	878	0	0	1	4	48	152	262	253	121	37	1	0
	CDH23.3	10423	0	1	17	86	619	1897	3327	2969	1119	376	12	1
	CDH26.7	5505	0	0	3	18	246	999	1957	1674	481	126	1	0
Wind	WSAvg	2.6	2.8	3.0	2.8	2.7	2.5	2.6	2.5	2.4	2.3	2.2	2.6	2.6
Precipitation	PrecAvg	503	66	59	57	54	42	18	7	12	35	39	48	68
	PrecMax	868	231	181	157	192	125	91	49	41	109	142	143	328
	PrecMin	253	8	6	0	5	0	0	0	0	0	1	0	0
	PrecStd	140	50	41	33	34	30	19	10	11	26	29	38	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	21.3	25.4	29.0	35.2	40.2	41.3	41.0	36.2	33.1	25.0	19.9
		MCWB	11.4	11.7	14.3	16.0	18.4	19.4	20.2	20.2	19.7	17.9	14.9	12.2
	2%	DB	16.2	18.2	22.1	25.8	32.0	37.3	39.4	38.8	33.9	30.0	22.1	17.0
		MCWB	10.3	11.3	13.2	15.6	17.9	19.3	20.4	20.1	19.6	17.2	13.4	11.0
	5%	DB	14.2	16.0	20.0	23.1	29.2	34.9	37.6	36.8	31.9	27.3	19.9	15.1
		MCWB	9.4	10.3	12.6	14.9	17.6	19.1	20.3	20.2	19.3	17.0	13.1	10.3
	10%	DB	12.4	13.9	17.9	20.8	26.9	32.4	35.5	34.8	29.2	25.0	17.8	13.5
		MCWB	8.5	9.2	11.6	13.8	17.0	18.8	20.0	20.0	18.7	16.1	12.3	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.4	13.2	15.7	18.1	21.0	22.4	23.6	23.6	22.4	20.3	16.5	13.0
		MCDB	17.1	18.5	22.5	25.3	29.8	33.4	35.5	33.7	30.8	27.6	22.3	18.2
	2%	WB	11.0	11.7	14.2	16.5	19.5	21.1	22.4	22.5	21.3	18.8	14.7	11.7
		MCDB	15.2	16.9	20.9	23.3	28.0	32.4	34.2	32.5	29.0	25.6	19.1	15.9
	5%	WB	9.8	10.6	13.0	15.3	18.4	20.1	21.6	21.6	20.4	17.7	13.7	10.7
		MCDB	13.5	15.4	18.8	21.7	27.0	30.9	33.4	31.7	27.9	24.4	18.1	14.5
	10%	WB	8.9	9.5	11.9	14.3	17.3	19.3	20.7	20.9	19.5	16.9	12.7	9.8
		MCDB	12.1	13.4	17.1	20.0	25.6	30.3	32.4	30.9	26.9	23.5	17.0	13.0
Mean Daily Temperature Range	5% DB	MDBR	9.3	10.0	11.3	12.1	13.9	15.2	15.8	15.0	12.8	12.0	10.1	9.3
		MCDBR	12.7	14.1	15.5	16.5	17.4	18.1	18.1	17.6	15.7	15.7	13.9	12.4
		MCWBR	8.0	8.3	8.4	8.5	7.2	6.4	6.5	6.2	5.6	6.4	7.3	7.6
	5% WB	MCDBR	11.8	12.8	14.3	14.5	15.5	16.0	15.9	15.0	13.5	13.2	12.0	11.1
		MCWBR	7.8	7.8	8.2	8.1	7.2	6.6	6.8	6.1	5.4	6.1	6.9	7.1
Clear-Sky Solar Irradiance	taub	0.308	0.328	0.384	0.420	0.451	0.440	0.481	0.461	0.438	0.391	0.345	0.315	
	taud	2.483	2.421	2.239	2.158	2.093	2.150	2.026	2.082	2.165	2.278	2.400	2.479	
	Ebn at Noon	890	910	879	863	839	845	807	815	814	821	832	855	
	Edh at Noon	83	99	130	149	161	152	171	159	138	113	89	78	
All-Sky Solar Radiation	RadAvg	2.42	3.20	4.42	5.48	6.42	7.38	7.44	6.52	5.00	3.82	2.67	2.17	
	RadStd	0.27	0.31	0.37	0.44	0.41	0.25	0.19	0.25	0.24	0.22	0.18	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	+0.39	+0.39	N/A	N/A	N/A	N/A

Nomenclature: See separate page