

BORDJ BOU ARRERIDJ, AlgeriaWMO: **604440**Lat: **36.067N**Lon: **4.667E**Elev: **3140**StdP: **13.10**Time Zone: **1.00 (E01)**Period: **94-15**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.7	32.5	20.6	17.3	57.7	23.8	20.2	51.9	23.5	49.7	21.0	48.0	2.3	20	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.9	99.1	65.5	96.8	65.2	94.5	65.0	70.0	89.1	68.7	88.4	67.5	87.3	9.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.7	102.9	76.5	62.9	96.4	75.3	61.3	91.0	74.5	36.0	89.1	34.9	88.7	33.8	87.4	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 20.4	17.6	15.4		27.2	103.2	3.0	2.0	25.1	104.6	23.3	105.8	21.6	106.9	19.4	108.3	
(5)				27.0	74.3	2.3	1.9	25.4	75.6	24.1	76.7	22.8	77.8	21.2	79.2	(p)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.1	44.0	45.2	51.3	56.1	65.3	75.4	82.4	80.7	71.0	63.5	51.9	45.2	(6)
	DBStd	14.82	5.00	5.91	6.67	6.68	7.90	7.51	5.19	5.12	6.32	6.60	5.90	4.70	(7)
	HDD50	640	193	154	65	18	1	0	0	0	0	2	47	160	(8)
	HDD65	3151	650	556	428	277	96	11	0	0	15	109	395	614	(9)
	CDD50	4690	8	19	104	201	477	761	1006	951	631	419	102	11	(10)
	CDD65	1724	0	0	2	9	106	322	541	486	197	61	0	0	(11)
	CDH74	19738	0	1	13	101	1066	3710	6838	5805	1753	448	3	0	(12)
	CDH80	9914	0	0	1	9	329	1803	3855	3161	645	111	0	0	(13)
(14) Wind	WSAvg	5.4	5.0	5.4	5.5	6.0	5.8	6.0	6.0	5.5	5.4	4.5	4.9	5.0	(14)
(15) Precipitation	PrecAvg	20.0	2.5	2.0	1.8	2.0	1.8	0.7	0.3	0.4	1.8	1.8	2.2	2.6	(15)
	PrecMax	28.5	7.1	4.4	5.0	5.1	4.5	1.7	1.1	1.6	4.8	4.3	4.5	5.4	(16)
	PrecMin	12.0	0.6	0.3	0.3	0.4	0.3	0.0	0.0	0.0	0.7	0.5	0.5	0.4	(17)
	PrecStd	3.5	1.5	1.1	1.1	1.2	1.1	0.5	0.3	0.4	1.0	1.0	0.9	1.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.5	66.6	75.4	81.4	91.9	99.4	102.9	101.7	93.9	87.3	72.2	62.9	(19)
		MCWB	48.4	49.4	53.3	57.5	62.0	64.2	67.2	65.6	65.6	61.5	56.0	49.5	(20)
	2%	DB	58.7	62.3	70.7	77.1	87.4	96.3	100.0	98.3	90.0	83.0	67.9	58.7	(21)
		MCWB	48.0	47.9	52.2	56.1	60.9	64.0	66.3	65.5	63.5	59.8	53.5	48.9	(22)
	5%	DB	55.4	58.8	66.7	73.0	84.1	93.4	97.6	96.1	87.0	79.0	64.5	55.8	(23)
		MCWB	46.6	46.7	50.9	55.0	60.2	63.6	65.6	65.5	63.3	59.0	51.9	47.8	(24)
	10%	DB	52.1	55.4	63.2	69.0	80.5	89.9	95.1	93.7	83.6	75.0	61.6	53.1	(25)
		MCWB	45.0	45.8	49.7	53.4	59.0	62.9	65.3	65.3	62.5	58.2	51.3	46.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.6	52.7	56.2	60.9	67.2	69.7	72.4	72.3	69.6	64.9	59.2	52.5	(27)
		MCDB	59.2	62.5	69.5	75.2	84.6	88.3	90.8	90.5	82.7	78.7	67.0	58.6	(28)
	2%	WB	49.0	50.1	54.0	58.4	64.0	67.8	70.0	70.0	67.2	62.4	56.3	50.4	(29)
		MCDB	56.2	58.4	65.6	72.2	80.4	87.8	90.5	89.0	82.0	75.0	63.2	56.5	(30)
	5%	WB	47.3	48.0	52.4	56.6	62.2	66.2	68.8	68.7	65.7	60.9	54.0	48.7	(31)
		MCDB	54.0	55.8	63.8	69.3	78.3	85.9	90.0	87.8	79.9	73.2	61.4	54.3	(32)
	10%	WB	45.7	46.4	50.8	54.9	60.5	64.8	67.5	67.5	64.4	59.6	52.2	47.3	(33)
		MCDB	51.3	54.2	61.2	66.3	75.6	84.1	89.1	86.5	77.9	71.8	59.8	52.2	(34)
(35) Mean Daily Temperature Range		MDBR	14.1	15.6	17.9	19.4	21.1	22.9	23.9	24.2	20.4	18.2	14.8	13.1	(35)
	5% DB	MCDBR	19.9	21.0	22.8	25.1	24.6	25.1	25.4	26.8	23.8	22.0	18.8	17.2	(36)
		MCWBR	11.1	10.6	9.9	10.8	8.7	8.0	8.2	8.7	7.7	7.8	8.9	9.9	(37)
	5% WB	MCDBR	17.9	18.1	20.8	22.9	23.5	25.3	24.5	24.8	21.0	18.4	16.5	15.1	(38)
		MCWBR	10.8	10.2	10.2	10.9	9.6	9.3	9.2	9.4	8.3	7.5	8.9	9.4	(39)
(40) Clear-Sky Solar Irradiance	taub	0.290	0.309	0.364	0.397	0.432	0.440	0.485	0.454	0.423	0.376	0.330	0.299		(40)
	taud	2.513	2.455	2.282	2.200	2.119	2.108	1.973	2.068	2.171	2.304	2.426	2.508		(41)
	Ebn at Noon	291	296	286	281	271	268	255	261	263	266	271	279		(42)
	Edh at Noon	25	30	39	45	50	50	57	51	44	35	28	24		(43)
(44) All-Sky Solar Radiation	RadAvg	820	1070	1473	1816	2114	2420	2427	2149	1659	1275	890	737		(44)
	RadStd	84	104	116	138	146	77	56	74	87	85	62	68		(45)

Historical Trends

	DBAvg	Heating	
--	-------	---------	--