

SETIF AIN ARNAT, Algeria

WMO: 604450

Lat: 36.178N

Lon: 5.324E

Elev: 3445

StdP: 12.96

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.1	30.1	20.5	17.4	45.0	23.1	19.7	43.2	27.7	42.6	24.5	42.9	6.1	0	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.2	98.3	64.0	95.5	63.5	93.2	63.1	68.0	87.0	66.5	86.1	65.5	85.2	13.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.7	97.0	73.0	61.0	91.0	71.7	59.3	85.7	71.2	34.3	86.7	33.2	86.4	32.3	85.2	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.2	20.1	17.7	DB	23.9	102.3	3.8	2.8	21.2	104.3	18.9	106.0	16.8	107.5	14.1	109.5
			WB	22.7	71.7	3.8	3.5	20.0	74.2	17.8	76.3	15.6	78.2	12.9	80.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.9	42.0	43.1	48.8	54.1	62.7	72.4	79.8	78.5	69.4	61.3	49.9	43.7	
	DBStd	14.59	4.85	6.05	6.57	6.44	7.72	7.52	5.25	5.33	6.15	6.34	5.74	4.70	
	HDD50	861	249	204	101	30	3	0	0	0	0	3	70	201	
	HDD65	3607	712	613	503	331	139	21	0	0	26	150	452	660	
	CDD50	4113	3	11	63	152	396	672	923	884	582	353	68	6	
	CDD65	1384	0	0	1	3	67	243	458	419	158	35	0	0	
	CDH74	16107	0	0	5	57	749	2929	5762	4839	1432	332	2	0	
	CDH80	7882	0	0	0	3	219	1381	3179	2510	513	77	0	0	
Wind	WSAvg	8.0	7.9	8.8	8.7	8.7	8.2	8.2	7.9	7.8	7.5	7.1	8.1	7.3	
Precipitation	PrecAvg	15.1	1.7	1.3	1.4	1.5	1.6	1.0	0.4	0.6	1.5	1.1	1.5	1.7	
	PrecMax	18.3	5.1	4.0	4.0	3.5	4.0	2.9	1.6	1.4	4.7	2.5	4.6	5.2	
	PrecMin	11.8	0.2	0.2	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.0	
	PrecStd	2.1	1.2	0.8	1.0	0.9	1.1	0.8	0.4	0.4	1.2	0.7	1.0	1.3	
	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.5	66.4	73.6	79.1	90.9	98.5	101.8	100.4	92.3	86.2	71.9	62.7
MCWB			48.5	48.6	53.1	56.2	59.9	62.3	64.8	64.8	62.9	60.9	55.9	49.3	
2%		DB	57.6	61.1	68.4	75.2	85.8	95.0	98.8	97.3	89.2	82.1	66.8	58.2	
		MCWB	47.5	48.2	51.1	54.8	59.8	62.4	64.3	64.0	62.9	59.2	53.0	48.0	
5%		DB	54.0	57.4	64.8	71.4	82.1	91.7	96.6	95.0	86.0	77.3	63.3	55.2	
		MCWB	45.7	46.8	49.9	54.2	59.2	61.5	64.0	63.9	62.2	57.9	51.5	47.2	
10%		DB	50.9	53.8	61.3	67.3	78.2	88.1	93.8	91.9	82.4	73.4	60.1	52.2	
		MCWB	44.1	45.0	48.9	53.0	58.0	61.6	63.3	63.5	61.4	57.2	50.5	45.8	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures		0.4%	WB	50.9	53.2	55.5	59.4	64.1	67.7	70.1	69.9	68.6	63.9	58.5	52.0
			MCDB	57.9	60.9	68.1	72.9	80.8	88.7	89.4	88.0	83.7	78.0	66.2	58.5
	2%	WB	48.5	49.7	53.2	57.3	62.2	65.6	67.7	68.1	66.0	61.9	55.3	49.5	
		MCDB	55.6	57.8	64.7	69.8	78.7	85.8	89.3	86.2	80.0	74.7	63.2	55.7	
	5%	WB	46.5	47.6	51.5	55.7	60.7	64.1	66.3	66.6	64.5	60.2	53.2	48.0	
		MCDB	52.7	55.6	62.7	67.7	77.0	84.1	89.1	85.2	77.8	72.1	60.5	53.5	
	10%	WB	44.8	45.8	49.6	54.0	59.2	62.8	65.2	65.6	63.2	58.8	51.5	46.5	
		MCDB	50.1	52.7	59.9	65.1	75.1	82.0	87.9	84.5	76.2	69.4	58.6	51.4	
	Mean Daily Temperature Range	5% DB	MDBR	15.6	16.7	18.8	20.1	22.5	25.0	26.2	24.8	21.7	19.6	16.7	15.3
			MCDBR	22.2	23.2	24.8	26.6	27.1	27.5	27.9	27.4	25.7	25.7	22.1	20.4
MCWBR			14.1	13.1	12.3	12.3	10.4	8.9	8.9	9.0	8.5	10.2	11.8	12.8	
5% WB		MCDBR	20.3	20.6	23.6	23.9	25.2	27.5	27.2	25.8	22.7	21.3	20.1	17.9	
		MCWBR	13.5	12.6	12.8	12.6	10.8	10.5	9.9	9.6	8.4	9.4	11.8	11.8	
Clear-Sky Solar Irradiance	taub	0.292	0.313	0.369	0.403	0.439	0.440	0.487	0.457	0.427	0.378	0.332	0.300		
	taud	2.506	2.440	2.260	2.178	2.093	2.107	1.965	2.053	2.154	2.283	2.415	2.500		
	Ebn at Noon	289	294	284	279	269	268	254	260	261	265	269	278		
	Edh at Noon	25	31	40	46	51	50	58	52	44	36	28	24		
All-Sky Solar Radiation	RadAvg	790	1034	1431	1774	2072	2382	2397	2115	1627	1236	861	709		
	RadStd	84	102	122	137	139	82	58	70	80	81	57	72		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	+0.61	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page