

ARZEW, Algeria

WMO: 604520

Lat: 35.817N

Lon: 0.267W

Elev: 13

StdP: 14.69

Time Zone: 1.00 (E01)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 44.2	(c) 46.4	(d) 33.6	(e) 28.2	(f) 50.5	(g) 36.5	(h) 31.7	(i) 52.5	(j) 28.7	(k) 60.6	(l) 26.8	(m) 59.5	(n) 6.7	(o) 220	(p) 0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.7	(c) 90.6	(d) 70.0	(e) 87.1	(f) 70.7	(g) 84.3	(h) 72.3	(i) 78.3	(j) 82.4	(k) 77.3	(l) 81.5	(m) 76.5	(n) 80.7	(o) 10.7	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.1	141.0	81.5	76.0	136.1	80.6	75.1	131.9	79.9	41.8	82.6	40.7	81.6	39.9	80.9	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 25.4	(b) 22.0	(c) 19.3	(e) 40.2	(f) 100.5	(g) 2.2	(h) 3.8	(i) 38.6	(j) 103.2	(k) 37.3	(l) 105.5	(m) 36.1	(n) 107.6	(o) 34.5	(p) 110.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.6	55.6	56.2	59.6	62.5	67.6	73.6	78.7	79.5	75.2	70.2	62.3	57.7
	DBStd	9.16	3.44	4.21	3.91	3.37	3.42	3.51	3.49	3.09	3.09	3.86	4.51	3.93
	HDD50	8	4	2	1	0	0	0	0	0	0	0	0	1
	HDD65	1153	293	249	170	88	12	0	0	0	0	6	106	229
	CDD50	6080	176	175	300	376	546	709	891	916	756	625	370	240
	CDD65	1751	0	2	4	14	94	259	426	451	306	166	26	3
	CDH74	11178	0	8	9	26	173	1117	3542	4127	1709	412	50	5
	CDH80	2210	0	3	1	2	23	204	822	919	179	51	6	0
Wind	WSAvg	9.2	8.9	9.3	10.4	10.4	9.8	9.1	8.8	8.4	8.7	8.0	9.2	9.0
Precipitation	PrecAvg	14.0	2.0	1.7	1.3	1.3	0.8	0.1	0.0	0.1	0.7	1.3	2.4	2.2
	PrecMax	20.9	4.3	3.8	5.1	5.8	2.3	1.0	0.2	0.6	2.6	5.2	7.6	6.1
	PrecMin	10.2	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.3
	PrecStd	2.8	1.1	0.9	1.1	1.2	0.6	0.2	0.1	0.1	0.6	1.0	1.5	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.0	72.4	74.7	77.3	83.3	89.9	96.3	96.0	88.6	85.6	78.4	73.3
		MCWB	56.9	58.9	59.7	62.3	63.5	66.7	68.3	70.7	70.6	67.2	62.8	59.4
	2%	DB	64.9	67.9	70.6	73.2	78.1	85.0	91.1	90.1	83.8	80.2	74.7	68.4
		MCWB	56.8	57.3	59.6	60.8	64.5	68.6	70.1	71.1	71.1	68.9	62.7	59.0
	5%	DB	63.1	64.7	68.0	70.5	75.4	81.7	87.2	86.7	81.6	77.6	71.8	66.0
		MCWB	56.4	56.8	58.9	60.7	64.5	69.0	70.3	72.7	72.6	68.8	62.5	58.1
	10%	DB	61.4	62.4	65.8	68.5	73.4	79.3	83.9	84.0	80.0	75.9	69.4	63.9
		MCWB	55.6	56.3	58.5	60.3	64.2	69.5	72.2	74.4	72.6	68.5	61.8	57.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.7	60.8	63.1	65.3	70.0	75.9	79.1	80.9	77.4	73.5	68.3	62.3
		MCDB	64.2	66.9	68.2	70.6	75.2	80.9	83.4	85.0	81.5	77.4	74.0	67.8
	2%	WB	58.3	59.3	61.6	63.8	68.4	74.1	77.8	78.9	76.3	72.0	66.5	60.7
		MCDB	62.8	64.6	66.8	69.0	73.3	78.6	82.0	83.0	80.2	76.2	71.1	65.9
	5%	WB	57.3	58.1	60.4	62.9	67.3	73.0	76.7	78.0	75.2	70.9	64.8	59.3
		MCDB	61.9	63.0	65.6	67.7	71.9	77.3	81.1	82.1	79.1	75.3	69.5	64.6
	10%	WB	56.2	57.1	59.4	61.9	66.3	71.9	75.8	77.1	74.3	69.8	62.9	58.1
		MCDB	60.8	61.5	64.3	66.4	70.8	76.2	80.1	81.2	78.3	74.5	68.1	63.4
Mean Daily Temperature Range	5% DB	MDBR	11.1	11.2	10.8	10.3	9.4	8.7	9.2	8.7	9.0	10.3	11.1	10.8
		MCDBR	13.1	13.6	14.6	14.9	13.3	13.5	16.0	14.2	11.3	12.6	14.1	13.1
		MCWBR	8.3	7.9	7.9	8.2	7.0	7.1	8.7	8.7	7.2	7.5	8.3	8.2
	5% WB	MCDBR	11.6	11.4	11.6	11.0	9.2	8.0	8.0	8.2	8.4	9.5	11.0	11.4
		MCWBR	8.3	7.8	7.6	7.4	6.5	6.0	6.6	6.7	6.6	7.3	7.9	8.1
Clear-Sky Solar Irradiance	taub		0.332	0.358	0.418	0.434	0.466	0.490	0.538	0.512	0.472	0.421	0.374	0.340
	taud		2.487	2.411	2.214	2.195	2.130	2.071	1.945	2.021	2.144	2.279	2.394	2.478
	Ebn at Noon		274	279	269	270	262	255	242	245	249	252	255	263
	Edh at Noon		27	32	43	46	49	52	59	54	45	36	29	25
All-Sky Solar Radiation	RadAvg		859	1129	1518	1845	2128	2373	2325	2095	1675	1285	899	769
	RadStd		73	109	101	134	147	86	56	72	65	86	75	53

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page