

MOSTAGANEM, Algeria

WMO: 604570

Lat: 35.883N

Lon: 0.117E

Elev: 453

StdP: 14.46

Time Zone: 1.00 (E01)

Period: 01-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.0	38.3	31.2	25.9	45.6	33.5	28.6	45.4	22.9	56.7	20.4	54.7	0.4	40	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.2	95.6	71.1	91.7	70.3	88.9	70.5	77.0	84.3	75.8	83.2	74.8	82.1	7.2	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.1	134.0	80.5	73.8	128.2	79.4	72.7	123.4	78.7	40.7	84.4	39.6	83.4	38.6	82.2	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	15.8	13.7	DB	32.3	104.6	2.1	3.8	30.8	107.4	29.6	109.7	28.4	111.8	26.9	114.6	(4)
(5)			WB	31.7	79.4	2.0	2.4	30.3	81.1	29.1	82.4	28.0	83.8	26.6	85.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.4	51.8	52.8	56.0	60.1	66.0	73.1	78.6	79.0	73.7	68.3	58.9	53.6		
	DBStd	10.67	4.14	5.02	4.72	4.42	4.67	4.88	3.85	3.87	4.03	4.71	5.19	4.45		
	HDD50	75	27	23	9	1	0	0	0	0	0	0	1	14		
	HDD65	1799	408	341	281	157	42	2	0	0	0	19	195	354		
	CDD50	5330	84	102	195	304	495	693	885	899	712	566	269	126		
	CDD65	1580	0	1	2	10	72	245	420	434	262	120	13	1		
	CDH74	13769	0	7	27	113	555	1965	4039	4374	1912	705	66	6		
	CDH80	5054	0	2	4	20	144	693	1682	1804	522	174	9	0		
(14) Wind	WSAvg	4.5	4.3	5.4	5.0	5.4	5.3	5.0	4.2	4.1	4.0	3.5	4.0	3.9		
(15) Precipitation	PrecAvg	16.0	2.4	1.9	1.6	1.5	1.0	0.1	0.0	0.1	0.8	1.5	2.8	2.3		
	PrecMax	22.2	4.6	4.4	5.5	3.6	3.2	0.9	0.2	1.1	4.1	3.7	6.9	7.0		
	PrecMin	10.8	0.5	0.0	0.3	0.0	0.1	0.0	0.0	0.0	0.1	0.2	0.4	0.4		
	PrecStd	3.1	1.1	1.1	1.1	1.1	0.8	0.2	0.1	0.2	0.8	0.8	1.5	1.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.6	72.0	77.6	82.5	89.4	97.5	102.1	100.7	93.7	90.3	80.5	72.7		
		MCWB	56.3	57.5	60.0	62.5	66.7	71.3	71.3	71.1	70.2	66.6	61.8	59.4		
	2%	DB	64.8	67.3	71.6	77.1	83.7	91.3	95.5	95.2	88.7	84.9	75.0	67.5		
		MCWB	55.5	56.4	59.3	62.1	64.9	69.0	70.7	72.1	70.3	66.8	61.2	57.0		
	5%	DB	62.2	64.2	68.2	73.0	80.0	87.2	91.2	91.3	85.3	80.6	71.2	64.3		
		MCWB	55.0	55.6	58.0	60.4	64.2	68.1	70.2	71.3	69.9	67.0	61.0	56.0		
	10%	DB	60.2	61.6	65.4	69.7	76.4	83.7	88.2	88.3	82.5	77.4	68.0	62.0		
		MCWB	54.2	54.7	57.3	59.6	63.4	67.5	70.9	71.7	69.9	66.7	59.6	55.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.0	60.3	63.0	65.4	70.6	76.1	78.0	79.4	76.0	72.6	67.1	61.1		
		MCDB	63.5	68.6	72.7	75.1	83.5	87.5	85.4	87.3	83.1	79.0	73.4	68.7		
	2%	WB	57.3	58.3	60.9	63.6	68.2	73.4	76.5	77.6	74.4	70.9	64.3	58.9		
		MCDB	62.4	64.4	68.6	72.4	77.8	82.9	84.0	84.6	80.8	77.2	69.8	65.0		
	5%	WB	56.0	56.9	59.5	62.2	66.6	71.8	75.5	76.4	73.3	69.4	62.4	57.3		
		MCDB	61.0	62.4	66.0	70.1	75.2	80.1	83.1	83.2	79.9	76.0	68.3	62.7		
	10%	WB	54.7	55.5	58.1	60.8	65.1	70.5	74.5	75.3	72.3	68.1	60.8	55.9		
		MCDB	59.5	60.6	63.9	67.3	72.9	78.4	82.0	82.4	79.0	75.1	66.3	61.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.8	16.0	17.0	17.3	17.1	18.5	18.3	18.2	17.6	18.1	16.4	16.1		
		MCDBR	20.3	19.6	22.9	25.0	26.0	26.3	25.2	24.6	22.4	23.5	21.4	19.4		
		MCWBR	12.6	11.0	12.6	12.4	11.3	9.7	8.6	9.0	9.4	10.3	11.3	11.4		
	5% WB	MCDBR	17.5	16.5	19.2	19.3	19.7	19.3	17.8	16.6	17.1	17.6	17.3	17.0		
		MCWBR	11.9	10.5	11.9	10.8	9.6	8.3	7.7	7.9	8.5	9.6	10.8	11.3		
(40) Clear-Sky Solar Irradiance	taub		0.323	0.347	0.404	0.420	0.451	0.471	0.518	0.491	0.455	0.407	0.363	0.331		
	taud		2.498	2.429	2.247	2.224	2.162	2.113	1.980	2.063	2.177	2.308	2.415	2.493		
	Ebn at Noon		278	282	273	274	266	260	247	251	254	257	259	267		
	Edh at Noon		26	31	41	44	48	50	57	51	43	35	28	25		
(44) All-Sky Solar Radiation	RadAvg		851	1118	1511	1838	2120	2380	2338	2105	1671	1287	892	759		
	RadStd		77	110	103	140	150	87	51	77	70	87	73	53		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page