

ORAN TAFARAQUI, Algeria

WMO: 604592

Lat: 35.533N

Lon: 0.533W

Elev: 377

StdP: 14.50

Time Zone: 1.00 (E01)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.2	37.8	30.0	24.5	48.3	33.5	28.4	47.4	41.1	53.9	33.1	57.4	2.0	160	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.3	99.0	72.6	96.3	72.3	93.5	72.1	79.0	89.5	77.6	87.9	76.3	86.4	12.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.6	140.6	83.1	75.1	133.6	81.7	73.6	126.8	80.9	42.6	89.8	41.2	87.9	40.0	86.8	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.0	25.9	22.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	30.5	82.5	3.7	2.0	27.8	83.9	25.6	85.1	23.5	86.2	20.8	87.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	51.1	53.2	57.6	61.9	68.7	75.8	81.9	82.0	76.1	69.6	59.0	54.9
	DBStd	11.60	4.20	4.89	4.48	4.85	4.69	4.59	3.44	3.71	4.24	4.76	4.99	4.73
	HDD50	70	37	19	4	0	0	0	0	0	0	0	0	10
	HDD65	1646	429	333	232	117	16	0	0	0	12	191	316	
	CDD50	5935	72	108	240	357	579	775	990	992	783	607	271	161
	CDD65	2037	0	1	3	24	130	325	525	527	333	154	13	2
	CDH74	20618	0	7	98	301	1114	3197	5884	5798	2928	1181	91	19
	CDH80	9596	0	2	20	64	335	1465	3143	2986	1205	359	14	3
Wind	WSAvg	9.4	9.0	10.2	9.9	10.1	10.3	10.2	10.3	9.3	8.5	7.8	9.8	8.0
Precipitation	PrecAvg	14.4	1.8	1.7	1.6	1.2	1.0	0.2	0.0	0.1	0.6	1.3	2.0	2.2
	PrecMax	24.8	5.7	5.5	5.0	4.5	5.8	1.4	1.1	0.8	2.8	6.7	7.2	7.5
	PrecMin	6.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.0	1.3	1.2	1.3	0.9	1.1	0.3	0.2	0.2	0.6	1.3	1.5	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.0	73.1	82.3	86.0	93.6	100.1	104.1	103.4	97.0	92.3	82.5	75.9
		MCWB	57.3	57.5	66.6	64.8	68.9	71.1	74.1	73.6	71.3	65.9	61.7	62.6
	2%	DB	65.4	68.9	75.8	81.0	87.9	95.1	98.9	98.9	92.1	88.0	76.4	69.7
		MCWB	56.0	57.4	60.4	63.6	67.7	71.0	73.0	72.8	71.1	68.6	59.7	59.1
	5%	DB	62.6	66.1	71.8	77.2	83.8	91.5	96.2	95.7	89.6	83.9	72.4	66.3
		MCWB	55.0	56.7	59.8	62.2	66.4	70.2	72.4	73.7	71.6	67.4	59.5	58.0
	10%	DB	60.2	62.9	68.3	73.5	80.6	89.0	93.4	93.0	86.6	80.7	69.2	63.4
		MCWB	54.8	56.0	58.6	60.9	65.2	70.2	72.2	73.5	70.8	67.5	59.2	57.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.2	62.2	67.1	67.6	75.0	77.4	80.7	81.6	78.6	74.3	66.4	63.5
		MCDB	64.7	67.9	74.2	78.9	88.7	88.7	92.8	91.9	85.8	86.8	72.4	73.1
	2%	WB	58.2	59.7	63.4	65.3	71.2	75.1	78.7	79.3	76.3	71.7	64.0	61.0
		MCDB	62.3	65.1	71.3	75.5	81.1	87.6	91.5	88.5	84.8	80.7	70.4	66.4
	5%	WB	56.7	58.0	61.5	63.8	68.8	73.5	77.4	77.9	74.8	70.3	62.4	59.4
		MCDB	60.8	63.3	69.0	73.1	78.3	85.6	89.1	87.2	84.2	78.2	69.1	64.4
	10%	WB	55.3	56.6	59.7	62.4	67.1	72.1	76.0	76.5	73.1	69.0	60.7	57.9
		MCDB	59.8	61.8	66.4	70.9	75.6	82.8	86.6	86.0	81.6	76.4	66.7	62.5
Mean Daily Temperature Range	5% DB	MDBR	18.5	19.3	21.2	22.4	21.9	22.9	23.5	22.3	21.6	22.1	19.5	17.5
		MCDBR	24.1	24.0	29.0	28.8	29.6	28.7	29.0	27.4	26.1	28.0	25.8	21.9
		MCWBR	15.9	15.2	16.3	13.7	13.1	11.1	11.1	10.8	11.9	12.9	13.9	13.5
	5% WB	MCDBR	19.1	20.6	24.9	24.9	23.8	23.4	23.0	21.9	20.9	22.3	19.6	19.7
		MCWBR	13.9	14.2	16.0	13.0	11.9	10.4	10.1	10.4	10.4	12.5	12.4	13.6
Clear-Sky Solar Irradiance	taub	0.326	0.353	0.416	0.432	0.466	0.493	0.543	0.516	0.473	0.419	0.369	0.335	
	taud	2.478	2.397	2.191	2.169	2.099	2.029	1.898	1.976	2.105	2.250	2.382	2.471	
	Ebn at Noon	277	280	270	271	262	254	240	245	249	253	257	266	
	Edh at Noon	27	33	43	47	51	55	62	56	47	37	30	26	
All-Sky Solar Radiation	RadAvg	862	1124	1511	1823	2110	2349	2298	2069	1659	1278	898	776	
	RadStd	73	112	97	137	138	82	58	64	62	84	74	55	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page