

ORAN TAFARAOU, Algeria

WMO: 604592

Lat: 35.533N

Lon: 0.533W

Elev: 115

StdP: 99.95

Time Zone: 1.00 (E01)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.8	3.2	-1.1	3.5	9.0	0.8	4.1	8.5	18.4	12.2	14.8	14.1	0.9	160	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.4	37.2	22.6	35.7	22.4	34.1	22.3	26.1	31.9	25.3	31.0	24.6	30.2	5.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.1	28.4	23.9	19.1	27.6	23.1	18.1	27.2	81.3	32.1	78.0	31.1	75.1	30.4	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
13.4	11.6	10.1	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	-0.9	28.1	2.1	1.1	-2.3	28.9	-3.6	29.5	-4.7	30.1	-6.2	30.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	10.6	11.8	14.2	16.6	20.4	24.4	27.7	27.8	24.5	20.9	15.0	12.7
	DBStd	6.45	2.33	2.72	2.49	2.69	2.61	2.55	1.91	2.06	2.36	2.65	2.77	2.63
	HDD10.0	39	21	11	2	0	0	0	0	0	0	0	0	6
	HDD18.3	914	238	185	129	65	9	0	0	0	0	7	106	176
	CDD10.0	3297	40	60	133	198	322	431	550	551	435	337	151	89
	CDD18.3	1132	0	1	2	13	72	181	292	293	185	86	7	1
	CDH23.3	11454	0	4	54	167	619	1776	3269	3221	1627	656	51	11
CDH26.7	5331	0	1	11	36	186	814	1746	1659	669	199	8	2	
Wind	WSAvg	4.2	4.0	4.6	4.4	4.5	4.6	4.6	4.6	4.2	3.8	3.5	4.4	3.6
Precipitation	PrecAvg	366	46	44	41	31	26	6	1	2	15	33	51	56
	PrecMax	631	145	140	126	114	148	36	29	20	70	171	183	190
	PrecMin	172	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	101	33	31	33	24	29	8	4	15	34	39	49	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.1	22.8	27.9	30.0	34.2	37.8	40.1	39.7	36.1	33.5	28.1	24.4
		MCWB	14.1	14.2	19.2	18.2	20.5	21.7	23.4	23.1	21.8	18.8	16.5	17.0
	2%	DB	18.6	20.5	24.3	27.2	31.0	35.1	37.2	37.2	33.4	31.1	24.6	20.9
		MCWB	13.4	14.1	15.8	17.6	19.8	21.7	22.8	22.7	21.7	20.3	15.4	15.1
	5%	DB	17.0	18.9	22.1	25.1	28.8	33.1	35.7	35.4	32.0	28.8	22.4	19.1
		MCWB	12.8	13.7	15.4	16.8	19.1	21.2	22.4	23.1	22.0	19.6	15.3	14.4
	10%	DB	15.6	17.2	20.2	23.1	27.0	31.7	34.1	33.9	30.3	27.0	20.7	17.4
		MCWB	12.7	13.3	14.8	16.0	18.4	21.2	22.4	23.1	21.5	19.7	15.1	13.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	16.8	19.5	19.8	23.9	25.2	27.1	27.5	25.9	23.5	19.1	17.5
		MCDB	18.2	19.9	23.5	26.1	31.5	31.5	33.8	33.3	29.9	30.5	22.5	22.8
	2%	WB	14.6	15.4	17.5	18.5	21.8	23.9	25.9	26.3	24.6	22.1	17.8	16.1
		MCDB	16.8	18.4	21.8	24.2	27.3	30.9	33.1	31.4	29.3	27.1	21.3	19.1
	5%	WB	13.7	14.5	16.4	17.7	20.5	23.1	25.2	25.5	23.8	21.3	16.9	15.2
		MCDB	16.0	17.4	20.6	22.8	25.7	29.8	31.7	30.7	29.0	25.7	20.6	18.0
	10%	WB	13.0	13.7	15.4	16.9	19.5	22.3	24.5	24.7	22.9	20.5	15.9	14.4
		MCDB	15.4	16.6	19.1	21.6	24.2	28.2	30.3	30.0	27.6	24.6	19.3	17.0
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.7	11.8	12.5	12.2	12.7	13.0	12.4	12.0	12.3	10.8	9.7
		MCDBR	13.4	13.4	16.1	16.0	16.4	16.0	16.1	15.2	14.5	15.6	14.3	12.2
		MCWBR	8.9	8.4	9.0	7.6	7.3	6.2	6.2	6.0	6.6	7.2	7.7	7.5
	5% WB	MCDBR	10.6	11.4	13.8	13.9	13.2	13.0	12.8	12.2	11.6	12.4	10.9	11.0
		MCWBR	7.7	7.9	8.9	7.2	6.6	5.8	5.6	5.8	5.8	6.9	6.9	7.5
Clear-Sky Solar Irradiance	taub		0.326	0.353	0.416	0.432	0.466	0.493	0.543	0.516	0.473	0.419	0.369	0.335
	taud		2.478	2.397	2.191	2.169	2.099	2.029	1.898	1.976	2.105	2.250	2.382	2.471
	Ebn at Noon		874	884	850	854	827	802	758	771	784	797	810	837
	Edh at Noon		85	103	137	147	161	172	195	177	148	118	93	81
All-Sky Solar Radiation	RadAvg		2.72	3.54	4.76	5.75	6.65	7.41	7.24	6.52	5.23	4.03	2.83	2.45
	RadStd		0.23	0.35	0.30	0.43	0.44	0.26	0.18	0.20	0.19	0.27	0.23	0.17

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.22	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page