

TEBESSA, Algeria

WMO: 604750

Lat: 35.432N

Lon: 8.121E

Elev: 2661

StdP: 13.34

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.2	(c) 32.3	(d) 20.9	(e) 17.3	(f) 52.4	(g) 23.8	(h) 19.9	(i) 49.2	(j) 32.3	(k) 45.8	(l) 29.0	(m) 46.9	(n) 3.2	(o) 300	(p) 0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.9	102.3	66.9	99.7	66.4	96.8	66.1	72.0	92.2	70.2	89.7	69.0	88.1	13.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	107.1	78.4	64.6	100.5	76.6	62.9	94.8	75.6	37.5	91.9	35.9	90.3	34.7	88.1	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 27.4	(b) 23.5	(c) 20.8	(e) 26.1	(f) 106.1	(g) 2.3	(h) 1.7	(i) 24.5	(j) 107.4	(k) 23.1	(l) 108.4	(m) 21.9	(n) 109.4	(o) 20.2	(p) 110.6		
			DB	WB	24.7	74.9	2.2	3.1	23.1	77.1	21.8	79.0	20.6	80.7	19.0	83.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	45.2	46.3	52.0	57.9	66.7	75.3	81.5	80.3	72.2	64.4	53.8	47.0		
	DBStd	14.16	4.97	5.75	6.82	6.72	7.18	7.00	5.38	5.19	6.02	6.40	5.80	4.83		
	HDD50	505	164	130	57	10	0	0	0	0	0	0	26	118		
	HDD65	2845	614	524	408	230	67	6	0	0	9	89	339	559		
	CDD50	4872	15	26	118	247	517	760	975	939	665	448	139	23		
	CDD65	1738	0	0	3	17	119	316	510	474	225	72	2	0		
	CDH74	22123	0	6	64	299	1594	4205	6995	5935	2267	728	29	1		
	CDH80	11848	0	1	9	63	638	2271	4227	3427	982	227	3	0		
(14) Wind	WSAvg	7.3	7.1	8.5	8.6	8.8	8.0	7.4	7.1	6.5	6.3	5.9	6.8	7.1		
(15) Precipitation	PrecAvg	15.2	1.2	0.8	1.5	1.5	1.4	1.1	0.6	0.9	1.7	1.5	1.3	1.1		
	PrecMax	23.2	3.9	2.9	5.5	4.4	3.8	3.6	2.3	2.8	5.9	3.7	4.6	3.0		
	PrecMin	11.3	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0		
	PrecStd	3.0	0.9	0.8	1.1	1.1	0.9	0.9	0.6	0.8	1.2	1.0	1.1	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.2	72.8	80.5	86.0	96.6	102.6	105.9	104.3	97.0	90.7	77.4	69.6		
		MCWB	51.3	52.4	55.9	60.4	62.8	65.9	69.0	67.9	66.3	64.4	57.8	53.7		
	2%	DB	63.3	67.0	74.9	81.0	90.7	99.0	103.0	101.3	93.1	86.0	72.7	63.7		
		MCWB	49.0	50.5	53.9	57.4	61.7	65.6	67.4	66.9	66.3	62.2	55.6	50.5		
	5%	DB	59.2	62.7	70.2	77.2	86.4	95.9	100.4	98.6	89.7	82.0	68.9	60.5		
		MCWB	47.8	49.0	52.7	56.5	61.4	64.9	66.6	66.5	65.5	61.3	54.6	49.4		
	10%	DB	55.5	58.8	66.4	73.3	82.8	92.2	97.2	95.3	86.0	77.4	65.2	57.1		
		MCWB	46.2	47.4	51.6	55.4	60.4	64.2	66.4	66.7	64.6	59.8	53.4	48.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	56.2	59.2	62.7	68.0	70.9	75.2	73.8	71.9	67.5	61.9	55.3		
		MCDB	63.3	66.3	72.7	78.3	85.6	92.7	96.1	92.6	87.6	83.9	72.0	65.2		
	2%	WB	50.9	52.5	56.6	60.3	65.5	68.9	72.5	71.6	69.7	65.0	58.5	52.3		
		MCDB	60.5	63.7	69.8	75.0	83.8	90.9	94.2	91.6	83.9	79.0	67.1	60.7		
	5%	WB	48.6	49.7	54.5	58.5	63.5	67.4	70.4	70.0	68.1	63.5	56.4	50.5		
		MCDB	57.0	60.4	67.1	72.6	80.4	88.9	91.7	88.9	82.7	76.4	64.7	58.2		
	10%	WB	46.9	47.8	52.5	56.6	61.9	65.8	68.7	68.7	66.6	61.9	54.7	48.9		
		MCDB	54.1	57.3	64.4	69.8	78.0	86.5	89.7	87.4	80.2	73.5	63.0	55.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.2	19.3	21.8	23.1	25.6	27.4	28.9	27.4	23.5	21.7	19.3	17.8		
		MCDBR	26.3	27.5	29.0	29.8	30.1	30.8	31.7	31.0	28.3	27.3	25.6	25.2		
		MCWBR	15.2	14.5	13.7	12.6	11.0	10.1	10.2	9.8	9.7	10.7	12.9	14.7		
	5% WB	MCDBR	23.6	24.6	26.0	26.6	28.1	29.6	30.3	28.4	25.2	23.8	21.3	21.3		
		MCWBR	14.8	14.2	13.7	13.0	12.1	11.3	11.8	10.5	10.0	10.8	12.0	13.4		
(40) Clear-Sky Solar Irradiance	taub		0.297	0.318	0.388	0.433	0.470	0.451	0.486	0.468	0.445	0.396	0.341	0.305		
	taud		2.456	2.390	2.168	2.059	1.983	2.063	1.975	2.015	2.086	2.200	2.354	2.450		
	Ebn at Noon		288	293	278	271	261	265	255	257	256	260	267	277		
	Edh at Noon		27	33	44	52	57	53	57	54	48	39	30	26		
(44) All-Sky Solar Radiation	RadAvg		863	1123	1496	1850	2110	2375	2388	2121	1648	1279	948	775		
	RadStd		74	78	105	121	108	106	75	100	78	61	57	65		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.55	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page