

MASCARA MATEMORE, AlgeriaWMO: **605060**Lat: **35.330N**Lon: **0.210E**Elev: **476**StdP: **95.74**Time Zone: **1.00 (E01)**Period: **88-08**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.8	0.6	-5.9	2.4	11.0	-4.0	2.9	10.7	13.3	15.0	11.6	13.2	0.0	250	0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.6	38.7	20.1	36.7	20.2	35.0	19.8	22.9	32.4	22.0	31.4	21.3	30.8	4.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.2	15.8	26.4	19.2	14.8	26.0	18.2	13.9	25.3	69.8	32.3	66.6	31.0	63.8	30.9	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.1	7.8	-3.2	41.6	1.2	1.6	-4.1	42.8	-4.7	43.7	-5.4	44.6	-6.2	45.7		
(5)			-3.7	24.7	1.1	0.9	-4.6	25.3	-5.2	25.8	-5.8	26.3	-6.7	27.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	9.0	9.7	12.3	13.8	18.3	23.0	26.4	26.8	22.5	17.9	13.2	10.0
	DBStd	6.93	2.70	2.47	3.00	2.73	3.69	3.34	2.88	2.76	3.17	3.24	3.27	2.93
	HDD10.0	141	52	32	11	2	0	0	0	0	0	0	9	35
	HDD18.3	1378	291	242	190	139	46	3	0	0	5	48	157	257
	CDD10.0	2674	21	23	81	116	256	389	509	519	376	245	105	36
	CDD18.3	867	0	0	2	2	43	142	251	261	130	34	2	0
	CDH23.3	10864	0	2	48	83	594	1734	3296	3422	1329	329	24	3
	CDH26.7	5567	0	0	7	11	209	848	1886	1963	556	86	1	0
Wind	WSAvg	2.4	2.2	2.0	2.5	3.0	2.7	2.7	2.5	2.4	2.3	2.0	2.2	2.2
Precipitation	PrecAvg	345	42	39	36	41	27	10	3	7	19	33	51	38
	PrecMax	539	97	107	164	133	90	57	15	40	49	109	142	87
	PrecMin	200	0	0	0	0	1	0	0	0	0	1	8	0
	PrecStd	84	27	24	34	31	20	15	4	10	15	24	29	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.0	23.2	27.1	28.2	35.3	38.7	41.2	40.4	35.7	31.7	26.0	22.1
		MCWB	11.3	11.8	14.5	14.7	20.0	19.8	19.8	20.3	19.7	16.6	14.5	11.6
	2%	DB	18.3	20.6	24.5	25.8	31.1	36.1	39.0	38.6	33.6	29.1	23.6	19.2
		MCWB	10.0	10.8	13.4	13.7	17.2	19.6	19.9	20.3	18.9	16.4	13.9	11.6
	5%	DB	16.3	18.5	22.2	23.7	28.9	33.9	36.7	36.7	31.9	26.9	21.6	17.4
		MCWB	9.6	10.5	12.3	13.4	16.3	19.0	20.0	20.5	18.6	16.2	13.5	11.3
	10%	DB	14.6	16.5	19.9	21.6	26.6	31.4	34.8	35.1	30.0	24.9	19.6	15.6
		MCWB	9.1	10.0	11.8	12.8	15.9	18.0	19.8	20.1	18.9	16.0	13.0	10.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.1	13.9	16.2	16.6	20.1	22.7	23.3	24.7	22.7	19.6	16.6	14.7
		MCDB	16.8	20.3	23.6	24.4	31.8	34.2	33.9	34.5	29.2	25.2	21.4	18.3
	2%	WB	11.7	12.3	14.6	15.3	18.5	21.1	22.4	23.3	21.6	18.5	15.6	13.2
		MCDB	15.4	17.2	21.9	22.8	28.3	31.6	33.2	32.6	28.2	24.4	20.9	16.5
	5%	WB	10.7	11.3	13.3	14.4	17.6	20.0	21.5	22.4	20.7	17.7	14.7	12.2
		MCDB	14.7	16.0	19.8	21.1	25.9	29.8	32.2	31.5	27.5	23.5	19.4	15.8
	10%	WB	9.8	10.5	12.4	13.5	16.7	19.0	20.8	21.6	19.9	17.0	13.8	11.3
		MCDB	13.6	15.4	18.2	19.5	24.3	28.6	31.1	30.9	26.9	22.8	18.0	14.8
Mean Daily Temperature Range	5% DB	MDBR	11.3	12.8	13.1	13.4	13.7	14.7	15.7	15.6	13.5	12.4	11.1	10.8
		MCDBR	14.4	18.1	18.4	18.1	17.6	18.6	18.6	18.0	16.4	15.8	14.8	13.6
		MCWBR	7.8	9.6	8.8	8.2	6.8	7.0	6.8	6.7	6.3	6.2	7.1	7.4
	5% WB	MCDBR	11.3	14.0	15.0	14.9	14.7	15.8	15.8	14.8	13.3	11.9	11.5	10.4
		MCWBR	6.9	8.3	8.3	7.7	6.5	6.7	6.9	7.2	6.0	5.5	6.4	6.6
Clear-Sky Solar Irradiance	taub	0.306	0.334	0.396	0.417	0.450	0.474	0.528	0.495	0.455	0.400	0.351	0.316	
	taud	2.484	2.405	2.200	2.165	2.095	2.031	1.885	1.977	2.095	2.244	2.386	2.479	
	Ebn at Noon	899	907	869	869	841	818	770	788	800	816	832	863	
	Edh at Noon	84	102	136	148	161	172	198	177	149	118	92	80	
All-Sky Solar Radiation	RadAvg	2.75	3.58	4.83	5.84	6.73	7.60	7.50	6.77	5.36	4.18	2.91	2.47	
	RadStd	0.27	0.38	0.31	0.48	0.47	0.26	0.15	0.24	0.27	0.28	0.23	0.20	

Historical Trends

	DBAvg
--	-------