

TIARET BOU CHEKIF, Algeria

WMO: 605110

Lat: 35.341N

Lon: 1.463E

Elev: 3245

StdP: 13.05

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.2	29.9	19.7	16.6	48.6	23.0	19.5	44.9	42.7	45.9	38.2	45.7	3.2	240	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.5	100.2	65.4	97.6	65.1	95.1	64.7	70.2	90.0	68.6	88.5	67.2	87.1	13.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.7	103.1	76.9	62.7	96.3	75.1	60.9	90.2	74.0	36.3	89.7	34.8	88.2	33.6	86.8	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
32.3	27.4	23.2	DB	22.9	104.5	3.7	2.2	20.3	106.1	18.1	107.4	16.0	108.7	13.3	110.3
			WB	21.9	74.5	3.7	3.4	19.2	77.0	17.1	78.9	15.0	80.8	12.3	83.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	59.6	43.4	44.6	49.5	53.9	62.4	72.5	80.0	79.1	70.2	62.3	51.0	45.3	(6)
(7)		DBStd	14.23	4.95	5.76	5.99	6.21	7.61	7.14	5.12	4.81	6.03	6.48	6.21	4.91	(7)
(8)		HDD50	711	210	166	80	29	3	0	0	0	2	61	160		(8)
(9)		HDD65	3397	669	572	479	337	142	17	0	19	129	422	611		(9)
(10)		CDD50	4221	6	14	66	144	387	676	930	903	607	385	89	14	(10)
(11)		CDD65	1434	0	0	0	3	61	243	465	438	176	47	1	0	(11)
(12)		CDH74	19326	0	1	18	124	1030	3426	6459	5745	1959	552	12	0	(12)
(13)		CDH80	10194	0	0	1	14	382	1762	3834	3249	806	146	0	0	(13)
(14)	Wind	WSAvg	8.8	10.5	10.4	9.9	9.4	8.2	7.8	7.4	7.3	8.0	10.0	9.6	(14)	
(15)	Precipitation	PrecAvg	14.6	1.6	1.7	1.6	1.6	1.3	0.4	0.2	0.4	1.2	1.3	1.8	1.5	(15)
(16)		PrecMax	20.5	3.7	4.8	4.8	4.7	2.8	2.0	1.0	1.9	4.1	3.1	4.3	3.1	(16)
(17)		PrecMin	8.4	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.2	0.0	0.0	(17)
(18)		PrecStd	3.5	1.0	1.1	1.2	1.2	0.8	0.5	0.2	0.4	1.1	0.9	1.0	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.2	68.7	76.4	82.1	93.5	100.6	103.8	102.0	94.8	88.7	75.2	67.0	(19)
(20)		MCWB	49.6	51.7	56.3	58.4	62.6	64.7	65.9	66.0	63.3	60.8	57.1	51.8	(20)	
(21)		2%	DB	61.1	63.9	70.9	77.4	88.4	96.8	100.7	99.2	91.4	84.0	70.2	62.1	(21)
(22)		MCWB	47.8	49.3	54.0	57.0	61.6	64.9	65.7	65.2	64.2	60.0	53.7	50.4	(22)	
(23)		5%	DB	57.1	59.7	66.4	73.5	84.3	93.5	98.5	96.9	88.1	80.3	66.5	58.3	(23)
(24)		MCWB	46.8	48.2	52.4	56.2	60.8	64.4	65.5	64.8	62.8	59.1	53.2	49.1	(24)	
(25)		10%	DB	53.3	56.3	62.8	69.1	80.1	89.9	95.7	94.5	84.6	76.1	62.7	55.0	(25)
(26)		MCWB	45.8	47.2	50.9	54.0	59.3	63.3	64.8	65.0	62.6	58.3	52.2	47.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	54.5	58.5	61.2	67.3	71.0	73.5	72.8	69.6	66.5	60.4	55.1	(27)
(28)		MCDWB	59.8	63.8	70.6	75.4	83.8	91.9	94.6	91.6	82.5	78.9	70.1	63.6	(28)	
(29)		2%	WB	49.9	51.9	55.9	59.1	64.3	68.3	70.0	70.2	67.3	63.6	57.4	52.2	(29)
(30)		MCDWB	57.9	60.1	66.7	73.2	82.2	89.7	91.7	89.4	81.7	76.3	65.6	58.6	(30)	
(31)		5%	WB	48.2	49.8	53.8	57.3	62.3	66.2	68.2	68.7	65.9	61.6	55.3	50.3	(31)
(32)		MCDWB	54.6	57.2	63.7	70.5	79.4	87.9	90.7	87.7	80.4	73.7	62.6	56.1	(32)	
(33)		10%	WB	46.6	48.1	51.8	55.3	60.5	64.4	66.6	67.1	64.4	60.0	53.2	48.6	(33)
(34)		MCDWB	51.9	54.6	61.0	66.8	76.5	85.9	89.8	86.4	79.2	71.3	60.7	53.7	(34)	
(35)	Mean Daily Temperature Range	MDBR	17.6	19.1	21.3	23.3	25.8	28.5	29.5	28.3	25.1	22.7	18.3	17.0	(35)	
(36)		5% DB	MCDBR	25.7	26.8	28.6	32.2	32.8	31.9	31.8	31.2	29.4	28.2	24.9	24.3	(36)
(37)		MCWBR	15.3	15.7	15.6	16.2	13.2	12.2	11.3	11.4	11.0	12.0	13.1	14.7	(37)	
(38)		5% WB	MCDBR	21.0	22.3	25.1	29.0	29.2	30.7	30.0	28.3	25.8	24.0	21.2	19.9	(38)
(39)	MCWBR	13.6	14.4	15.1	15.7	13.6	13.2	12.3	12.2	11.2	12.1	12.4	13.2	(39)		
(40)	Clear-Sky Solar Irradiance	taub	0.281	0.305	0.364	0.392	0.428	0.445	0.497	0.462	0.428	0.374	0.326	0.291	(40)	
(41)		taud	2.517	2.450	2.263	2.199	2.118	2.071	1.912	2.016	2.120	2.278	2.414	2.506	(41)	
(42)		Ebn at Noon	296	298	286	283	273	267	252	259	262	268	273	284	(42)	
(43)		Edh at Noon	25	31	40	45	50	52	61	54	46	36	28	24	(43)	
(44)	All-Sky Solar Radiation	RadAvg	859	1110	1523	1854	2129	2413	2354	2123	1685	1322	927	770	(44)	
(45)		RadStd	102	130	118	151	172	95	60	95	90	97	71	69	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (9 neighbors)	N/A	N/A	N/A	+0.85	N/A	N/A	N/A	+153	+81	(47)

Nomenclature: See separate page