

TIARET BOU CHEKIF, Algeria

WMO: 605110

Lat: 35.341N

Lon: 1.463E

Elev: 989

StdP: 89.99

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.6	-1.2	-6.8	2.4	9.2	-5.0	2.8	7.2	19.1	7.7	17.1	7.6	1.4	240	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	37.9	18.5	36.5	18.4	35.1	18.2	21.2	32.2	20.4	31.4	19.5	30.6	6.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	14.7	24.9	17.1	13.8	23.9	16.1	12.9	23.3	66.7	32.1	63.1	31.2	60.2	30.5	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	12.2	10.4	DB	-5.0	40.3	2.1	1.2	-6.5	41.2	-7.7	41.9	-8.9	42.6	-10.4	43.5
			WB	-5.6	23.6	2.0	1.9	-7.1	25.0	-8.3	26.1	-9.4	27.1	-10.9	28.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	6.4	7.0	9.7	12.1	16.9	22.5	26.7	26.2	21.2	16.9	10.5	7.4	(6)
(7)		DBStd	7.90	2.75	3.20	3.33	3.45	4.23	3.97	2.84	2.67	3.35	3.60	3.45	2.73	(7)
(8)		HDD10.0	395	117	92	44	16	2	0	0	0	1	34	89	(8)	
(9)		HDD18.3	1887	372	318	266	187	79	9	0	11	72	234	339	(9)	
(10)		CDD10.0	2345	3	8	37	80	215	376	517	502	337	214	49	8	(10)
(11)		CDD18.3	797	0	0	0	2	34	135	258	243	98	26	1	0	(11)
(12)		CDH23.3	10737	0	1	10	69	572	1903	3588	3192	1088	307	7	0	(12)
(13)		CDH26.7	5663	0	0	1	8	212	979	2130	1805	448	81	0	0	(13)
(14)	Wind	WSAvg	4.0	4.7	4.7	4.4	4.2	3.7	3.5	3.3	3.3	3.6	4.5	4.3	(14)	
(15)	Precipitation	PrecAvg	370	40	43	41	41	32	11	4	11	30	34	45	39	(15)
(16)		PrecMax	521	95	123	121	119	72	52	26	49	103	79	108	79	(16)
(17)		PrecMin	213	0	0	0	0	2	0	0	1	1	2	6	0	(17)
(18)		PrecStd	89	26	29	31	30	21	12	6	11	27	24	26	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.0	20.4	24.7	27.8	34.1	38.1	39.9	38.9	34.9	31.5	24.0	19.5	(19)
(20)		0.4%	MCWB	9.8	10.9	13.5	14.7	17.0	18.1	18.8	18.9	17.4	16.0	13.9	11.0	(20)
(21)		2%	DB	16.2	17.7	21.6	25.2	31.3	36.0	38.2	37.3	33.0	28.9	21.2	16.7	(21)
(22)		2%	MCWB	8.8	9.6	12.2	13.9	16.5	18.3	18.7	18.4	17.9	15.6	12.1	10.2	(22)
(23)		5%	DB	13.9	15.4	19.1	23.1	29.0	34.2	36.9	36.0	31.2	26.8	19.2	14.6	(23)
(24)		5%	MCWB	8.2	9.0	11.3	13.5	16.0	18.0	18.6	18.2	17.1	15.1	11.8	9.5	(24)
(25)		10%	DB	11.8	13.5	17.1	20.6	26.7	32.2	35.4	34.7	29.2	24.5	17.1	12.8	(25)
(26)		10%	MCWB	7.7	8.5	10.5	12.2	15.1	17.4	18.2	18.3	17.0	14.6	11.2	8.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	12.5	14.7	16.2	19.6	21.7	23.1	22.7	20.9	19.2	15.8	12.8	(27)
(28)		0.4%	MCDWB	15.5	17.7	21.4	24.1	28.8	33.3	34.8	33.1	28.1	26.1	21.2	17.6	(28)
(29)		2%	WB	10.0	11.0	13.3	15.1	17.9	20.2	21.1	21.2	19.6	17.5	14.1	11.2	(29)
(30)		2%	MCDWB	14.4	15.6	19.3	22.9	27.9	32.0	33.2	31.9	27.6	24.6	18.7	14.8	(30)
(31)		5%	WB	9.0	9.9	12.1	14.0	16.9	19.0	20.1	20.4	18.8	16.4	12.9	10.2	(31)
(32)		5%	MCDWB	12.6	14.0	17.6	21.4	26.4	31.0	32.6	31.0	26.9	23.1	17.0	13.4	(32)
(33)		10%	WB	8.1	8.9	11.0	12.9	15.8	18.0	19.2	19.5	18.0	15.6	11.8	9.2	(33)
(34)		10%	MCDWB	11.0	12.5	16.1	19.3	24.7	29.9	32.1	30.2	26.2	21.8	15.9	12.1	(34)
(35)	Mean Daily Temperature Range		MDBR	9.8	10.6	11.8	12.9	14.3	15.9	16.4	15.7	14.0	12.6	10.2	9.4	(35)
(36)		5% DB	MCDBR	14.3	14.9	15.9	17.9	18.2	17.7	17.6	17.3	16.3	15.6	13.8	13.5	(36)
(37)		5% DB	MCWBR	8.5	8.7	8.7	9.0	7.4	6.8	6.3	6.3	6.1	6.7	7.3	8.2	(37)
(38)		5% WB	MCDBR	11.6	12.4	13.9	16.1	16.2	17.1	16.6	15.7	14.3	13.4	11.8	11.1	(38)
(39)		5% WB	MCWBR	7.5	8.0	8.4	8.7	7.6	7.3	6.8	6.8	6.2	6.7	6.9	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.281	0.305	0.364	0.392	0.428	0.445	0.497	0.462	0.428	0.374	0.326	0.291	(40)	
(41)		taud	2.517	2.450	2.263	2.199	2.118	2.071	1.912	2.016	2.120	2.278	2.414	2.506	(41)	
(42)		Ebn at Noon	933	941	903	892	861	842	795	816	826	845	862	896	(42)	
(43)		Edh at Noon	80	97	127	143	158	165	192	170	145	114	89	77	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.71	3.50	4.80	5.84	6.71	7.61	7.42	6.69	5.31	4.17	2.92	2.43	(44)	
(45)		RadStd	0.32	0.41	0.37	0.47	0.54	0.30	0.19	0.30	0.28	0.31	0.22	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	+0.47	N/A	N/A	N/A	+85	+45

Nomenclature: See separate page