

BISKRA, AlgeriaWMO: **605250**Lat: **34.793N**Lon: **5.738E**Elev: **289**StdP: **14.54**Time Zone: **1.00 (E01)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	40.0	42.5	22.2	16.8	57.7	24.9	19.2	57.6	33.7	57.1	31.2	55.6	5.0	10	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.9	111.3	71.4	108.7	70.9	105.8	70.5	75.3	100.3	74.0	99.3	72.9	98.2	9.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.1	104.2	84.8	66.2	97.5	84.4	64.5	91.8	84.9	38.8	100.5	37.6	99.1	36.6	98.2	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.5	28.1	24.6	35.1	115.7	2.3	1.6	33.5	116.9	32.1	117.8	30.8	118.7	29.2	119.9
			31.8	78.6	1.8	3.3	30.4	81.0	29.3	82.9	28.3	84.8	27.0	87.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.1	54.1	56.6	63.3	70.1	79.5	88.4	94.5	93.1	84.2	74.7	62.8	55.5	(6)
(7)		DBStd	15.17	4.12	5.08	5.75	5.97	6.48	6.13	4.56	4.51	6.10	5.52	5.19	4.34	(7)
(8)		HDD50	24	11	6	0	0	0	0	0	0	0	0	0	7	(8)
(9)		HDD65	1096	339	240	101	18	0	0	0	0	0	3	100	295	(9)
(10)		CDD50	8475	137	190	413	602	913	1152	1379	1335	1025	766	385	178	(10)
(11)		CDD65	4069	0	4	49	170	448	702	914	870	575	303	34	0	(11)
(12)		CDH74	58640	1	31	420	1622	5492	10759	15472	14332	7665	2672	172	2	(12)
(13)		CDH80	36744	0	5	83	565	2862	6922	11045	9933	4301	1006	22	0	(13)
(14)	Wind	WSAvg	9.2	8.9	9.8	10.9	11.8	11.5	9.5	8.4	7.7	8.2	7.4	8.5	8.1	(14)
(15)	Precipitation	PrecAvg	4.4	0.5	0.3	0.5	0.5	0.2	0.0	0.2	0.5	0.5	0.6	0.4	0.4	(15)
(16)		PrecMax	9.9	3.0	1.5	1.9	2.7	2.2	0.9	1.3	1.3	2.0	3.1	2.9	1.5	(16)
(17)		PrecMin	1.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.0	0.7	0.3	0.5	0.6	0.6	0.3	0.2	0.3	0.5	0.7	0.7	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.6	77.3	87.5	94.8	105.6	112.0	115.2	113.2	105.9	96.9	82.6	71.7	(19)
(20)		MCWB	54.7	56.7	60.8	63.2	67.5	70.3	72.8	71.8	71.2	67.9	62.7	56.0	56.0	(20)
(21)		2%	DB	68.1	73.4	81.6	89.6	100.1	108.4	112.1	110.4	102.2	92.5	78.5	68.9	(21)
(22)		MCWB	53.9	55.0	58.3	62.5	67.0	69.4	71.7	71.4	70.8	66.6	61.2	55.0	55.0	(22)
(23)		5%	DB	65.8	70.1	78.6	86.2	96.4	104.8	109.4	107.5	98.8	88.6	75.3	66.6	(23)
(24)		MCWB	52.4	53.7	57.0	61.4	65.9	68.8	71.3	71.2	70.3	65.9	59.2	54.0	54.0	(24)
(25)		10%	DB	62.9	67.2	75.4	82.7	93.0	101.8	106.2	104.5	95.9	85.6	72.6	64.4	(25)
(26)		MCWB	51.1	52.3	56.2	59.9	64.9	68.6	70.9	71.3	69.7	65.5	57.8	52.9	52.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.7	59.5	63.0	66.2	70.7	74.0	76.7	77.6	76.3	71.9	65.6	59.0	(27)
(28)		MCD B	68.1	74.2	77.8	85.5	96.0	101.0	105.5	98.7	95.7	87.1	78.7	67.2	67.2	(28)
(29)		2%	WB	54.9	56.7	60.4	64.3	68.7	72.0	74.9	75.4	74.1	69.8	62.8	56.7	(29)
(30)		MCD B	65.1	70.2	77.9	84.3	93.2	99.4	104.3	99.5	94.2	85.1	75.0	65.7	65.7	(30)
(31)		5%	WB	53.3	54.9	58.5	62.7	67.3	70.7	73.5	74.2	72.7	68.2	60.8	55.2	(31)
(32)		MCD B	63.2	67.7	75.5	81.6	91.5	98.2	102.3	99.1	92.6	83.0	72.7	64.2	64.2	(32)
(33)		10%	WB	51.8	53.0	57.0	61.2	66.0	69.6	72.2	73.1	71.4	66.8	59.0	53.8	(33)
(34)		MCD B	61.3	65.2	73.2	78.9	89.3	97.0	101.0	98.4	90.5	81.7	69.9	62.9	62.9	(34)
(35)	Mean Daily Temperature Range	MDBR	17.6	18.8	20.2	20.4	20.9	21.5	21.9	21.0	19.1	18.8	17.6	16.9	16.9	(35)
(36)		5% DB	MCD BR	20.6	22.2	23.9	24.1	24.2	24.0	25.0	23.7	21.7	22.0	20.0	19.3	(36)
(37)		MCWBR	11.3	11.3	10.6	10.0	9.2	8.4	8.6	8.4	8.2	9.2	9.8	10.6	10.6	(37)
(38)		5% WB	MCD BR	18.8	20.5	21.4	21.6	22.1	22.4	22.4	20.9	19.4	18.5	18.6	17.3	(38)
(39)		MCWBR	11.2	11.4	10.5	9.8	9.2	9.1	9.2	9.0	8.5	8.8	10.0	10.3	10.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.329	0.357	0.438	0.487	0.543	0.551	0.604	0.569	0.531	0.464	0.388	0.342	0.342	(40)
(41)		taud	2.357	2.262	1.999	1.896	1.791	1.785	1.688	1.762	1.859	1.995	2.177	2.311	2.311	(41)
(42)		Ebn at Noon	275	279	262	255	243	240	226	231	232	237	248	261	261	(42)
(43)		Edh at Noon	30	37	53	62	69	70	76	70	60	48	36	30	30	(43)
(44)	All-Sky Solar Radiation	RadAvg	985	1285	1671	2017	2268	2479	2463	2189	1762	1385	1042	876	876	(44)
(45)		RadStd	66	65	86	102	81	70	45	71	62	84	46	57	57	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		+0.81	N/A	N/A	N/A	+1.15	+1.40	N/A	N/A	N/A	N/A	
(47)	Regional (6 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page