

SAIDA, Algeria

WMO: 605360

Lat: 34.8913N

Lon: 0.1577E

Elev: 2467

StdP: 13.43

Time Zone: 1.00 (E01)

Period: 01-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.9	33.3	23.4	19.3	48.5	26.4	22.2	46.1	35.1	47.5	30.2	48.3	1.0	0	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.4	102.5	67.9	99.8	67.5	97.1	67.2	72.7	91.6	71.0	90.5	69.7	89.2	12.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.2	109.7	79.9	65.5	103.1	78.9	63.6	96.6	78.1	38.0	91.1	36.5	90.4	35.2	89.2	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
28.0	23.3	20.0	DB	25.9	106.9	5.0	1.5	22.2	107.9	19.3	108.8	16.4	109.6	12.8	110.6
			WB	24.8	75.6	4.9	2.2	21.2	77.2	18.3	78.5	15.6	79.7	12.0	81.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.0	47.6	48.2	53.4	58.1	65.4	74.9	82.6	81.5	73.4	66.8	54.8	48.8
(7)		DBStd	13.83	5.10	6.07	6.31	7.04	7.68	7.14	5.10	4.66	5.80	6.44	6.41	5.79
(8)		HDD50	361	108	94	38	10	0	0	0	0	0	22	89	
(9)		HDD65	2570	538	470	362	229	93	6	0	3	54	311	504	
(10)		CDD50	5123	35	44	143	252	477	747	1009	977	701	520	167	51
(11)		CDD65	1858	0	0	2	21	105	303	544	512	254	109	7	1
(12)		CDH74	24147	0	5	58	400	1454	4023	7502	6779	2729	1142	51	4
(13)		CDH80	13181	0	0	7	104	595	2171	4632	4043	1231	390	8	0
(14)	Wind	WSAvg	6.2	6.0	7.0	7.0	6.7	6.3	6.0	6.1	5.8	5.4	5.6	6.4	5.9
(15)	Precipitation	PrecAvg	13.9	1.5	1.5	1.5	1.6	1.3	0.5	0.2	0.4	0.8	1.5	1.9	1.2
(16)		PrecMax	20.9	4.1	4.9	6.8	4.9	3.9	2.8	1.2	1.8	3.1	5.7	7.4	3.2
(17)		PrecMin	6.7	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.5	0.0	0.0
(18)		PrecStd	3.5	1.2	1.0	1.5	1.1	0.9	0.6	0.3	0.4	0.7	1.3	1.3	0.9
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.4	73.0	80.0	87.3	95.6	102.6	106.2	104.8	97.8	92.4	80.0	72.4
(20)		0.4%	MCWB	51.9	53.9	56.8	59.3	64.7	67.0	68.2	67.4	66.2	64.6	59.7	55.0
(21)		2%	DB	65.3	67.2	74.4	82.8	90.8	99.0	103.2	101.9	94.1	88.3	74.0	65.7
(22)		2%	MCWB	50.2	52.0	56.0	58.7	63.5	66.6	67.9	68.5	66.3	63.2	56.3	52.6
(23)		5%	DB	60.9	63.2	70.1	78.6	86.6	95.6	100.5	99.3	90.9	84.5	70.0	62.0
(24)		5%	MCWB	48.8	50.4	55.0	58.4	62.6	65.9	67.6	67.7	66.2	62.2	55.5	51.1
(25)		10%	DB	57.3	59.4	66.6	73.9	82.6	92.0	97.6	96.4	87.4	80.5	66.1	58.5
(26)		10%	MCWB	48.6	49.2	53.8	57.0	61.3	65.3	67.1	67.9	65.1	61.1	54.2	49.4
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	56.6	60.7	65.2	69.2	71.3	73.9	75.1	73.6	70.9	63.6	56.9
(28)		0.4%	MCDWB	64.3	68.4	71.3	78.4	89.0	94.6	94.1	94.0	89.3	84.8	74.8	67.4
(29)		2%	WB	52.1	53.8	58.3	61.5	66.2	69.0	71.9	73.2	70.5	66.0	59.9	54.1
(30)		2%	MCDWB	60.7	63.3	69.9	76.3	83.7	91.2	92.3	91.8	84.6	81.0	68.9	64.1
(31)		5%	WB	50.4	51.6	56.4	59.5	64.3	67.5	70.3	71.4	68.7	64.1	57.2	51.9
(32)		5%	MCDWB	57.8	60.4	67.4	74.8	81.6	89.6	91.8	90.9	83.0	78.5	66.7	60.2
(33)		10%	WB	49.0	49.9	54.5	57.7	62.5	66.3	69.1	69.9	67.2	62.6	54.7	50.3
(34)		10%	MCDWB	56.0	57.7	64.5	71.4	79.3	88.7	91.4	88.9	82.2	76.1	64.0	57.1
(35)	Mean Daily Temperature Range		MDBR	18.2	18.2	21.7	24.2	25.3	28.1	29.4	28.9	25.0	22.9	17.9	16.7
(36)		5% DB	MCDBR	25.4	25.5	28.9	33.1	32.0	31.6	31.0	31.6	29.4	27.8	23.6	22.1
(37)			MCWBR	13.9	13.1	14.3	14.6	12.4	10.7	10.0	10.7	10.8	11.0	10.9	12.2
(38)			5% WB	MCDWB	21.1	21.9	25.3	29.8	28.0	28.9	28.0	28.9	26.0	24.1	20.8
(39)		MCWBR		12.6	12.3	13.6	14.5	11.9	11.3	11.1	12.1	11.3	11.0	10.4	11.7
(40)	Clear-Sky Solar Irradiance	taub	0.292	0.322	0.388	0.412	0.450	0.476	0.536	0.499	0.456	0.395	0.340	0.303	
(41)		taud	2.495	2.409	2.191	2.144	2.061	1.989	1.835	1.931	2.052	2.218	2.385	2.487	
(42)		Ebn at Noon	292	293	279	277	267	259	243	249	254	261	269	280	
(43)		Edh at Noon	26	32	44	48	53	57	66	59	49	38	29	25	
(44)	All-Sky Solar Radiation	RadAvg	913	1188	1593	1926	2188	2446	2409	2187	1754	1374	969	820	
(45)		RadStd	83	114	89	142	143	80	51	79	98	89	76	65	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	+0.52	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page