

EL OUED GUEMAR, Algeria

WMO: 605590

Lat: 33.511N

Lon: 6.777E

Elev: 203

StdP: 14.59

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.4	39.5	22.7	17.2	57.9	25.8	19.9	56.7	26.1	56.9	22.9	57.1	2.0	220	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.3	113.3	72.2	110.8	71.9	107.5	71.4	76.4	99.0	75.2	98.2	74.1	97.4	8.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.2	116.0	84.0	69.2	108.0	83.9	67.5	102.0	83.9	39.9	98.5	38.7	98.2	37.7	97.3	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	21.4	18.3	DB	33.1	118.2	1.8	3.0	31.8	120.4	30.7	122.2	29.7	123.8	28.4	126.0	(4)
(5)			WB	30.7	80.3	1.9	2.2	29.4	81.8	28.3	83.1	27.3	84.3	25.9	85.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.8	52.8	55.9	63.1	70.7	79.5	88.0	93.8	92.6	84.5	74.8	62.2	54.2
	DBStd	15.44	3.99	5.25	6.14	6.31	6.40	6.08	4.88	4.61	6.16	6.02	5.46	4.39
	HDD50	36	17	7	0	0	0	0	0	0	0	0	1	11
	HDD65	1220	378	259	110	17	0	0	0	0	0	3	117	336
	CDD50	8349	104	174	407	621	914	1141	1357	1320	1035	767	367	142
	CDD65	4058	0	5	52	188	450	691	892	855	585	305	34	1
	CDH74	59372	2	63	588	2040	5708	10604	15089	14036	7920	3038	274	10
	CDH80	37441	0	10	168	847	3139	6918	10726	9684	4598	1303	48	0
Wind	WSAvg	6.2	4.8	5.9	6.9	8.4	8.3	8.0	7.0	6.4	6.1	4.6	4.2	4.4
Precipitation	PrecAvg	2.8	0.7	0.2	0.3	0.3	0.1	0.0	0.0	0.1	0.4	0.2	0.2	0.3
	PrecMax	8.1	4.9	1.7	1.3	1.2	1.4	0.4	0.3	0.6	1.4	1.3	1.5	1.1
	PrecMin	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0
	PrecStd	1.8	1.1	0.4	0.3	0.3	0.3	0.1	0.0	0.2	0.4	0.3	0.4	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.8	80.4	90.3	98.8	107.9	114.8	118.0	115.1	109.1	99.1	84.6	73.8
		MCWB	55.5	56.8	62.5	65.7	69.6	71.0	72.9	73.1	71.4	68.6	62.6	57.5
	2%	DB	68.1	75.1	84.4	93.1	102.4	110.9	114.6	112.6	104.5	94.9	80.3	69.7
		MCWB	53.9	56.6	59.6	63.3	68.5	70.7	72.9	72.3	71.5	68.0	61.8	55.3
	5%	DB	65.8	71.3	80.4	88.6	98.1	106.9	111.4	109.3	101.0	90.7	76.9	67.0
		MCWB	52.7	54.4	58.5	62.5	67.1	70.1	72.3	72.0	71.1	67.3	60.2	54.6
	10%	DB	63.0	67.7	76.6	84.5	94.3	102.6	107.8	105.8	97.2	87.1	73.6	64.5
		MCWB	51.6	52.9	57.2	61.1	66.4	69.7	71.9	71.9	71.0	66.8	58.7	53.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.9	60.8	65.6	68.8	73.7	76.5	78.8	78.2	77.5	73.7	66.6	60.2
		MCDB	68.2	77.0	81.9	88.5	97.1	100.8	102.9	99.8	94.3	88.7	80.6	68.7
	2%	WB	55.6	57.5	62.1	66.1	71.0	73.8	76.0	76.3	75.6	71.7	63.8	57.6
		MCDB	64.9	71.1	79.5	87.2	94.4	99.6	103.3	98.6	92.9	86.5	76.4	66.1
	5%	WB	53.9	55.5	59.9	64.0	69.0	72.2	74.5	75.1	74.2	70.0	61.6	55.9
		MCDB	63.3	68.4	77.0	83.6	92.9	98.4	102.5	98.0	91.4	83.8	73.8	64.5
	10%	WB	52.3	53.8	58.2	62.3	67.5	70.9	73.3	74.1	72.9	68.4	59.7	54.3
		MCDB	61.4	66.0	74.2	81.0	90.6	97.2	101.3	97.6	90.2	82.4	71.3	63.3
Mean Daily Temperature Range	5% DB	MDBR	21.1	22.4	23.0	23.5	24.2	24.9	25.3	23.9	21.6	21.9	21.3	20.5
		MCDBR	23.9	25.8	27.9	28.8	28.7	29.5	29.5	27.9	25.5	25.7	23.7	22.8
		MCWBR	13.0	12.8	12.1	11.0	9.9	9.5	9.0	8.3	8.5	9.7	10.7	12.0
	5% WB	MCDBR	21.8	23.5	25.6	25.4	25.5	26.2	26.2	24.2	21.8	21.3	21.8	20.6
		MCWBR	12.9	12.7	12.2	11.2	10.8	10.3	9.5	8.5	8.5	9.1	11.1	12.1
Clear-Sky Solar Irradiance	taub		0.368	0.399	0.502	0.554	0.608	0.602	0.636	0.606	0.582	0.513	0.428	0.383
	taud		2.107	2.006	1.740	1.653	1.575	1.598	1.553	1.613	1.670	1.791	1.957	2.059
	Ebn at Noon		259	264	244	239	227	228	219	223	220	223	233	244
	Edh at Noon		40	49	69	79	86	84	88	81	74	60	46	40
All-Sky Solar Radiation	RadAvg		1087	1400	1737	2091	2279	2429	2408	2161	1804	1439	1124	964
	RadStd		47	53	73	82	76	65	41	53	49	64	37	47

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.85	N/A	-1.62	N/A	N/A	N/A	-27	N/A	+238	N/A
Regional (3 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+203	+189

Nomenclature: See separate page