

BECHAR, Algeria

WMO: 605710

Lat: 31.646N

Lon: 2.270W

Elev: 2661

StdP: 13.34

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.9	36.4	9.7	10.0	57.2	13.4	12.0	58.6	32.1	53.0	28.5	53.4	2.3	350	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.0	107.6	67.6	106.0	67.1	104.3	66.6	71.7	97.6	70.2	96.8	68.9	95.6	11.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.9	98.3	82.1	61.2	89.0	81.1	59.2	82.8	81.4	37.2	97.9	35.8	97.1	34.5	95.6	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.3	25.5	21.9	30.1	110.5	2.7	1.5	28.1	111.6	26.5	112.5	25.0	113.4	23.0	114.5
			27.0	74.5	2.7	2.5	25.0	76.4	23.4	77.8	21.9	79.3	19.9	81.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.1	50.3	54.2	61.9	69.4	77.9	86.8	93.9	91.9	82.8	72.3	59.6	51.8	(6)
	DBStd	15.90	4.46	5.21	5.98	6.15	6.70	4.99	3.43	3.72	6.02	5.59	5.90	4.50	(7)
	HDD50	105	50	20	0	0	0	0	0	0	0	0	2	33	(8)
	HDD65	1519	455	302	132	27	2	0	0	0	0	9	182	410	(9)
	CDD50	7826	60	138	370	581	864	1103	1360	1298	983	691	290	88	(10)
	CDD65	3766	0	1	37	158	402	653	895	833	533	235	19	0	(11)
	CDH74	56830	3	25	449	1689	5186	10156	15684	13918	7255	2280	183	2	(12)
	CDH80	35590	0	3	93	578	2634	6429	11296	9603	4113	818	23	0	(13)
(14) Wind	WSAvg	8.4	5.9	7.8	9.2	10.9	11.1	9.8	9.5	8.9	8.7	7.3	6.7	5.5	(14)
(15) Precipitation	PrecAvg	3.4	0.3	0.3	0.3	0.3	0.2	0.1	0.1	0.1	0.3	0.5	0.4	0.4	(15)
	PrecMax	9.6	3.1	2.1	2.9	1.9	1.1	1.6	0.6	1.4	3.0	6.0	1.7	2.3	(16)
	PrecMin	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	2.0	0.6	0.5	0.6	0.4	0.3	0.3	0.1	0.2	0.5	1.0	0.5	0.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.0	77.4	87.6	93.3	100.7	106.2	109.8	108.0	103.5	93.6	83.0	73.3	(19)
		MCWB	50.6	53.6	56.2	59.1	64.1	66.9	67.9	68.0	67.0	63.4	59.3	52.8	(20)
	2%	DB	68.9	73.0	82.4	89.5	97.9	104.2	108.0	106.3	100.7	90.0	79.0	69.6	(21)
		MCWB	49.5	50.8	54.5	58.8	63.0	66.0	67.6	67.4	66.0	61.2	56.9	51.6	(22)
	5%	DB	66.0	70.0	78.8	86.2	95.1	102.3	107.3	105.3	98.6	87.7	75.4	66.3	(23)
		MCWB	48.7	49.8	53.7	57.9	61.8	65.2	67.4	67.1	65.1	61.0	55.2	50.4	(24)
	10%	DB	62.8	67.2	75.5	82.9	91.8	100.1	105.7	103.7	96.0	84.6	72.1	63.0	(25)
		MCWB	47.3	48.9	52.5	56.5	60.6	64.7	67.0	66.6	64.4	60.1	53.8	49.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.7	56.6	59.5	64.9	68.4	71.3	73.5	73.9	72.9	68.2	62.6	56.9	(27)
		MCDB	67.9	71.0	76.8	83.2	90.3	97.8	102.3	99.5	93.4	88.2	80.4	66.0	(28)
	2%	WB	51.8	53.6	57.0	62.3	65.5	69.0	71.4	71.6	70.2	65.4	59.3	53.8	(29)
		MCDB	65.6	68.7	75.9	81.8	88.8	95.5	101.0	96.7	91.4	81.9	72.4	65.1	(30)
	5%	WB	49.8	51.8	55.1	59.8	63.6	67.2	69.8	70.1	68.4	63.7	57.1	52.0	(31)
		MCDB	62.8	65.7	73.7	80.0	87.1	94.2	100.7	96.2	89.6	80.0	71.8	63.1	(32)
	10%	WB	48.0	49.9	53.5	57.7	61.8	65.7	68.2	68.7	66.9	62.3	55.1	50.2	(33)
		MCDB	60.5	63.7	72.1	77.8	85.8	93.0	99.1	95.6	87.9	78.5	70.5	61.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	23.5	22.8	22.7	22.1	22.2	22.8	23.0	22.2	21.5	21.2	21.6	22.1	(35)
		MCDBR	29.2	27.4	26.8	25.2	24.5	25.2	24.5	23.5	23.6	24.3	24.8	26.8	(36)
		MCWBR	15.5	13.2	11.5	10.6	9.5	9.1	9.0	8.5	8.7	9.8	11.6	13.6	(37)
	5% WB	MCDBR	26.1	23.6	24.3	22.4	22.9	23.3	22.6	22.1	20.9	20.9	22.3	23.6	(38)
		MCWBR	15.0	12.1	11.5	10.7	9.8	9.5	9.8	9.0	9.0	9.4	11.7	12.8	(39)
(40) Clear-Sky Solar Irradiance	taub		0.289	0.328	0.404	0.438	0.485	0.528	0.614	0.569	0.506	0.437	0.351	0.302	(40)
	taud		2.463	2.334	2.068	1.989	1.884	1.788	1.618	1.722	1.867	2.030	2.292	2.441	(41)
	Ebn at Noon		299	294	277	272	259	246	225	233	243	252	271	287	(42)
	Edh at Noon		29	36	50	57	64	70	82	73	61	48	34	28	(43)
(44) All-Sky Solar Radiation	RadAvg		1218	1524	1902	2224	2424	2552	2448	2234	1853	1539	1251	1100	(44)
	RadStd		73	84	86	90	84	80	50	75	98	98	64	51	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.74	N/A	N/A	+0.65	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page