

OUARGLA, Algeria

WMO: 605800

Lat: 31.917N

Lon: 5.413E

Elev: 150

StdP: 99.54

Time Zone: 1.00 (E01)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.6	3.9	-8.2	1.9	16.6	-6.2	2.3	16.7	12.0	15.1	10.4	15.1	1.0	320	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	46.6	23.0	45.2	22.8	43.9	22.3	25.0	41.3	24.1	40.8	23.5	39.9	4.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	15.1	31.7	19.0	14.1	31.9	18.0	13.2	31.8	76.6	41.4	73.0	40.7	70.2	39.7	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.7	8.6	DB	0.1	48.7	1.3	1.0	-0.9	49.3	-1.6	49.9	-2.4	50.4	-3.3	51.1	
			WB	-1.6	26.2	1.2	1.7	-2.4	27.4	-3.1	28.4	-3.8	29.3	-4.7	30.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.8	11.8	13.9	18.4	23.0	27.9	32.7	36.1	35.1	30.8	24.7	17.2	12.7
	DBStd	9.07	2.42	3.16	3.67	3.72	3.69	3.28	2.52	2.35	3.52	3.49	3.11	2.66
	HDD10.0	19	9	3	0	0	0	0	0	0	0	0	1	6
	HDD18.3	617	203	131	45	4	0	0	0	0	0	1	58	176
	CDD10.0	5039	65	111	261	391	556	682	811	777	624	457	215	89
	CDD18.3	2596	0	5	47	145	297	432	552	519	374	199	23	2
	CDH23.3	40923	9	86	624	1815	4226	7183	9861	8978	5592	2283	249	18
Wind	WSAvg	3.8	2.9	3.6	4.0	4.6	4.9	4.6	4.0	4.0	4.1	3.3	2.7	2.6
	PrecAvg	41	8	1	6	4	4	1	0	1	3	5	3	4
	PrecMax	114	53	23	23	29	49	3	2	12	15	34	38	33
	PrecMin	9	0	0	1	2	0	0	0	0	0	0	0	0
	PrecStd	27	13	4	7	5	10	1	0	2	4	8	8	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.2	29.2	34.1	39.1	43.3	46.7	48.8	47.2	45.0	39.2	31.0	25.6
		MCWB	13.4	15.1	17.5	18.6	20.9	22.6	23.5	23.0	22.2	20.5	17.8	14.2
	2%	DB	21.9	25.9	31.3	36.2	40.9	45.0	47.1	45.8	42.8	37.0	28.2	22.7
		MCWB	12.3	13.8	16.5	17.9	20.5	22.3	23.1	23.2	21.6	19.5	16.3	13.4
	5%	DB	20.0	23.2	29.0	34.1	38.7	43.2	45.9	44.1	40.9	34.8	26.1	20.8
		MCWB	11.8	12.7	15.6	17.3	19.7	21.7	23.2	22.7	21.1	19.0	15.6	12.7
	10%	DB	18.2	21.1	26.9	31.8	36.8	41.3	44.2	42.8	39.0	32.4	24.1	19.0
		MCWB	10.7	11.6	14.3	16.5	19.0	21.0	22.4	22.2	21.0	18.7	14.8	11.7
	0.4%	WB	14.6	16.8	19.6	21.0	23.2	25.8	26.5	26.0	25.1	23.0	19.7	15.6
		MCDB	21.7	27.1	29.8	34.6	37.8	40.9	41.8	42.1	38.1	32.9	28.9	23.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	13.3	14.6	17.8	19.1	21.8	23.9	25.0	24.7	23.9	21.5	17.8	14.2
		MCDB	20.2	24.1	28.6	31.9	36.5	40.2	42.6	41.2	37.5	31.9	26.0	20.9
	5%	WB	12.3	13.2	16.5	18.0	20.7	22.8	24.1	23.9	23.0	20.6	16.4	13.2
		MCDB	18.7	21.8	26.8	30.7	35.0	39.4	42.2	40.6	35.9	30.7	24.3	19.5
	10%	WB	11.2	12.1	15.0	17.1	19.8	21.9	23.3	23.2	22.2	19.7	15.2	12.2
		MCDB	17.2	20.1	25.3	29.5	33.5	38.3	41.3	39.7	35.1	29.8	22.7	18.2
Mean Daily Temperature Range	5% DB	MDBR	13.1	13.6	14.3	14.2	14.2	14.5	14.6	14.2	13.5	13.7	13.1	12.8
		MCDBR	15.3	16.6	17.3	17.1	16.2	16.8	16.5	16.0	15.9	16.1	15.1	14.7
		MCWBR	8.4	8.7	8.1	7.1	6.4	6.3	6.1	5.7	5.6	6.5	7.2	8.0
	5% WB	MCDBR	14.0	15.0	16.0	15.0	14.4	14.8	14.6	14.3	13.6	13.5	13.9	13.4
		MCWBR	8.2	8.4	8.3	7.0	6.6	6.6	6.2	5.9	5.7	6.3	7.4	7.7
Clear-Sky Solar Irradiance	taub		0.361	0.389	0.496	0.538	0.599	0.606	0.635	0.605	0.594	0.514	0.417	0.374
	taud		2.142	2.051	1.762	1.697	1.594	1.592	1.557	1.619	1.649	1.793	1.993	2.103
	Ebn at Noon		839	852	781	769	726	718	695	708	689	712	762	796
	Edh at Noon		124	150	216	240	268	268	276	256	239	192	143	123
All-Sky Solar Radiation	RadAvg		3.70	4.63	5.71	6.73	7.25	7.71	7.67	7.01	5.88	4.79	3.82	3.30
	RadStd		0.15	0.19	0.23	0.26	0.24	0.20	0.10	0.15	0.19	0.20	0.14	0.15

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.34	N/A	N/A	N/A	N/A	-0.36	N/A	N/A	N/A	N/A

Nomenclature: See separate page