

EL MENIA, Algeria

WMO: 605900

Lat: 30.571N

Lon: 2.860E

Elev: 1306

StdP: 14.02

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.4	35.8	16.1	13.0	55.8	19.3	15.2	56.7	31.1	55.6	26.5	57.3	3.3	350	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.8	112.6	70.7	110.4	70.1	108.1	69.6	73.8	103.6	72.4	103.0	71.2	102.2	9.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.4	95.1	86.3	62.3	88.3	86.0	60.4	82.4	85.9	38.0	103.5	36.7	102.9	35.7	102.5	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
27.8	23.0	20.1	DB	28.0	115.9	2.5	1.4	26.2	117.0	24.7	117.8	23.3	118.6	21.5	119.6
			WB	25.0	78.4	2.4	3.4	23.2	80.8	21.8	82.8	20.5	84.7	18.8	87.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	72.9	50.7	55.1	63.1	71.3	80.7	89.5	95.0	93.6	86.2	74.7	60.7	52.7	(6)
(7)		DBStd	16.47	4.54	5.80	6.48	6.32	6.14	4.88	3.54	3.51	5.83	6.30	6.02	4.79	(7)
(8)		HDD50	90	46	16	1	0	0	0	0	0	0	2	25		(8)
(9)		HDD65	1394	442	282	113	14	0	0	0	0	4	156	383		(9)
(10)		CDD50	8442	69	158	408	639	952	1184	1396	1351	1087	765	324	109	(10)
(11)		CDD65	4271	0	4	55	203	487	734	931	886	637	305	28	1	(11)
(12)		CDH74	66601	4	97	849	2582	6765	11924	16335	15122	9191	3381	333	18	(12)
(13)		CDH80	43432	0	22	274	1180	3893	8029	11948	10768	5699	1545	73	1	(13)
(14)	Wind	WSAvg	7.8	6.4	7.9	8.5	9.8	9.9	9.1	7.7	7.5	7.7	7.0	6.2	6.2	(14)
(15)	Precipitation	PrecAvg	1.7	0.3	0.1	0.3	0.2	0.2	0.0	0.0	0.2	0.2	0.2	0.1	0.1	(15)
(16)		PrecMax	5.4	2.8	0.8	1.7	1.4	1.5	0.2	0.0	0.4	1.8	1.3	1.2	0.7	(16)
(17)		PrecMin	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.1	0.6	0.2	0.4	0.3	0.3	0.0	0.0	0.1	0.4	0.4	0.3	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.5	82.6	91.8	98.9	107.5	112.4	115.4	109.2	100.8	86.3	76.6		(19)
MCWB			54.3	56.7	60.5	63.5	67.2	70.5	71.3	70.9	69.9	67.8	62.3	56.1		(20)
2%		DB	69.5	76.3	86.4	94.8	103.5	109.7	113.2	111.2	106.0	95.6	81.8	70.7		(21)
		MCWB	51.8	54.3	58.7	62.4	66.6	69.5	70.8	70.7	69.1	65.6	59.6	53.8		(22)
5%		DB	66.2	72.1	82.5	91.1	100.0	107.3	111.4	109.2	103.7	91.7	77.7	67.4		(23)
		MCWB	50.5	52.7	57.7	61.1	65.5	68.9	70.2	70.3	68.8	64.8	58.2	52.4		(24)
10%		DB	63.1	68.6	78.6	87.2	96.5	104.2	109.3	107.2	100.4	88.2	73.8	64.4		(25)
		MCWB	49.3	51.1	55.8	59.8	64.3	68.2	69.9	69.7	68.3	64.0	56.1	51.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.1	58.8	63.6	67.3	70.7	75.6	76.0	75.7	74.4	71.0	65.0	58.5	(27)
MCD B			69.0	77.7	81.9	90.6	96.6	105.8	106.1	105.1	99.8	93.7	81.5	71.3	(28)	
2%		WB	53.4	55.9	60.7	64.1	68.4	72.3	73.5	73.5	72.3	68.6	61.9	55.7	(29)	
		MCD B	66.1	73.6	80.7	87.2	94.9	102.5	106.6	104.1	98.2	88.0	76.6	67.4	(30)	
5%		WB	51.4	53.7	58.4	62.2	66.5	70.4	71.9	72.0	70.8	66.9	59.6	54.0	(31)	
		MCD B	63.6	70.1	79.5	85.7	94.1	101.5	106.2	103.1	96.8	85.8	74.6	65.1	(32)	
10%		WB	49.9	51.9	56.5	60.3	65.0	69.0	70.7	70.9	69.6	65.3	57.4	52.3	(33)	
		MCD B	61.9	67.2	76.4	83.4	91.7	100.2	104.9	102.1	94.7	84.2	71.8	63.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	24.8	25.1	26.1	25.8	25.9	26.2	26.8	26.0	24.7	24.2	24.7	23.7	(35)
MCDBR			29.4	30.0	32.9	32.2	31.0	30.9	30.8	29.5	29.2	28.5	28.4	27.7	(36)	
MCWBR			16.0	14.9	15.2	13.8	11.4	11.8	11.0	10.8	11.0	11.7	13.5	15.0	(37)	
5% WB		MCD BR	26.2	28.0	30.2	28.1	27.1	27.6	28.2	26.3	24.8	24.4	25.2	24.5	(38)	
		MCWBR	15.1	14.6	14.8	13.0	11.5	12.0	11.4	10.7	10.8	11.4	13.1	14.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.337	0.368	0.467	0.506	0.561	0.590	0.622	0.591	0.576	0.499	0.391	0.346	(40)	
taud		2.202	2.090	1.808	1.742	1.640	1.596	1.551	1.623	1.659	1.797	2.041	2.181	(41)		
Ebn at Noon		279	280	258	253	240	232	224	229	225	233	254	268	(42)		
Edh at Noon		37	46	66	73	82	85	89	81	75	62	44	36	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1273	1559	1912	2221	2363	2516	2483	2287	1927	1602	1306	1146	(44)	
(45)		RadStd	50	62	86	78	78	58	45	54	69	70	55	47	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page