

TIMIMOUN, Algeria

WMO: 606070

Lat: 29.237N

Lon: 0.276E

Elev: 1027

StdP: 14.16

Time Zone: 1.00 (E01)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 37.5	(c) 39.8	(d) 5.3	(e) 7.5	(f) 57.4	(g) 9.0	(h) 9.0	(i) 58.8	(j) 32.6	(k) 56.0	(l) 28.8	(m) 56.3	(n) 7.6	(o) 30	(p) 0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.8	116.2	71.0	114.5	70.5	112.7	70.0	72.7	104.0	71.2	104.0	70.1	103.9	9.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	89.3	83.7	60.4	81.5	84.6	57.2	72.5	87.5	36.8	103.4	35.6	103.2	34.5	103.8	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 29.9	(b) 26.2	(c) 22.8	(e) 32.1	(f) 118.7	(g) 3.0	(h) 1.2	(i) 29.9	(j) 119.5	(k) 28.1	(l) 120.2	(m) 26.4	(n) 120.8	(o) 24.2	(p) 121.7		
(4) 29.9	(5) 26.2	(6) 22.8	(7) N/A	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.7	53.9	58.8	67.6	75.8	84.5	92.9	99.0	97.0	89.9	78.9	64.5	55.8
	DBStd	16.52	4.40	6.04	6.65	6.31	6.13	4.62	3.57	3.46	5.56	6.09	6.14	4.63
	HDD50	24	13	5	0	0	0	0	0	0	0	0	0	6
	HDD65	952	345	189	48	3	0	0	0	0	0	0	80	287
	CDD50	9756	134	251	547	774	1071	1288	1520	1456	1197	897	434	187
	CDD65	5207	0	14	130	327	606	838	1055	991	747	432	64	3
	CDH74	85221	18	243	1762	4361	9168	14565	19500	17791	11770	5280	729	34
	CDH80	58862	0	56	717	2326	5865	10484	15051	13355	7933	2843	230	2
Wind	WSAvg	10.4	9.2	10.6	11.1	12.1	12.1	11.3	10.8	10.2	9.9	9.4	8.6	9.2
Precipitation	PrecAvg	0.5	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.1
	PrecMax	1.4	0.4	0.7	1.1	1.3	0.4	0.0	0.2	0.7	0.9	1.1	0.3	0.9
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.4	0.1	0.2	0.2	0.2	0.1	0.0	0.0	0.2	0.2	0.2	0.1	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.8	86.2	96.9	104.1	109.7	115.2	118.6	116.6	111.6	104.1	91.7	77.4
		MCWB	53.2	57.2	60.2	65.3	68.1	70.4	72.8	70.7	69.2	65.6	60.9	54.6
	2%	DB	72.4	80.6	91.4	98.9	107.5	113.1	116.8	114.7	109.6	99.7	86.3	73.5
		MCWB	51.2	54.2	60.0	63.1	67.6	70.7	71.4	70.3	68.6	64.3	58.6	53.0
	5%	DB	69.6	76.6	87.6	95.4	104.2	111.1	115.2	112.9	107.6	96.8	81.6	70.5
		MCWB	49.5	52.8	57.8	61.9	66.1	69.4	70.8	70.0	68.1	63.1	57.1	51.7
	10%	DB	66.4	73.1	83.8	92.4	100.7	108.6	113.8	111.1	105.4	93.4	77.4	67.8
		MCWB	48.1	51.5	56.5	60.3	64.5	68.0	70.4	69.3	67.5	62.6	55.2	50.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.1	57.7	64.5	66.3	71.0	74.2	74.6	74.5	72.9	69.4	62.8	57.1
		MCDB	71.8	75.9	79.1	91.6	97.3	102.7	110.2	103.8	92.6	89.2	84.0	73.2
	2%	WB	52.6	55.6	60.2	63.7	68.3	70.4	72.3	72.6	71.1	66.7	60.5	54.6
		MCDB	69.0	73.6	80.9	89.9	95.1	103.1	109.6	104.7	97.8	89.0	81.2	70.1
	5%	WB	50.7	53.7	57.9	62.1	66.4	68.8	70.8	71.0	69.9	65.2	58.4	52.8
		MCDB	66.5	71.6	81.1	88.6	94.8	103.1	109.0	104.8	98.5	89.0	78.5	68.3
	10%	WB	48.8	51.8	55.9	60.3	64.8	67.3	69.5	69.8	68.4	63.8	56.4	51.2
		MCDB	64.4	70.0	78.5	86.2	94.3	102.1	108.1	104.7	97.6	88.6	75.0	65.9
Mean Daily Temperature Range	5% DB	MDBR	25.1	25.7	27.1	27.6	27.7	28.8	28.8	27.4	26.0	25.6	24.7	23.6
		MCDBR	28.5	30.0	32.3	31.7	30.8	31.3	29.5	29.0	29.0	28.7	28.1	26.3
		MCWBR	13.6	13.5	13.6	12.6	10.4	12.8	10.0	9.4	10.1	10.2	11.5	12.3
	5% WB	MCDBR	26.3	25.6	26.3	26.1	26.0	26.2	27.0	24.5	23.9	24.6	24.6	24.2
	MCWBR	13.6	12.5	12.3	11.4	11.0	11.2	9.9	9.3	9.5	9.9	11.3	12.0	
Clear-Sky Solar Irradiance	taub	0.359	0.401	0.490	0.530	0.581	0.618	0.661	0.629	0.606	0.525	0.413	0.366	
	taud	2.125	1.993	1.764	1.694	1.611	1.555	1.493	1.567	1.615	1.753	1.991	2.119	
	Ebn at Noon	272	270	253	248	235	226	215	220	219	227	250	263	
	Edh at Noon	41	52	69	77	84	89	94	86	80	65	47	40	
All-Sky Solar Radiation	RadAvg	1313	1600	1935	2200	2364	2484	2453	2263	1921	1621	1356	1197	
	RadStd	54	72	85	69	82	69	43	66	82	77	54	50	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page