

IN AMENAS, Algeria

WMO: 606110

Lat: 28.052N

Lon: 9.643E

Elev: 1847

StdP: 13.74

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.2	37.0	8.7	9.2	56.7	12.0	10.9	58.0	32.9	55.8	28.4	57.1	5.7	60	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.2	109.5	67.4	107.6	67.3	105.7	67.0	74.5	98.8	72.3	97.6	70.5	96.6	10.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	104.1	88.9	63.4	93.6	86.9	60.9	85.5	85.7	39.2	98.1	37.2	97.2	35.4	96.4	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.4	25.1	22.1	DB	29.4	112.7	2.9	1.4	27.3	113.8	25.5	114.6	23.9	115.4	21.8	116.5	(4)
(5)			WB	25.4	75.7	2.2	5.0	23.9	79.3	22.6	82.2	21.4	85.0	19.8	88.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.4	51.8	55.9	64.6	74.3	83.3	89.2	90.8	90.3	86.6	75.9	63.2	54.2	(6)
(7)		DBStd	15.32	5.20	6.37	7.38	7.32	5.98	4.66	3.83	3.34	4.38	5.84	5.90	5.40	(7)
(8)		HDD50	73	38	14	2	0	0	0	0	0	0	0	1	18	(8)
(9)		HDD65	1225	411	262	99	11	1	0	0	0	0	2	102	337	(9)
(10)		CDD50	8623	92	180	453	729	1031	1177	1266	1249	1098	803	397	148	(10)
(11)		CDD65	4303	1	9	86	290	567	727	801	784	648	340	47	3	(11)
(12)		CDH74	66336	31	213	1287	3930	8285	11796	13470	12883	9713	4006	654	68	(12)
(13)		CDH80	42059	3	48	490	2040	5085	7967	9340	8753	6176	1977	169	11	(13)
(14)	Wind	WSAvg	10.1	8.5	9.7	10.6	11.3	12.3	11.5	10.8	10.3	9.9	9.6	8.3	8.5	(14)
(15)	Precipitation	PrecAvg	0.8	0.1	0.0	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.1	(15)
(16)		PrecMax	3.0	0.7	0.3	1.4	0.8	1.0	1.2	0.0	0.6	0.6	1.1	0.4	0.5	(16)
(17)		PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	0.7	0.2	0.1	0.3	0.2	0.2	0.2	0.0	0.1	0.1	0.3	0.1	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.5	85.8	94.6	102.5	107.3	111.4	112.1	110.9	107.3	100.1	88.4	80.8	(19)
(20)			MCWB	53.0	57.3	60.0	63.8	66.0	66.3	68.6	68.0	67.3	65.2	59.6	54.6	(20)
(21)		2%	DB	72.8	80.3	89.9	98.4	104.0	108.9	109.8	107.7	105.4	96.5	84.5	75.0	(21)
(22)			MCWB	51.2	54.3	59.0	61.3	65.2	66.2	68.1	68.3	66.5	64.9	58.5	53.5	(22)
(23)		5%	DB	68.7	75.5	85.7	94.9	101.3	106.2	107.7	105.8	103.4	93.3	81.0	70.6	(23)
(24)			MCWB	49.5	52.4	57.6	60.8	64.5	66.2	67.6	67.9	66.4	63.9	57.4	51.8	(24)
(25)		10%	DB	64.9	71.2	81.4	91.3	98.5	103.9	105.5	103.7	100.7	90.4	77.3	66.6	(25)
(26)			MCWB	48.2	50.8	55.9	59.7	63.9	66.0	67.2	67.4	66.1	63.3	56.3	50.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.9	59.5	65.5	68.6	73.8	76.2	75.5	77.4	75.4	72.3	65.9	58.7	(27)
(28)			MCD B	71.4	75.7	85.7	92.2	96.5	98.9	103.4	99.9	95.9	91.5	82.1	70.6	(28)
(29)		2%	WB	52.8	56.2	61.9	65.4	69.7	72.6	73.0	74.0	72.4	68.7	61.6	55.4	(29)
(30)			MCD B	68.9	74.2	81.6	88.7	94.2	96.6	102.3	99.0	94.8	88.5	78.5	71.2	(30)
(31)		5%	WB	50.5	53.8	59.2	63.2	67.2	70.0	70.6	71.6	70.2	66.4	59.1	53.3	(31)
(32)			MCD B	65.5	71.8	80.5	87.3	92.4	95.5	100.2	98.0	93.9	86.7	76.8	68.0	(32)
(33)		10%	WB	48.9	51.6	56.9	61.2	65.2	67.9	68.5	69.5	68.3	64.6	57.1	51.3	(33)
(34)			MCD B	63.5	69.1	79.1	85.6	93.4	96.2	99.4	98.0	92.1	85.2	74.9	65.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	25.8	26.6	27.5	27.1	26.3	26.3	27.2	26.2	25.9	25.1	26.2	24.8	(35)
(36)			MCDBR	30.1	32.5	32.2	30.9	29.2	28.6	29.2	27.9	28.5	28.3	29.6	29.1	(36)
(37)			MCWBR	16.3	16.8	15.9	13.6	12.1	11.1	12.0	11.1	11.3	12.3	14.4	15.5	(37)
(38)		5% WB	MCDBR	26.8	28.4	28.5	26.4	25.4	25.4	26.9	25.6	24.7	24.5	26.1	26.1	(38)
(39)			MCWBR	15.8	16.5	16.1	13.5	13.0	13.3	13.6	13.2	11.8	12.4	14.3	15.2	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.353	0.385	0.488	0.555	0.610	0.585	0.510	0.504	0.542	0.495	0.405	0.361	(40)
(41)		taud		2.150	2.047	1.776	1.652	1.575	1.638	1.805	1.831	1.748	1.834	2.023	2.140	(41)
(42)		Ebn at Noon		277	278	254	242	229	233	251	252	237	238	255	267	(42)
(43)		Edh at Noon		41	49	69	81	87	82	69	66	70	61	46	40	(43)
(44)	All-Sky Solar Radiation	RadAvg		1356	1627	1961	2198	2333	2470	2553	2376	2057	1680	1387	1233	(44)
(45)		RadStd		64	68	93	92	94	82	35	56	72	89	46	60	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	-3.40	+0.81	-2.99	-3.47	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	-2.45	N/A	-2.03	-2.75	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page