

TAGUENTOUR, Algeria

WMO: 606190

Lat: 28.467N

Lon: 2.517E

Elev: 2087

StdP: 13.62

Time Zone: 1.00 (E01)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.9	36.5	2.7	6.8	71.2	5.6	7.9	70.6	34.3	52.7	31.2	55.3	7.0	10	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.7	110.5	63.7	108.8	63.5	107.0	63.3	67.1	95.7	65.8	97.3	64.9	98.7	10.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.1	80.8	74.7	55.5	70.9	75.6	52.2	62.6	77.6	32.7	94.0	31.6	96.3	30.9	97.8	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
32.0	27.6	24.6	DB	29.0	112.8	2.3	1.1	27.3	113.6	26.0	114.2	24.7	114.9	23.0	115.7	
			WB	24.8	69.2	2.3	2.5	23.1	71.0	21.8	72.4	20.5	73.9	18.8	75.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.8	52.8	56.6	64.5	74.1	82.1	89.8	94.0	91.7	86.9	75.4	62.8	53.6	(6)
	DBStd	15.86	5.50	7.68	7.78	6.96	6.00	4.99	4.05	3.53	5.25	6.41	6.79	6.04	(7)
	HDD50	80	32	21	1	0	0	0	0	0	0	0	1	25	(8)
	HDD65	1232	378	253	105	9	0	0	0	0	0	4	123	360	(9)
	CDD50	8767	120	205	452	724	995	1194	1365	1293	1108	788	385	138	(10)
	CDD65	4443	1	17	91	283	530	744	900	828	658	327	57	7	(11)
	CDH74	69327	27	240	1216	3745	7675	12316	15895	13859	9843	3817	618	76	(12)
	CDH80	45115	0	53	439	1924	4666	8453	11594	9632	6294	1862	185	13	(13)
(14) Wind	WSAvg	11.4	9.7	11.1	11.3	13.0	13.2	12.9	11.7	11.3	10.0	10.6	10.5	11.5	(14)
(15) Precipitation	PrecAvg	1.8	0.2	0.1	0.2	0.2	0.1	0.1	0.0	0.1	0.2	0.2	0.2	0.2	(15)
	PrecMax	3.8	1.4	0.5	1.1	1.3	0.5	0.4	0.2	0.4	1.1	1.0	0.7	0.6	(16)
	PrecMin	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	0.7	0.4	0.1	0.2	0.3	0.2	0.1	0.0	0.1	0.3	0.2	0.2	0.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.5	85.9	94.5	101.3	105.9	111.1	112.7	110.7	107.3	99.5	90.2	82.1	(19)
		MCWB	50.6	53.8	55.8	60.2	61.5	63.1	63.7	64.5	63.4	61.8	59.0	54.9	(20)
	2%	DB	73.3	80.0	88.5	96.6	103.5	109.2	111.2	108.4	105.4	96.1	85.5	74.7	(21)
		MCWB	50.2	52.2	55.2	58.3	61.0	62.9	63.7	64.2	63.1	60.4	56.9	52.7	(22)
	5%	DB	69.7	76.7	85.3	94.0	101.1	107.0	109.9	106.7	103.8	93.6	80.9	70.0	(23)
		MCWB	48.5	50.9	54.3	57.3	60.4	62.4	63.7	63.9	62.7	59.9	55.2	50.6	(24)
	10%	DB	66.1	72.1	81.0	90.7	98.0	104.8	108.2	105.1	101.7	90.1	76.8	66.4	(25)
		MCWB	46.9	49.3	52.7	56.4	59.4	62.1	63.6	63.7	62.6	59.6	54.0	49.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.1	56.9	61.6	62.1	65.6	66.2	66.5	69.7	69.1	64.4	60.7	56.6	(27)
		MCDB	62.3	79.9	72.8	88.0	85.7	97.7	104.6	90.2	87.7	84.7	84.9	72.9	(28)
	2%	WB	51.6	54.3	58.1	60.7	63.5	64.8	65.5	67.6	66.8	62.9	58.4	53.8	(29)
		MCDB	70.7	75.2	78.7	88.8	91.5	99.5	105.0	98.3	88.6	87.1	80.5	70.3	(30)
	5%	WB	49.3	52.1	56.0	58.9	62.1	63.8	64.7	66.2	65.5	61.9	56.4	51.9	(31)
		MCDB	67.9	72.9	80.5	87.7	94.5	100.4	105.5	100.3	90.7	86.5	76.8	67.5	(32)
	10%	WB	47.8	50.3	54.1	57.4	60.7	62.9	64.0	65.1	64.5	60.7	54.6	50.1	(33)
		MCDB	65.8	70.5	79.8	88.4	94.3	101.1	105.1	100.5	93.2	84.7	74.9	64.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	25.1	25.1	26.5	26.9	26.7	26.9	26.7	25.9	25.0	24.8	24.3	24.0	(35)
		MCDBR	27.7	27.2	28.5	28.7	28.1	28.0	26.4	26.2	27.1	26.7	25.7	26.1	(36)
	5% WB	MCWBR	13.4	12.6	12.5	11.6	10.3	9.9	8.9	8.7	8.8	9.7	10.4	12.5	(37)
		MCWBR	25.2	24.1	24.9	25.2	24.6	25.8	25.9	23.7	22.9	24.1	23.8	23.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.338	0.370	0.469	0.506	0.573	0.593	0.590	0.575	0.572	0.500	0.386	0.345	(40)
		taud	2.278	2.162	1.864	1.799	1.678	1.646	1.659	1.712	1.722	1.862	2.141	2.268	(41)
	Ebn at Noon		284	283	260	254	238	232	232	234	228	237	263	275	(42)
		Edh at Noon	36	44	63	69	79	81	80	75	72	59	41	35	(43)
(44) All-Sky Solar Radiation	RadAvg		1367	1626	1946	2186	2292	2426	2408	2257	1935	1661	1411	1240	(44)
	RadStd		53	72	90	74	109	88	56	66	84	76	51	48	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page