

IN SALAH, Algeria

WMO: 606300

Lat: 27.233N

Lon: 2.500E

Elev: 883

StdP: 14.23

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.3	42.6	10.8	9.9	58.7	14.0	11.6	60.9	33.1	59.5	30.4	60.6	1.5	0	0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.0	116.7	72.2	115.1	71.6	113.4	71.0	75.0	108.3	73.4	107.6	72.0	107.0	10.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	94.1	89.3	61.2	83.4	90.6	58.9	76.8	91.1	39.0	108.9	37.4	107.6	36.1	106.9	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
31.0	27.7	24.9	DB	32.7	119.1	2.5	1.3	30.9	120.0	29.5	120.7	28.1	121.4	26.3	122.4	85.1
			WB	28.6	79.8	2.6	2.0	26.7	81.3	25.3	82.5	23.8	83.6	22.0	85.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.4	58.4	63.0	71.3	79.3	88.7	96.4	101.0	99.6	93.8	82.9	68.8	60.8
	DBStd	15.90	5.13	6.17	6.35	6.36	6.04	4.37	2.92	2.92	4.80	5.51	6.15	5.04
	HDD50	4	2	1	0	0	0	0	0	0	0	0	0	1
	HDD65	508	213	100	18	0	0	0	0	0	0	0	29	148
	CDD50	11110	262	364	659	880	1201	1393	1582	1537	1313	1019	565	335
	CDD65	6140	8	43	212	431	736	943	1117	1072	863	554	144	17
	CDH74	100855	139	615	2672	5926	11734	16741	20506	19335	14336	7148	1489	214
	CDH80	71078	18	165	1231	3447	7931	12532	16044	14877	10184	4091	525	33
Wind	WSAvg	11.8	10.4	11.3	11.4	12.3	13.3	12.6	13.7	13.2	11.2	11.1	9.6	11.0
Precipitation	PrecAvg	0.4	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecMax	1.8	0.8	1.2	0.5	0.4	0.4	0.1	0.1	0.5	0.3	0.4	0.3	1.3
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.4	0.2	0.2	0.1	0.1	0.1	0.0	0.0	0.1	0.1	0.1	0.1	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.2	89.8	98.8	107.5	112.6	117.0	118.8	116.9	113.4	107.0	94.4	84.2
		MCWB	56.3	60.9	63.2	67.3	70.4	71.7	73.1	72.4	70.7	67.8	62.9	58.2
	2%	DB	77.4	84.4	94.8	102.5	109.8	115.1	117.2	115.1	111.6	102.6	89.6	79.0
		MCWB	53.6	57.9	61.8	65.6	69.2	71.5	72.5	71.7	70.0	66.8	61.2	56.4
	5%	DB	74.7	80.8	91.1	99.0	107.5	113.2	116.3	113.7	109.9	100.0	86.0	75.6
		MCWB	53.0	56.3	60.6	64.0	68.1	70.9	72.1	71.3	69.6	66.2	59.9	55.2
	10%	DB	71.4	77.3	87.3	95.5	104.3	111.2	114.5	112.2	107.8	96.6	82.4	72.8
		MCWB	51.9	54.3	58.7	62.5	66.8	70.0	71.3	70.8	69.1	65.3	58.7	53.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.3	63.0	66.6	69.9	73.6	76.0	77.4	77.3	76.4	71.8	65.7	61.8
		MCDB	72.3	82.7	87.8	93.3	102.4	108.9	111.8	108.4	104.4	94.2	86.7	76.2
	2%	WB	56.6	59.8	63.8	67.2	70.7	73.4	74.6	74.5	73.3	69.7	63.4	59.0
		MCDB	73.0	80.1	86.7	95.8	102.8	107.9	111.7	108.0	102.2	93.9	83.6	75.4
	5%	WB	54.4	57.5	61.7	65.0	69.0	71.5	72.7	72.8	71.6	68.1	61.6	56.7
		MCDB	71.6	76.6	86.2	93.6	101.3	107.7	111.7	107.6	101.5	94.0	81.7	73.3
	10%	WB	52.4	55.2	59.5	63.0	67.4	70.0	71.2	71.4	70.2	66.5	59.8	54.6
		MCDB	69.4	74.9	84.4	91.5	99.4	106.6	110.8	107.5	101.4	92.4	79.8	71.0
Mean Daily Temperature Range	5% DB	MDBR	26.0	26.3	27.5	28.0	27.2	27.4	26.0	24.8	25.1	24.7	25.5	24.3
		MCDBR	30.0	30.8	33.0	32.3	29.7	29.8	28.4	26.9	27.7	28.8	28.7	28.0
		MCWBR	15.2	15.0	15.2	14.1	12.6	12.4	11.8	10.8	10.5	12.0	13.2	14.4
	5% WB	MCDBR	27.4	27.2	28.1	27.1	26.6	25.8	25.9	24.6	24.2	25.2	25.2	26.2
		MCWBR	15.2	15.0	14.6	13.5	12.7	12.2	12.3	11.2	10.7	11.4	13.0	14.7
Clear-Sky Solar Irradiance	taub	0.381	0.418	0.523	0.567	0.637	0.652	0.629	0.630	0.623	0.550	0.432	0.388	
	taud	2.060	1.954	1.702	1.636	1.534	1.516	1.557	1.580	1.599	1.721	1.952	2.055	
	Ebn at Noon	268	267	246	239	223	219	223	222	217	224	247	259	
	Edh at Noon	45	55	75	82	91	92	88	86	82	68	50	44	
All-Sky Solar Radiation	RadAvg	1387	1623	1950	2187	2292	2411	2428	2266	1967	1674	1419	1267	
	RadStd	57	74	96	84	111	91	44	59	84	76	48	43	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page