

IN SALAH, Algeria

WMO: 606300

Lat: 27.233N

Lon: 2.500E

Elev: 269

StdP: 98.13

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.0	5.9	-11.8	1.4	14.8	-10.0	1.7	16.1	14.8	15.3	13.6	15.9	0.7	0	0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.5	47.1	22.3	46.1	22.0	45.2	21.7	23.9	42.4	23.0	42.0	22.2	41.7	4.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.4	31.8	16.2	11.9	32.6	15.0	11.0	32.8	72.9	42.7	69.0	42.0	66.1	41.6	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	12.4	11.1	0.4	48.4	1.4	0.7	-0.6	48.9	-1.4	49.3	-2.2	49.7	-3.1	50.2		
(5)			-1.9	26.6	1.4	1.1	-2.9	27.4	-3.7	28.0	-4.5	28.7	-5.6	29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.9	14.7	17.2	21.8	26.3	31.5	35.8	38.4	37.5	34.3	28.3	20.5	16.0	(6)
(7)		DBStd	8.83	2.85	3.43	3.53	3.53	3.36	2.43	1.62	1.62	2.67	3.06	3.42	2.80	(7)
(8)		HDD10.0	2	1	1	0	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD18.3	282	118	56	10	0	0	0	0	0	0	0	16	82	(9)
(10)		CDD10.0	6172	146	202	366	489	667	774	879	854	729	566	314	186	(10)
(11)		CDD18.3	3411	4	24	118	239	409	524	621	596	479	308	80	9	(11)
(12)		CDH23.3	56031	77	342	1484	3292	6519	9301	11392	10742	7964	3971	827	119	(12)
(13)	CDH26.7	39488	10	92	684	1915	4406	6962	8913	8265	5658	2273	292	18	(13)	
(14)	Wind	WSAvg	5.3	4.7	5.0	5.1	5.5	5.9	6.1	5.9	5.0	5.0	4.3	4.9	(14)	
(15)	Precipitation	PrecAvg	11	2	2	1	1	0	0	0	1	1	1	3	(15)	
(16)		PrecMax	45	20	31	12	11	9	3	2	13	8	11	8	34	(16)
(17)		PrecMin	0	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	11	6	5	3	2	2	1	0	2	2	2	2	8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	32.1	37.1	41.9	44.8	47.2	48.2	47.2	45.2	41.7	34.7	29.0	(19)
MCWB			13.5	16.0	17.3	19.6	21.3	22.0	22.8	22.4	21.5	19.9	17.1	14.6	(20)	
2%		DB	25.2	29.1	34.9	39.1	43.2	46.2	47.4	46.2	44.2	39.2	32.0	26.1	(21)	
		MCWB	12.0	14.4	16.5	18.7	20.7	21.9	22.5	22.1	21.1	19.3	16.2	13.6	(22)	
5%		DB	23.7	27.1	32.8	37.2	41.9	45.1	46.8	45.4	43.3	37.8	30.0	24.2	(23)	
		MCWB	11.6	13.5	15.9	17.8	20.0	21.6	22.3	21.8	20.9	19.0	15.5	12.9	(24)	
10%		DB	21.9	25.2	30.7	35.3	40.2	44.0	45.8	44.6	42.1	35.9	28.0	22.7	(25)	
		MCWB	11.0	12.4	14.9	17.0	19.3	21.1	21.9	21.5	20.6	18.5	14.8	12.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	17.2	19.2	21.0	23.1	24.5	25.2	24.7	22.1	18.7	16.6	(27)	
MCD B			22.4	28.2	31.0	34.0	39.1	42.7	44.3	42.5	40.2	34.6	30.4	24.6	(28)	
2%		WB	13.6	15.5	17.6	19.6	21.5	23.0	23.7	23.6	23.0	20.9	17.5	15.0	(29)	
		MCD B	22.8	26.7	30.4	35.4	39.3	42.1	44.3	42.2	39.0	34.4	28.7	24.1	(30)	
5%		WB	12.4	14.1	16.5	18.3	20.5	21.9	22.6	22.7	22.0	20.0	16.4	13.7	(31)	
		MCD B	22.0	24.8	30.1	34.2	38.5	42.0	44.3	42.0	38.6	34.4	27.6	23.0	(32)	
10%		WB	11.3	12.9	15.3	17.2	19.7	21.1	21.8	21.9	21.2	19.2	15.4	12.6	(33)	
		MCD B	20.8	23.8	29.1	33.1	37.5	41.5	43.8	42.0	38.6	33.5	26.5	21.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.5	14.6	15.3	15.5	15.1	15.2	14.5	13.8	14.0	13.7	14.2	13.5	(35)
MCD BR			16.6	17.1	18.3	17.9	16.5	16.6	15.8	14.9	15.4	16.0	16.0	15.5	(36)	
MCWBR			8.4	8.3	8.4	7.8	7.0	6.9	6.6	6.0	5.9	6.7	7.3	8.0	(37)	
5% WB		MCD BR	15.2	15.1	15.6	15.0	14.8	14.3	14.4	13.7	13.5	14.0	14.0	14.6	(38)	
		MCWBR	8.5	8.3	8.1	7.5	7.1	6.8	6.8	6.2	5.9	6.3	7.2	8.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.381	0.418	0.523	0.567	0.637	0.652	0.629	0.630	0.623	0.550	0.432	0.388	(40)	
taud		2.060	1.954	1.702	1.636	1.534	1.516	1.557	1.580	1.599	1.721	1.952	2.055	(41)		
Ebn at Noon		844	843	774	755	703	689	703	699	684	706	779	815	(42)		
Edh at Noon		143	172	235	259	287	290	278	270	258	215	158	138	(43)		
(44)	All-Sky Solar Radiation	RadAvg	4.37	5.12	6.15	6.90	7.22	7.60	7.66	7.14	6.20	5.28	4.47	4.00	(44)	
(45)		RadStd	0.18	0.23	0.30	0.26	0.35	0.29	0.14	0.19	0.26	0.24	0.15	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	+0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page