

ILLIZI TAKHAMALT, Algeria

WMO: 606400

Lat: 26.724N

Lon: 8.623E

Elev: 1778

StdP: 13.78

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.5	40.0	14.6	12.3	59.8	17.5	14.2	61.2	28.9	62.0	24.0	63.7	3.5	90	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.8	111.2	69.5	109.4	69.1	107.7	68.9	73.8	101.7	72.3	101.4	71.1	101.1	10.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.3	99.9	84.7	62.5	90.3	87.0	59.6	81.2	89.3	38.5	101.8	37.0	100.8	35.9	101.3	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
24.7	21.9	19.2	DB	32.5	114.4	2.7	1.7	30.5	115.6	28.9	116.6	27.4	117.6	25.5	118.9	
			WB	28.5	77.6	2.2	2.5	26.9	79.4	25.6	80.9	24.3	82.3	22.7	84.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.8	55.4	60.0	68.3	78.1	86.9	92.5	93.6	92.8	89.2	79.2	67.0	58.0
	DBStd	15.01	5.91	6.99	7.79	7.32	5.52	4.24	3.52	3.08	3.90	5.75	6.03	6.10
	HDD50	24	14	4	1	0	0	0	0	0	0	0	0	5
	HDD65	816	305	172	56	3	0	0	0	0	0	0	46	234
	CDD50	9814	180	283	567	843	1143	1274	1353	1328	1176	904	510	253
	CDD65	5131	6	31	158	396	678	824	888	863	726	439	106	16
	CDH74	82716	159	554	2261	5668	10539	14086	15592	14907	11675	5655	1360	260
	CDH80	54505	29	181	1006	3257	6854	9964	11244	10570	7771	3082	483	64
Wind	WSAvg	8.8	7.6	8.7	9.3	9.7	10.4	10.1	9.8	9.3	8.8	8.2	7.1	7.0
Precipitation	PrecAvg	0.9	0.1	0.1	0.1	0.0	0.0	0.1	0.0	0.0	0.1	0.1	0.1	0.1
	PrecMax	2.4	0.7	1.5	1.1	0.7	0.6	0.8	0.0	0.1	1.5	0.9	1.4	0.5
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.6	0.2	0.3	0.3	0.2	0.1	0.2	0.0	0.0	0.3	0.2	0.3	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.1	90.3	97.5	105.6	109.6	113.1	113.4	111.5	108.7	102.2	92.9	86.4
		MCWB	57.1	60.0	63.2	65.5	69.6	69.6	69.8	70.0	69.2	69.4	63.4	57.5
	2%	DB	78.5	85.5	93.7	101.9	106.8	110.8	111.4	109.4	107.2	98.8	89.1	80.6
		MCWB	55.2	57.8	61.5	64.2	68.7	69.1	69.5	69.4	68.8	66.5	61.1	56.4
	5%	DB	74.1	80.8	89.9	98.6	104.1	108.6	109.5	107.6	105.2	96.7	85.8	76.0
		MCWB	53.4	55.8	60.3	63.7	67.3	68.6	69.1	69.4	68.4	65.9	60.2	54.7
	10%	DB	70.0	76.0	86.0	95.2	101.8	106.1	107.6	105.8	103.0	93.9	82.1	71.8
		MCWB	51.6	53.8	58.7	62.7	66.5	68.1	68.6	68.7	67.8	65.2	58.5	53.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.8	62.5	66.8	70.2	74.2	74.4	74.5	74.9	75.4	75.9	67.9	60.8
		MCDB	77.0	85.4	90.8	93.4	102.2	104.4	106.3	102.0	99.4	93.7	88.1	77.3
	2%	WB	57.0	59.1	63.6	66.7	71.5	72.0	72.4	72.7	72.8	70.8	64.2	57.9
		MCDB	74.0	81.2	87.7	94.1	100.3	102.1	105.2	103.5	98.9	89.8	83.8	76.1
	5%	WB	54.5	56.7	61.2	64.7	69.6	70.5	70.9	71.3	71.1	68.5	61.5	55.9
		MCDB	71.5	77.0	85.9	93.4	98.4	101.9	105.1	103.4	97.7	89.6	81.8	73.3
	10%	WB	52.3	54.6	59.2	63.1	67.8	69.2	69.5	70.0	69.6	66.8	59.3	53.9
		MCDB	68.5	73.7	83.1	92.0	97.2	101.5	104.5	102.3	97.5	89.1	79.5	70.6
Mean Daily Temperature Range	5% DB	MDBR	27.1	27.3	28.0	27.8	26.1	25.7	26.8	26.1	26.2	25.7	26.7	25.8
		MCDBR	31.8	32.6	32.3	31.5	28.7	27.4	28.1	27.1	28.1	28.1	30.1	30.3
		MCWBR	16.4	16.2	14.8	13.1	12.1	10.6	10.9	10.7	10.9	11.7	14.1	15.1
	5% WB	MCDBR	29.6	30.2	29.2	28.6	25.9	25.6	26.8	25.7	25.6	25.1	28.0	28.0
		MCWBR	16.7	16.1	14.8	13.3	12.8	11.3	11.9	11.4	11.4	11.7	14.5	14.9
Clear-Sky Solar Irradiance	taub		0.354	0.391	0.498	0.574	0.639	0.627	0.516	0.524	0.555	0.507	0.415	0.365
	taud		2.190	2.074	1.791	1.652	1.556	1.593	1.823	1.822	1.754	1.845	2.035	2.174
	Ebn at Noon		280	278	253	238	223	224	250	247	235	237	255	270
	Edh at Noon		40	49	69	81	89	85	68	67	70	61	47	39
All-Sky Solar Radiation	RadAvg		1415	1655	1995	2198	2300	2427	2529	2355	2064	1706	1433	1289
	RadStd		63	81	106	99	89	95	53	55	76	93	51	62

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	-2.45	N/A	-2.03	-2.75	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page