

DJANET TISKA, Algeria

WMO: 606700

Lat: 24.293N

Lon: 9.452E

Elev: 3176

StdP: 13.09

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.0	37.6	6.9	8.8	54.6	10.3	10.4	55.1	27.0	66.9	22.7	62.3	1.9	350	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	104.1	65.6	102.5	65.1	101.1	64.6	71.0	94.4	68.9	93.5	67.1	93.8	9.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	97.1	84.2	59.5	85.5	84.4	56.7	77.2	83.7	36.9	94.5	35.0	93.0	33.4	93.5	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.4	21.7	18.8	DB	29.1	107.1	3.9	1.5	26.3	108.1	24.1	109.0	21.9	109.9	19.1	111.0	(4)
(5)			WB	24.2	72.4	2.7	3.3	22.3	74.7	20.7	76.6	19.2	78.5	17.3	80.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.4	53.4	58.7	67.2	77.8	85.2	88.9	88.7	88.3	85.6	76.4	65.2	56.8
	DBStd	13.84	5.53	6.40	6.70	5.53	4.62	3.83	2.71	2.76	3.45	5.28	5.32	5.64
	HDD50	34	23	4	0	0	0	0	0	0	0	0	0	7
	HDD65	939	364	194	56	0	0	0	0	0	0	2	61	262
	CDD50	8952	127	248	534	834	1091	1168	1201	1188	1067	819	457	218
	CDD65	4379	2	18	124	384	626	718	736	723	617	356	68	7
	CDH74	64863	49	294	1552	4954	9221	11324	11870	11426	9003	4164	887	119
	CDH80	38748	5	68	529	2566	5623	7355	7713	7303	5433	1949	194	10
Wind	WSAvg	7.3	4.9	6.0	7.7	8.8	9.0	8.8	9.4	8.6	8.1	6.4	5.0	4.5
Precipitation	PrecAvg	0.6	0.0	0.0	0.1	0.0	0.1	0.1	0.0	0.0	0.1	0.1	0.0	0.0
	PrecMax	2.1	0.6	0.4	0.9	0.4	1.0	0.9	0.4	0.4	0.7	0.6	0.1	0.1
	PrecMin	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.5	0.1	0.1	0.2	0.1	0.2	0.2	0.1	0.1	0.2	0.1	0.0	0.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.2	87.6	91.7	100.2	104.0	106.9	105.8	104.2	102.3	97.0	87.7	81.1
		MCWB	54.0	55.8	58.4	63.1	65.2	66.7	65.4	66.8	65.6	62.3	57.5	54.4
	2%	DB	73.8	80.9	89.0	97.0	102.0	104.4	103.8	102.3	100.5	94.6	84.5	77.2
		MCWB	50.9	53.7	57.1	61.7	64.6	65.7	65.2	65.6	64.3	62.0	56.9	52.6
	5%	DB	70.2	77.0	85.9	94.8	100.1	102.4	102.1	100.7	98.9	91.9	82.2	73.7
		MCWB	49.0	52.1	55.8	61.0	63.7	65.0	64.9	64.9	63.6	61.3	56.2	51.0
	10%	DB	67.5	73.6	82.5	91.8	97.8	100.6	100.4	99.1	97.4	89.6	79.1	70.7
		MCWB	47.9	50.4	54.5	59.9	63.0	64.3	64.2	64.1	63.1	60.4	54.7	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.5	58.0	61.7	66.2	72.4	72.7	73.1	73.6	70.9	66.5	62.6	57.4
		MCDB	71.0	77.0	78.1	92.1	95.3	96.9	97.0	96.7	89.2	86.9	81.4	73.3
	2%	WB	53.1	55.6	59.1	63.7	67.8	69.3	69.7	70.4	68.1	64.5	59.4	54.7
		MCDB	69.9	75.4	78.3	91.0	93.3	94.5	93.3	94.7	92.1	84.9	79.5	72.0
	5%	WB	50.8	53.5	57.1	62.0	65.5	67.0	66.9	68.4	66.2	63.3	57.2	52.6
		MCDB	67.6	72.3	80.7	89.5	93.2	94.8	96.2	93.8	92.5	85.4	79.2	70.4
	10%	WB	48.6	51.3	55.3	60.6	63.8	65.4	64.9	66.5	64.7	62.1	55.4	50.8
		MCDB	65.2	71.1	80.6	88.3	93.1	95.2	97.0	93.5	92.8	85.4	77.6	68.8
Mean Daily Temperature Range	5% DB	MDBR	27.7	27.5	26.6	25.7	23.9	22.6	23.3	22.8	23.8	24.5	27.1	27.2
		MCDBR	29.4	30.0	29.1	27.1	25.2	23.7	25.0	23.4	24.4	25.1	27.9	28.7
		MCWBR	15.8	14.1	12.8	10.9	9.2	8.2	9.3	8.6	9.0	9.9	13.0	14.6
	5% WB	MCDBR	27.7	27.0	25.0	24.2	22.8	22.0	23.7	22.2	22.3	23.3	26.5	26.8
		MCWBR	15.7	14.1	12.1	10.7	9.4	8.4	10.0	9.0	8.8	9.6	13.3	15.0
Clear-Sky Solar Irradiance	taub	0.320	0.353	0.451	0.556	0.623	0.621	0.486	0.511	0.510	0.474	0.386	0.330	
	taud	2.260	2.154	1.848	1.637	1.536	1.555	1.836	1.796	1.787	1.856	2.058	2.238	
	Ebn at Noon	297	294	269	244	227	226	258	252	249	250	269	288	
	Edh at Noon	38	46	65	82	91	89	67	69	69	61	47	38	
All-Sky Solar Radiation	RadAvg	1489	1741	2078	2259	2330	2422	2531	2349	2138	1808	1529	1377	
	RadStd	74	104	112	112	95	106	100	59	69	71	77	53	64

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page