

MERTOUEK, AlgeriaWMO: **606720**Lat: **24.227N**Lon: **5.540E**Elev: **1343**StdP: **86.20**Time Zone: **1.00 (E01)**Period: **08-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.6	4.2	-21.5	0.6	16.7	-19.3	0.8	16.5	10.1	15.1	8.7	14.1	1.4	330	0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	37.6	14.7	36.8	14.7	36.1	14.6	17.5	28.9	17.0	29.8	16.5	30.1	2.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.8	11.6	22.1	12.1	10.4	23.3	10.5	9.3	24.5	54.7	28.9	52.7	29.4	51.1	30.0	19.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.2	6.3	-0.1	38.9	1.9	0.5	-1.5	39.3	-2.6	39.5	-3.6	39.8	-5.0	40.1		
(5)			-4.4	18.7	1.7	0.8	-5.6	19.2	-6.6	19.7	-7.6	20.1	-8.8	20.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.9	12.3	15.2	18.7	23.6	28.2	30.5	31.2	30.2	28.7	23.8	18.2	13.7
	DBStd	7.19	3.01	3.86	3.52	2.95	2.11	1.97	1.55	1.48	1.66	2.25	2.41	3.12
	HDD10.0	22	12	4	1	0	0	0	0	0	0	0	0	5
	HDD18.3	507	189	101	39	1	0	0	0	0	0	0	31	146
	CDD10.0	4727	82	151	271	407	563	615	659	627	559	427	246	121
	CDD18.3	2170	1	14	52	158	304	365	401	368	309	169	26	2
	CDH23.3	30182	8	119	504	1882	4174	5608	6243	5351	4195	1807	256	36
	CDH26.7	16361	0	23	89	751	2230	3424	3878	3079	2232	638	15	1
Wind	WSAvg	2.1	1.9	2.2	2.3	2.5	2.4	2.0	2.1	2.0	1.7	1.8	2.0	1.9
Precipitation	PrecAvg	90	3	2	8	2	4	11	10	21	13	8	5	2
	PrecMax	180	19	11	52	13	35	50	43	70	40	55	71	21
	PrecMin	36	0	0	0	0	0	0	1	2	1	0	0	0
	PrecStd	34	5	2	13	3	6	13	9	16	10	13	12	4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.5	29.6	30.2	35.4	36.5	38.5	38.4	37.6	36.1	33.7	28.2	26.2
		MCWB	9.2	11.1	11.5	13.4	14.4	14.6	14.9	15.2	14.9	13.8	12.1	9.5
	2%	DB	22.5	26.7	28.9	33.3	35.6	37.7	37.5	36.5	35.3	32.3	27.0	24.3
		MCWB	8.3	10.1	10.8	12.9	14.1	14.5	14.8	15.2	14.7	13.7	11.3	9.0
	5%	DB	20.9	24.4	27.6	32.1	34.9	36.9	36.8	35.7	34.7	31.2	25.9	22.5
		MCWB	7.5	9.0	10.5	12.2	13.8	14.5	14.7	15.1	14.6	13.4	10.7	8.4
	10%	DB	19.4	22.8	26.3	30.6	34.0	36.0	36.1	35.0	33.9	30.0	24.9	20.9
		MCWB	6.8	8.2	10.1	11.8	13.5	14.3	14.6	15.0	14.5	13.1	10.3	7.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	12.1	13.5	14.8	16.2	17.6	18.2	18.2	17.7	16.2	13.7	10.8
		MCDB	21.1	22.4	21.7	28.9	30.4	28.5	27.6	28.9	27.4	23.9	24.5	21.0
	2%	WB	9.5	11.2	12.6	13.8	15.5	16.7	17.3	17.6	16.9	15.4	12.4	10.0
		MCDB	19.8	23.1	23.4	29.7	31.0	29.5	29.7	29.4	29.0	25.6	23.5	21.5
	5%	WB	8.1	10.1	11.8	13.2	14.9	16.1	16.5	17.0	16.4	14.8	11.6	9.1
		MCDB	19.9	22.4	24.2	29.6	31.4	30.6	31.4	30.2	29.2	26.8	23.5	21.2
	10%	WB	7.1	9.0	10.9	12.5	14.3	15.5	15.8	16.5	15.9	14.1	10.9	8.1
		MCDB	19.3	21.3	24.8	28.9	31.7	31.6	32.5	30.4	29.5	27.2	23.5	20.3
Mean Daily Temperature Range	5% DB	MDBR	12.8	12.6	12.3	12.2	11.0	10.8	9.9	10.1	10.9	11.7	12.3	12.3
		MCDBR	14.2	13.7	13.3	13.1	11.6	11.4	10.5	10.6	11.2	12.5	13.4	14.1
		MCWBR	6.8	6.3	5.5	4.9	4.2	3.6	3.4	3.5	3.4	4.2	5.7	6.4
	5% WB	MCDBR	12.7	12.1	10.4	11.2	10.5	10.9	10.2	10.6	11.0	11.0	11.3	12.7
		MCWBR	6.5	5.8	4.1	4.2	3.6	3.1	3.4	3.3	3.1	3.4	5.0	5.9
Clear-Sky Solar Irradiance	taub	0.282	0.312	0.401	0.473	0.553	0.587	0.498	0.522	0.510	0.443	0.350	0.297	
	taud	2.431	2.334	2.021	1.845	1.685	1.633	1.830	1.793	1.817	1.968	2.223	2.406	
	Ebn at Noon	987	974	896	837	767	736	804	785	784	820	893	954	
	Edh at Noon	101	120	173	211	247	259	212	220	210	171	124	100	
All-Sky Solar Radiation	RadAvg	4.84	5.56	6.62	7.22	7.36	7.39	7.64	7.06	6.46	5.63	4.90	4.50	
	RadStd	0.23	0.30	0.41	0.35	0.28	0.40	0.27	0.24	0.29	0.34	0.17	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.58	+0.97	+1.82	+3	N/A	N/A	+72

Nomenclature: See separate page