

TAMANRASSET ASSEKREM, Algeria

WMO: 606790

Lat: 23.260N

Lon: 5.632E

Elev: 2710

StdP: 72.73

Time Zone: 1.00 (E01)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.4	0.5	-38.6	0.1	7.2	-34.5	0.2	7.5	23.1	3.1	20.7	3.5	8.6	350	0.614

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.8	25.5	8.8	24.7	8.7	24.1	8.7	11.9	19.0	11.4	18.8	10.8	18.7	5.3	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.2	10.1	15.0	8.1	9.4	15.5	7.0	8.7	15.6	42.5	19.1	40.8	19.0	39.3	18.6	14.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.7	16.0	13.5	DB	-5.9	27.1	3.0	0.5	-8.0	27.4	-9.8	27.7	-11.5	28.0	-13.7	28.3	(4)
(5)			WB	-7.7	13.5	1.8	0.4	-9.0	13.7	-10.1	13.9	-11.1	14.1	-12.4	14.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	6.9	8.1	11.0	15.1	18.4	20.2	20.1	18.9	18.2	14.8	10.9	8.0		
	DBStd	5.30	2.62	3.27	3.16	2.48	1.95	1.70	1.48	1.43	1.42	1.91	1.87	2.81		
	HDD10.0	279	101	67	27	1	0	0	0	0	0	0	12	72		
	HDD18.3	1683	355	286	227	101	22	6	4	11	19	109	224	320		
	CDD10.0	1827	4	15	58	153	262	304	312	277	245	149	38	11		
	CDD18.3	189	0	0	0	3	26	60	57	29	14	1	0	0		
	CDH23.3	325	0	0	0	3	32	142	109	34	4	0	0	0		
	CDH26.7	1	0	0	0	0	0	1	1	0	0	0	0	0		
(14) Wind	WSAvg	6.1	6.2	7.4	7.2	6.8	6.1	5.2	5.6	5.3	5.4	5.5	6.5	5.6		
(15) Precipitation	PrecAvg	172	5	2	17	4	11	17	19	45	26	14	10	3		
	PrecMax	344	37	17	124	24	48	79	80	93	65	97	137	26		
	PrecMin	53	0	0	0	0	0	0	0	2	0	0	0	0		
	PrecStd	73	9	5	36	7	14	20	21	31	22	25	31	6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	19.7	19.8	23.9	25.3	26.6	26.3	25.2	23.7	21.6	18.0	16.8		
		MCWB	2.7	5.2	5.1	7.3	8.6	8.8	9.0	9.5	8.8	7.8	5.7	3.9		
	2%	DB	13.8	16.4	18.6	22.3	24.3	25.7	25.3	24.3	23.1	20.6	16.3	15.0		
		MCWB	2.2	4.2	4.8	7.0	8.5	8.7	8.8	9.4	8.9	7.6	4.9	2.7		
	5%	DB	12.3	14.4	17.3	21.1	23.4	25.0	24.5	23.5	22.3	19.6	15.2	13.5		
		MCWB	1.2	2.8	4.3	6.5	8.1	8.6	8.7	9.3	8.7	7.5	4.3	2.0		
	10%	DB	11.0	13.0	16.1	19.8	22.6	24.1	23.8	22.5	21.6	18.5	14.3	12.3		
		MCWB	0.4	2.1	3.9	5.8	7.7	8.5	8.7	9.3	8.6	7.1	3.9	1.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.0	6.1	7.2	8.9	11.1	11.9	12.7	12.7	11.7	10.4	7.7	6.2		
		MCDB	9.6	15.8	13.7	19.5	18.6	19.0	19.2	19.5	19.1	15.6	15.0	8.9		
	2%	WB	3.3	5.0	6.4	7.9	9.9	10.9	11.6	12.1	11.0	9.5	6.6	4.4		
		MCDB	11.3	14.6	13.9	18.8	19.6	19.1	19.2	19.1	19.1	16.1	13.1	12.1		
	5%	WB	2.0	4.0	5.6	7.3	9.2	10.2	10.9	11.6	10.4	8.8	5.7	3.2		
		MCDB	11.4	12.1	14.2	18.7	20.1	20.0	19.2	18.8	18.5	16.3	12.7	12.3		
	10%	WB	1.0	2.9	4.8	6.7	8.7	9.7	10.2	11.1	9.8	8.1	4.8	2.3		
		MCDB	10.5	11.3	14.7	18.3	20.2	20.4	19.6	18.5	18.1	16.2	12.7	11.5		
(35) Mean Daily Temperature Range	MDBR		7.7	8.0	8.4	8.3	8.0	7.8	7.7	7.6	7.4	7.2	7.0	7.7		
	5% DB	MCDBR	8.0	8.2	8.9	8.5	8.1	8.2	8.0	8.2	7.6	7.6	7.5	8.0		
		MCWBR	4.2	4.2	4.0	3.6	3.4	3.2	3.2	3.4	3.2	3.2	3.7	4.1		
	5% WB	MCDBR	7.5	6.9	7.6	7.8	7.9	7.7	7.6	7.5	7.0	6.6	6.6	7.1		
		MCWBR	4.3	4.1	4.0	3.6	3.5	3.3	3.6	3.3	3.2	3.1	3.7	4.2		
(40) Clear-Sky Solar Irradiance	taub		0.235	0.257	0.324	0.402	0.476	0.517	0.433	0.456	0.434	0.377	0.295	0.251		
	taud		2.590	2.510	2.260	2.009	1.821	1.738	1.963	1.917	1.968	2.126	2.409	2.554		
	Ebn at Noon		1054	1041	975	900	829	789	858	841	854	891	967	1021		
	Edh at Noon		87	101	137	180	216	233	186	194	181	147	104	87		
(44) All-Sky Solar Radiation	RadAvg		5.00	5.73	6.77	7.32	7.34	7.27	7.53	6.87	6.39	5.75	5.07	4.67		
	RadStd		0.23	0.35	0.41	0.34	0.33	0.42	0.31	0.27	0.35	0.32	0.18	0.18		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	+0.58	+0.97	+1.82	+3	N/A	N/A	+72

Nomenclature: See separate page