

TABARKA, Tunisia

WMO: 607100

Lat: 36.980N

Lon: 8.877E

Elev: 70

StdP: 100.49

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.0	5.1	0.2	3.8	11.5	1.8	4.3	11.4	15.2	12.8	13.8	13.1	3.2	80	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	38.9	21.6	36.0	21.7	33.8	21.6	25.9	29.7	25.2	29.4	24.5	28.9	3.8	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	20.2	28.0	24.0	19.1	27.6	23.1	18.0	27.2	80.4	29.8	77.2	29.2	74.2	28.9	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.1	10.5	9.2	DB	1.7	43.4	1.2	1.8	0.8	44.7	0.1	45.8	-0.6	46.8	-1.5	48.2	(4)
			WB	1.3	27.2	1.2	0.9	0.4	27.8	-0.3	28.3	-1.0	28.9	-1.8	29.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	11.8	11.8	13.7	16.2	19.6	23.2	26.0	26.5	23.8	20.8	16.3	13.1
	DBStd	5.98	2.43	2.65	2.83	2.85	3.26	3.39	2.94	3.02	2.81	2.97	2.83	2.43
	HDD10.0	27	10	11	2	0	0	0	0	0	0	0	1	3
	HDD18.3	875	203	184	146	79	20	1	0	0	0	8	72	163
	CDD10.0	3170	66	60	118	185	298	397	495	512	413	336	191	99
	CDD18.3	978	0	1	3	14	59	148	237	254	163	86	12	1
	CDH23.3	9700	1	5	47	138	547	1414	2628	2916	1351	581	67	6
CDH26.7	4154	0	0	12	39	224	627	1192	1370	488	193	9	0	
Wind	WSAvg	3.9	4.3	4.4	4.4	4.3	4.0	3.6	3.6	3.3	3.3	3.3	3.8	4.1
Precipitation	PrecAvg	1066	159	128	102	92	47	17	4	14	65	107	164	170
	PrecMax	1314	289	344	234	194	124	68	25	68	130	225	289	289
	PrecMin	573	49	7	2	32	9	0	0	1	0	16	55	61
	PrecStd	177	63	83	54	42	26	18	6	18	36	60	69	63
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.9	23.9	27.9	30.9	35.9	40.2	42.0	41.8	37.9	35.0	28.0	24.0
		MCWB	13.6	14.7	16.2	18.1	20.9	21.3	21.6	21.9	22.4	19.8	16.8	15.8
	2%	DB	19.2	20.3	24.1	27.1	32.1	36.1	38.7	38.5	34.1	31.1	25.1	20.9
		MCWB	13.2	13.5	15.2	16.9	19.3	21.4	21.5	21.8	21.7	19.8	16.2	14.2
	5%	DB	17.2	18.2	21.2	24.1	29.1	33.0	35.1	35.6	31.7	28.4	23.2	18.9
		MCWB	12.7	12.8	14.2	16.0	18.8	20.4	21.7	22.2	22.0	19.8	16.1	13.4
	10%	DB	16.1	16.5	19.1	21.7	26.1	30.1	32.1	32.9	29.2	26.2	21.4	17.2
		MCWB	12.4	12.5	13.8	15.3	17.7	20.6	21.9	22.7	21.9	19.7	16.0	13.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	15.8	17.8	19.5	22.3	24.9	26.8	27.2	25.9	23.6	20.1	16.7
		MCDB	18.4	20.3	24.2	27.1	30.9	30.3	30.2	30.5	29.8	27.9	23.4	20.1
	2%	WB	14.4	14.6	16.1	17.9	20.9	23.5	25.6	26.2	24.6	22.3	18.5	15.6
		MCDB	17.2	18.3	21.1	24.4	28.0	28.9	29.4	29.9	29.0	26.3	21.8	18.2
	5%	WB	13.6	13.8	15.2	17.0	19.9	22.7	24.8	25.5	23.6	21.4	17.5	14.9
		MCDB	16.4	16.9	19.4	21.6	25.6	28.0	29.0	29.5	28.0	25.4	20.8	17.6
	10%	WB	12.8	12.9	14.4	16.2	19.1	22.0	24.1	24.8	22.7	20.6	16.7	14.1
		MCDB	15.5	15.8	18.1	20.2	24.1	27.4	28.6	29.2	27.3	24.7	20.0	16.8
Mean Daily Temperature Range	5% DB	MDBR	7.7	8.0	8.9	9.1	10.0	10.7	10.7	10.7	9.5	9.5	8.3	7.6
		MCDBR	10.4	11.6	13.7	14.4	15.6	16.3	16.5	15.6	13.5	13.3	11.4	10.9
		MCWBR	6.3	6.5	6.9	6.9	6.7	6.6	6.7	6.8	5.9	5.8	5.9	6.1
	5% WB	MCDBR	8.5	9.5	11.0	11.1	12.6	12.4	11.3	11.2	10.5	10.3	9.4	8.2
		MCWBR	5.8	6.1	6.3	6.2	6.2	6.3	6.5	6.6	5.8	5.7	5.7	5.4
Clear-Sky Solar Irradiance	taub	0.352	0.372	0.425	0.470	0.491	0.460	0.487	0.476	0.466	0.431	0.387	0.359	
	taud	2.416	2.350	2.184	2.081	2.058	2.185	2.109	2.142	2.179	2.234	2.331	2.393	
	Ebn at Noon	827	854	835	817	804	828	801	802	786	775	774	789	
	Edh at Noon	88	106	137	160	167	147	157	149	136	118	96	85	
All-Sky Solar Radiation	RadAvg	2.27	3.08	4.36	5.49	6.49	7.46	7.48	6.58	4.95	3.73	2.54	2.05	
	RadStd	0.21	0.25	0.35	0.42	0.38	0.25	0.21	0.30	0.23	0.23	0.17	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page