

BIZERTE, Tunisia

WMO: 607140

Lat: 37.245N

Lon: 9.791E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.8	5.0	0.9	4.0	8.6	2.4	4.5	8.4	14.3	12.1	12.9	12.6	1.6	340	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	37.1	23.0	34.9	23.0	33.0	22.9	26.6	30.7	25.6	30.0	24.8	29.5	5.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.8	21.1	28.6	24.4	19.4	27.5	23.4	18.2	27.0	83.2	31.2	78.5	30.2	75.1	29.7	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.7	9.5	1.4	41.6	1.1	1.9	0.6	42.9	-0.1	44.0	-0.7	45.1	-1.5	46.4		
(5)			1.1	27.3	1.1	1.5	0.3	28.4	-0.3	29.3	-0.9	30.2	-1.7	31.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	11.6	11.5	13.3	15.8	19.5	23.7	26.6	27.2	24.2	21.0	16.2	12.8
	DBStd	6.10	2.09	2.17	2.31	2.28	2.64	2.85	2.24	2.28	2.55	2.70	2.50	2.17
	HDD10.0	22	8	9	2	0	0	0	0	0	0	0	0	3
	HDD18.3	904	209	191	157	82	16	1	0	0	0	6	73	172
	CDD10.0	3184	57	52	104	174	296	412	516	532	427	340	186	90
	CDD18.3	1024	0	0	1	5	53	162	257	273	177	88	8	0
	CDH23.3	9481	0	1	14	53	403	1439	2729	2962	1359	481	37	1
	CDH26.7	3918	0	0	3	9	121	578	1256	1381	444	122	4	0
Wind	WSAvg	4.3	4.2	4.4	4.5	4.5	4.7	4.6	4.7	4.1	4.0	3.8	3.9	4.0
Precipitation	PrecAvg	640	88	79	57	51	24	10	2	11	54	64	94	106
	PrecMax	1028	182	239	156	228	51	61	19	58	218	152	166	209
	PrecMin	398	21	1	1	6	6	0	0	0	8	3	35	23
	PrecStd	157	48	56	37	44	13	15	4	15	42	39	40	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.0	21.2	25.0	28.0	33.4	38.2	39.9	40.3	36.8	33.1	26.9	21.9
		MCWB	14.7	15.2	18.1	19.7	21.1	22.7	23.4	23.2	22.5	21.5	17.3	15.2
	2%	DB	17.9	18.8	21.7	24.8	29.9	34.8	36.7	37.0	33.2	29.8	24.1	19.2
		MCWB	14.1	14.2	16.0	17.5	20.0	22.2	22.9	23.6	23.3	21.8	17.9	15.1
	5%	DB	16.8	17.2	19.9	22.2	27.3	32.1	34.2	34.8	30.9	27.4	22.2	18.0
		MCWB	13.7	13.8	15.1	16.8	19.2	21.6	22.8	23.3	23.5	21.4	17.5	14.5
	10%	DB	15.8	16.0	18.1	20.8	25.2	29.9	32.2	32.9	29.1	25.9	20.9	17.0
		MCWB	13.0	13.0	14.3	16.2	18.5	21.3	22.9	23.4	22.7	20.9	17.0	14.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.4	16.5	18.9	21.2	23.4	26.1	27.6	28.2	27.1	24.9	21.5	17.7
		MCDB	18.0	19.4	23.2	25.6	30.4	30.8	31.1	31.7	30.5	27.9	23.5	19.0
	2%	WB	15.1	15.2	16.9	18.9	21.4	24.4	26.3	26.8	25.6	23.6	19.5	16.1
		MCDB	17.0	17.6	20.1	22.3	26.4	29.7	30.5	31.0	29.5	26.5	21.8	17.7
	5%	WB	14.1	14.2	15.7	17.7	20.3	23.2	25.2	25.7	24.5	22.5	18.5	15.2
		MCDB	16.2	16.5	18.7	21.2	25.0	28.5	30.1	30.2	28.4	25.4	21.0	17.2
	10%	WB	13.2	13.2	14.8	16.8	19.3	22.2	24.2	24.9	23.6	21.7	17.5	14.5
		MCDB	15.2	15.5	17.4	19.8	23.8	27.8	29.4	29.7	27.3	24.7	20.1	16.6
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.4	9.4	9.6	10.4	10.8	10.9	10.8	9.4	9.4	8.5	7.9
		MCDBR	9.7	11.1	13.0	13.2	14.7	15.1	15.0	14.6	12.1	11.7	11.1	9.9
		MCWBR	6.8	7.4	8.1	7.5	6.7	5.6	5.5	5.4	4.9	5.5	6.2	6.6
	5% WB	MCDBR	8.9	10.1	11.5	11.6	12.3	12.8	12.1	11.8	10.7	10.1	9.6	8.7
		MCWBR	6.7	7.1	7.6	7.3	6.5	5.8	5.7	5.7	5.1	5.6	6.4	6.4
Clear-Sky Solar Irradiance	taub		0.352	0.369	0.417	0.460	0.477	0.445	0.468	0.458	0.454	0.425	0.385	0.358
	taud		2.429	2.369	2.223	2.122	2.111	2.245	2.181	2.216	2.235	2.275	2.358	2.412
	Ebn at Noon		826	857	843	825	816	840	817	817	797	782	777	790
	Edh at Noon		87	104	131	154	158	138	146	138	129	113	93	83
All-Sky Solar Radiation	RadAvg		2.25	3.06	4.33	5.49	6.47	7.34	7.34	6.46	4.92	3.69	2.52	2.03
	RadStd		0.18	0.23	0.34	0.39	0.35	0.25	0.20	0.29	0.21	0.22	0.14	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page